

Pendleton School District 16R Lead Analysis Results Summary Report

*PPB - Parts per billion

**EPA recommends action to reduce lead levels if sample is above 20 parts per billion

***ND - Analyte Not Detected

Indicates levels that exceed EPA recommendations

Indicates Retest due to elevated levels of lead

Pendleton Early Learning Center					
Lab Sample #	Retest #	Sample Location		Result mg/L	Result PPB*
160720007-001		Room 173	Sink	0.0012	1.2
160720007-002		Room 180	Drinking Fountain	0.00283	2.8
160720007-003		Gym	Drinking Fountain	ND	ND
160720007-004		Kitchen	Sink	ND	ND
160720007-005		Room 127	Sink	ND	ND
160817097-001		Room 163	WIC Sink	ND	ND
160817097-002		Room 164	WIC Sink	ND	ND
160817097-003		Room 167	Exam Rm Sink	ND	ND
160817097-004		Room 166	Exam Rm Sink	0.00179	1.8
160817097-005		Room 178	Mother's Room Sink	ND	ND
160817097-006		Room 181	Drinking Fountain	0.00485	4.9
160817097-007		Room 157	Breakroom sink	ND	ND
160817097-008		Room 102	Drinking Fountain	ND	ND
160817097-009		Room 103	Drinking Fountain	ND	ND
160817097-010		Room 104	Drinking Fountain	ND	ND
160817097-011		Room 105	Drinking Fountain	0.0017	1.7
160817097-012		Room 106	Drinking Fountain	ND	ND
160817097-013		Room 107	Drinking Fountain	0.00166	1.7
160817097-014		Room 108	Drinking Fountain	ND	ND
160817097-015		Room 109	Drinking Fountain	ND	ND
160817097-016		Room 110	Drinking Fountain	0.00141	1.4
160817097-017		Room 111	Drinking Fountain	ND	ND
160817097-018		Room 112	Drinking Fountain	0.00176	1.8
160817097-019		Room 113	Drinking Fountain	ND	ND
160817097-020		Room 114	Drinking Fountain	0.00153	1.5
160817097-021		Room 115	Drinking Fountain	ND	ND
160817097-022		Room 116	Drinking Fountain	ND	ND
160817097-023		Room 117	Drinking Fountain	0.00228	2.3
160817097-024		Room 118	Drinking Fountain	ND	ND
160817097-025		Room 119	Drinking Fountain	0.00473	4.7

McKay Creek Elementary

Lab Sample #	Retest #	Sample Location		Result mg/L	Result PPB*
160720007-012		Kitchen	Sink	ND	ND
160720007-013		Gym Hallway	Drinking Fountain	0.00584	5.8
160815007-001		Room 145	Drinking Fountain	0.0102	10.2
160815007-002		Room 143	Drinking Fountain	0.0194	19.4
160815007-003		Outside Primary	Drinking Fountain	0.0162	16.2
160815007-004		Room 136	Drinking Fountain	0.0165	16.5
160815007-005		Room 135	Drinking Fountain	0.0412	41.2
160901020-001	Retest 1	Room 135	Drinking Fountain	0.033	33
160930023-003	Retest 2	Room 135	Drinking Fountain	ND	ND
160815007-006		Room 134	Drinking Fountain	0.0495	49.5
160902031-001	Retest 1	Room 134	Drinking Fountain	0.0332	33.2
160930023-002	Retest 2	Room 134	Drinking Fountain	ND	ND
160815007-007		Room 133	Drinking Fountain	0.00645	6.5
160815007-008		Room 127	Drinking Fountain	0.109	10.9
160815007-009		Room 125	Drinking Fountain	0.0249	24.9
160901020-003	Retest 1	Room 125	Drinking Fountain	0.00482	4.8
160815007-010		Room 124	Drinking Fountain	0.0499	49.9
160901020-004	Retest 1	Room 124	Drinking Fountain	0.113	113
160930023-005	Retest 2	Room 124	Drinking Fountain	0.00252	2.5
160815007-011		Room 121	Drinking Fountain	0.0864	86.4
160901020-005	Retest 1	Room 121	Drinking Fountain	0.0742	74.2
160914059-001	Retest 2	Room 121	Drinking Fountain	ND	ND
160815007-012		Room 120	Drinking Fountain	0.0424	42.4
160901020-006	Retest 1	Room 120	Drinking Fountain	0.0165	16.5
160930023-004	Retest 2	Room 120	Drinking Fountain	ND	ND
160815007-013		Room 113	Drinking Fountain	0.0954	95.4
160901020-007	Retest 1	Room 113	Drinking Fountain	0.0196	19.6
160815007-014		Room 116	Drinking Fountain	0.731	731
160901020-008	Retest 1	Room 116	Drinking Fountain	0.0235	23.5
160930023-007	Retest 2	Room 116	Drinking Fountain	0.00112	1.1
160815007-015		Room 117	Drinking Fountain	0.0476	47.6
160901020-009	Retest 1	Room 117	Drinking Fountain	0.0498	49.8
160930023-008	Retest 2	Room 117	Drinking Fountain	0.0219	21.9
161007036-001	Retest 3	Room 117	Drinking Fountain	0.00615	6.2
160815007-016		Outside Intermediate	Drinking Fountain	0.0123	12.3
160815007-017		Gym 104	Drinking Fountain	0.00316	3.2
160815007-018		Room 171 North	Drinking Fountain/S	0.0027	2.7
160815007-019		Room 171 South	Drinking Fountain/S	0.0102	10.2
160720007-011		Staff Room Office	Sink	0.0274	27.4
160817098-001	Retest 1	Staff Room Office	Sink	0.0378	37.8
160902031-002	Retest 2	Staff Room Office	Sink	0.00256	2.6
160930023-001		Room 169	Drinking Fountain	0.00128	1.3

Sherwood Heights Elementary					
Lab Sample #	Retest #	Sample Location		Result mg/L	Result PPB*
160720007-016		Kitchen	Sink	0.00261	2.6
160817096-001		Cafeteria 117	Drinking Fountain	0.00115	1.2
160817096-002		Room 120	Drinking Fountain	0.00212	2.1
160817096-003		Room 124	Breakroom Sink	0.00174	1.7
160817096-004		Room 125	Drinking Fountain	0.00169	1.7
160817096-005		Room 126	Drinking Fountain	0.00403	4
160817096-006		Room 128	Drinking Fountain	0.0021	2.1
160817096-007		Room 129	Drinking Fountain	0.00223	2.2
160817096-008		Room 130	Drinking Fountain	0.00142	1.4
160817096-009		Collaboration 131	Sink	0.00651	6.5
160817096-010		Room 134	Drinking Fountain	ND	ND
160817096-011		Room 139	Drinking Fountain	0.00154	1.5
160817096-012		Room 147	Drinking Fountain	0.00186	1.9
160817096-013		Room 148	Drinking Fountain	0.00191	1.9
160817096-014		Room 149	Drinking Fountain	0.00111	1.1
160817096-015		Room 150	Drinking Fountain	0.001	1
160817096-016		Room 153	Drinking Fountain	ND	ND
160817096-017		Room 154	Drinking Fountain	ND	ND
160817096-018		Room 155	Drinking Fountain	0.00156	1.6
160817096-019		Room 156	Drinking Fountain	0.00106	1.1
160817096-020		Collaboration 158	Sink	0.00158	1.6
160817096-021		Room 157	Drinking Fountain	0.00136	1.4
160817096-022		Gym 159	Drinking Fountain	ND	ND
160817096-023		Room 168	Drinking Fountain	0.0027	2.7
160817096-024		Room 215	Drinking Fountain	0.00129	1.3
160817096-025		Room 216	Drinking Fountain	0.00304	3
160817096-026		Room 217	Drinking Fountain	0.00286	2.9
160817096-027		Room 218	Drinking Fountain	0.00131	1.3
160817096-028		Room 220	Drinking Fountain	0.0011	1.1
160817096-029		Room 222	Drinking Fountain	0.00265	2.7
160817096-030		Room 223	Drinking Fountain	0.00335	3.4
160817096-031		Room 224	Drinking Fountain	0.00153	1.5
160817096-032		Collaboration 225	Sink	0.00116	1.2

Washington Elementary					
Lab Sample #	Retest #	Sample Location		Result mg/L	Result PPB*
160720007-015		Kitchen	Sink	0.00151	1.5
160825044-001		Cafeteria 117	Drinking Fountain	0.0034	3.4
160825044-002		Room 120	Drinking Fountain	ND	ND
160825044-003		Room 124	Breakroom Sink	0.00102	1
160825044-004		Room 125	Drinking Fountain	0.004	4
160825044-005		Room 126	Drinking Fountain	0.00231	2.3
160825044-006		Room 128	Drinking Fountain	0.0163	16.3

160825044-007		Room 129	Drinking Fountain	ND	ND
160825044-008		Room 130	Drinking Fountain	0.0012	1.2
160825044-009		Collaboration 131	Sink	0.00209	2.1
160825044-010		Room 134	Drinking Fountain	ND	ND
160825044-011		Room 139	Drinking Fountain	0.0019	1.9
160825044-012		Room 147	Drinking Fountain	0.00143	1.4
160825044-013		Room 148	Drinking Fountain	ND	ND
160825044-014		Room 149	Drinking Fountain	ND	ND
160825044-015		Room 150	Drinking Fountain	ND	ND
160825044-016		Room 153	Drinking Fountain	0.00243	2.4
160825044-017		Room 154	Drinking Fountain	0.00153	1.5
160825044-018		Room 155	Drinking Fountain	0.00171	1.7
160825044-019		Room 156	Drinking Fountain	0.00192	1.9
160825044-020		Collaboration 158	Sink	0.00114	1.1
160825044-021		Room 157	Drinking Fountain	0.00115	1.2
160825044-022		Gym 159	Drinking Fountain	0.00199	1.2
160825044-023		Room 168	Drinking Fountain	ND	ND
160825044-024		Room 215	Drinking Fountain	0.00134	1.3
160825044-025		Room 216	Drinking Fountain	ND	ND
160825044-026		Room 217	Drinking Fountain	0.00146	1.5
160825044-027		Room 218	Drinking Fountain	ND	ND
160825044-028		Room 220	Drinking Fountain	0.00424	4.2
160825044-029		Room 222	Drinking Fountain	0.00342	3.4
160825044-030		Room 223	Drinking Fountain	0.00307	3.1
160825044-031		Room 224	Drinking Fountain	0.00127	1.3
160825044-032		Collaboration 225	Sink	0.00309	3.1

Sunridge Middle School					
Lab Sample #	Retest #	Sample Location		Result mg/L	Result PPB*
160720007-007		Kitchen	Sink	ND	ND
160720007-008		1st Floor West	Drinking Fountain	0.00177	1.8
160720007-009		2nd Floor West	Drinking Fountain	0.00385	3.9
160720007-010		2nd Floor East	Drinking Fountain	0.00148	1.5
160815008-001		Far East Wing	High Drinking Fount	ND	ND
160815008-002		East Staff Rm	Sink	0.00616	6.2
160815008-003		2nd Floor East	Drinking Fountain	0.011	11
160815008-004		Gym/Locker Rm	High Drinking Fount	0.00112	11.2
160815008-005		1st Floor Staff Rm	Sink	0.00429	4.3
160815008-006		Commons	Drinking Fountain	ND	ND
160815008-007		Band Room	Drinking Fountain	ND	ND
160815008-008		Softball Field	Drinking Fountain	0.00219	2.2

Pendleton High School					
Lab Sample #	Retest #	Sample Location		Result mg/L	Result PPB*
160720007-017		Room 218	Sink	0.00198	2
160720007-018		Room 221	Sink 1	0.0124	12.4
160720007-019		Room 226/227	Sink	0.00344	3.4
160720007-020		2nd Floor	Drinking Fountain	ND	ND
160720007-021		3rd Floor	Drinking Fountain	ND	ND
160720007-022		Bldg 4	Drinking Fountain	ND	ND
160720007-023		Concessions	Sink	0.0243	24.3**
160817027-039	Retest 1	Concession	Sink	ND	ND
160720007-024		Commons	Drinking Fountain	ND	ND
160720007-025		Gold Gym West	Drinking Fountain	ND	ND
160720007-026		Bldg 6	Drinking Fountain	0.00582	5.8
160720007-027		Warberg	Drinking Fountain 1	ND	ND
160817027-001		Room 217B	HS Infant Sink	0.0112	11.2
160817027-002		First Floor	Drinking Fountain	ND	ND
160817027-003		Room 221	Sink 2	0.00175	1.8
160817027-004		Room 221	Sink 3	0.00876	8.8
160817027-005		Room 221	Sink 4	0.00262	2.6
160817027-006		Room 221	Sink 5	0.0058	5.88
160817027-007		Room 221	Sink 6	0.00253	2.5
160817027-008		Room 210	Sink	0.00946	9.5
160817027-009		Room 208	Sink	0.00229	2.3
160817027-010		Bld 4 Greenhouse	Sink	0.00204	2
160817027-011		Bld 4 Room 103	Sink	0.00162	1.6
160817027-012		Bld 4 Room 108	Sink	0.00138	1.4
160817027-013		Staff Room 302	Sink	ND	ND
160817027-014		Office	Drinking Fountain	ND	ND
160817027-015		Health Room (Office)	Sink	ND	ND
160817027-016		Warberg Training Room	Sink	0.00176	1.8
160817027-017		Warberg Gym	Drinking Fountain 2	ND	ND
160817027-018		Room 536	Sink	0.00266	2.3
160817027-019		Student Store	Sink	0.0037	3.7
160817027-020		Room 520A	Sink	ND	ND
160817027-021		Journalism Room	Sink	0.00384	3.8
160817027-022		Conference Room	Sink	0.00123	1.2
160817027-023		Room 905	Sink	0.0019	1.9
160817027-024		Room 904	Sink	0.00199	2
160817027-025		Room 907	Sink	0.0014	1.4
160817027-026		Room 936	Sink	0.00102	1
160817027-027		Room 940	Sink	0.00108	1.1
160817027-028		Gold Gym Girls Dressing Room	Sink 1	0.0345	34.5
160901021-001	Retest 1	Gold Gym Girls Dressing Room	Sink 1	0.0166	16.6
160817027-029		Gold Gym Girls Dressing Room	Sink 2	0.0282	28.2
160901021-002	Retest 1	Gold Gym Girls Dressing Room	Sink 2	0.0213	21.3
160914059-002	Retest 2	Gold Gym Girls Dressing Room	Sink 2	0.02	20

160817027-030		Band Room 1225	Sink	0.0161	16.1
160817027-031		Art Room 1201	Sink 1	ND	ND
160817027-032		Art Room 1201	Sink 2	ND	ND
160817027-033		Art Room 1205	Sink 1	0.00258	2.6
160817027-034		Art Room 1205	Sink 2	0.00509	5.1
160817027-035		Art Room 1205	Sink 3	0.0118	11.8
160817027-036		Dressing Room 1239	Sink	ND	ND
160817027-037		Dressing Room 1242	Sink	ND	ND
160817027-038		Kitchen	Sink	0.00169	1.7

Pendleton Tech & Trades Center					
Lab Sample #	Retest #	Sample Location		Result mg/L	Result PPB*
160720007-006		Kitchen	Sink	0.00387	3.9
161221042-001		Break Room	Sink	0.00369	3.7
161221042-002		Break Room	Drinking Fountain	0.00283	2.8
161221042-003		Room 119	Eye Wash Sink	0.007	7
161221042-004		Room 118	Eye Wash Sink	0.00322	3.2
161221042-005		Room 117	Bubbler	0.022	22
	DISABLED	Room 117	Bubbler - DISABLED	N/A	N/A
161221042-006		Culinary Classroom	Sink	0.00382	3.8
161221042-007		Culinary Kitchen	Pot Filler Spout	0.0721	72
170106007-001		Culinary Kitchen	Pot Filler Spout	ND	ND
161221042-008		Culinary Kitchen	Sink (Ice Machine)	ND	ND