**UMPQUA Research Company**

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT**URC # 9070507**

Pendleton School District	Project: General	Date Reported: 07/29/19
107 NW 10th Street	Project #: Lead/Copper 2019-2020	Date Received: 07/05/19 07:21
Pendleton, OR 97801	Client Contact: Michelle Jones	Sampled By: KLL

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
9070507-01	Sample Location: SMS Girls Locker Room / Restroom Sink 1-PSD 85									
Lead		1030	4	ppb	2	15	07/02/19 11:09	07/10/19	JJL	
Copper			501	ppb	10	1300	07/02/19 11:09	07/10/19	JJL	
9070507-02	Sample Location: SMS Girls Locker Room / Restroom Sink 2-PSD 86									
Lead		1030	9	ppb	2	15	07/02/19 11:08	07/10/19	JJL	
Copper			61	ppb	10	1300	07/02/19 11:08	07/10/19	JJL	
9070507-03	Sample Location: SMS Boys Locker Room / Restroom Sink 1-PSD 87									
Lead		1030	4	ppb	2	15	07/02/19 11:05	07/10/19	JJL	
Copper			108	ppb	10	1300	07/02/19 11:05	07/10/19	JJL	
9070507-04	Sample Location: SMS Boys Locker Room / Restroom Sink 2-PSD 88									
Lead		1030	ND	ppb	2	15	07/02/19 11:07	07/10/19	JJL	
Copper			221	ppb	10	1300	07/02/19 11:07	07/10/19	JJL	
9070507-05	Sample Location: SMS Room 1067 (Home Ec) / Restroom Sink 1-PSD 89									
Lead		1030	ND	ppb	2	15	07/02/19 11:01	07/10/19	JJL	
Copper			115	ppb	10	1300	07/02/19 11:01	07/10/19	JJL	
9070507-06	Sample Location: SMS Room 1067 (Home Ec) / Restroom Sink 2-PSD 90									
Lead		1030	ND	ppb	2	15	07/02/19 11:03	07/10/19	JJL	
Copper			106	ppb	10	1300	07/02/19 11:03	07/10/19	JJL	
9070507-07	Sample Location: SMS Room 1067 (Home Ec) / Restroom Sink 3-PSD 91									
Lead		1030	ND	ppb	2	15	07/02/19 11:02	07/10/19	JJL	
Copper			88	ppb	10	1300	07/02/19 11:02	07/10/19	JJL	
9070507-08	Sample Location: SMS Room 1067 (Home Ec) / Restroom Sink 4-PSD 92									
Lead		1030	2	ppb	2	15	07/02/19 11:02	07/10/19	JJL	
Copper			74	ppb	10	1300	07/02/19 11:02	07/10/19	JJL	
9070507-09	Sample Location: SMS Room 1067 (Home Ec) / Restroom Sink 5-PSD 93									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9070507

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	2	ppb	2	15	07/02/19 11:01	07/10/19	JJL	
Copper			76	ppb	10	1300	07/02/19 11:01	07/10/19	JJL	
9070507-10	Sample Location: SMS Room 1067 (Home Ec) / Restroom Sink 6-PSD 94									
Lead		1030	15	ppb	2	15	07/02/19 11:00	07/10/19	JJL	CON-1
Copper			117	ppb	10	1300	07/02/19 11:00	07/10/19	JJL	
9070507-11	Sample Location: SMS Room 1110 Girls Restroom (Commons) / Restroom Sink-PSD 96									
Lead		1030	ND	ppb	2	15	07/02/19 10:54	07/10/19	JJL	
Copper			94	ppb	10	1300	07/02/19 10:54	07/10/19	JJL	
9070507-12	Sample Location: SMS Room 1111 Boys Restroom (Commons) / Restroom Sink-PSD 97									
Lead		1030	4	ppb	2	15	07/02/19 10:56	07/10/19	JJL	
Copper			78	ppb	10	1300	07/02/19 10:56	07/10/19	JJL	
9070507-13	Sample Location: SMS Room 2021 Girls Restroom (Counseling)) / Restroom Sink-PSD 98									
Lead		1030	6	ppb	2	15	07/02/19 11:14	07/10/19	JJL	
Copper			260	ppb	10	1300	07/02/19 11:14	07/10/19	JJL	
9070507-14	Sample Location: SMS Room 2022 Boys Restroom (Counseling)) / Restroom Sink-PSD 99									
Lead		1030	ND	ppb	2	15	07/02/19 11:15	07/10/19	JJL	
Copper			100	ppb	10	1300	07/02/19 11:15	07/10/19	JJL	
9070507-15	Sample Location: SMS Room 2058 (Lifeskills) / Kitchen Sink-PSD 100									
Lead		1030	ND	ppb	2	15	07/02/19 11:19	07/10/19	JJL	
Copper			34	ppb	10	1300	07/02/19 11:19	07/10/19	JJL	
9070507-16	Sample Location: SMS Room 2058 (Lifeskills) / Restroom Sink-PSD 101									
Lead		1030	ND	ppb	2	15	07/02/19 11:20	07/10/19	JJL	
Copper			35	ppb	10	1300	07/02/19 11:20	07/10/19	JJL	
9070507-17	Sample Location: SMS Library Workroom / Sink-PSD 102									
Lead		1030	2	ppb	2	15	07/02/19 11:24	07/10/19	JJL	
Copper			30	ppb	10	1300	07/02/19 11:24	07/10/19	JJL	
9070507-18	Sample Location: SMS Room 2101 Girls Restroom (6th Grade) / Restroom Sink-PSD 103									
Lead		1030	10	ppb	2	15	07/02/19 11:22	07/10/19	JJL	
Copper			53	ppb	10	1300	07/02/19 11:22	07/10/19	JJL	
9070507-19	Sample Location: SMS Room 2102 Boys Restroom (6th Grade) / Restroom Sink-PSD 104									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9070507

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead	SMS	1030	ND	ppb	2	15	07/02/19 11:23	07/10/19	JJL	
Copper			89	ppb	10	1300	07/02/19 11:23	07/10/19	JJL	
9070507-20	Sample Location: McKay Primary Hallway / Drinking Fountain-PSD 14									
Lead		1030	3	ppb	2	15	07/02/19 08:23	07/10/19	JJL	
Copper			16	ppb	10	1300	07/02/19 08:23	07/10/19	JJL	
9070507-21	Sample Location: McKay Secondary Hallway / Drinking Fountain-PSD 15									
Lead		1030	2	ppb	2	15	07/02/19 08:17	07/10/19	JJL	
Copper			ND	ppb	10	1300	07/02/19 08:17	07/10/19	JJL	
9070507-22	Sample Location: McKay Room 152 / Restroom Sink-PSD 16									
Lead		1030	16	ppb	2	15	07/02/19 08:29	07/10/19	JJL	CON-1
Copper			ND	ppb	10	1300	07/02/19 08:29	07/10/19	JJL	
9070507-23	Sample Location: McKay Room 150 / Restroom Sink-PSD 17									
Lead		1030	2	ppb	2	15	07/02/19 08:28	07/10/19	JJL	
Copper			12	ppb	10	1300	07/02/19 08:28	07/10/19	JJL	
9070507-24	Sample Location: McKay Room 151 / Restroom Sink-PSD 18									
Lead		1030	6	ppb	2	15	07/02/19 08:31	07/10/19	JJL	
Copper			12	ppb	10	1300	07/02/19 08:31	07/10/19	JJL	
9070507-25	Sample Location: McKay Room 145 / Restroom Sink-PSD 19									
Lead		1030	53	ppb	2	15	07/02/19 08:25	07/10/19	JJL	CON-1
Copper			95	ppb	10	1300	07/02/19 08:25	07/10/19	JJL	
9070507-26	Sample Location: McKay Room 144 / Restroom Sink-PSD 20									
Lead		1030	16	ppb	2	15	07/02/19 08:27	07/10/19	JJL	CON-1
Copper			18	ppb	10	1300	07/02/19 08:27	07/10/19	JJL	
9070507-27	Sample Location: McKay Room 138/139 Restroom / Restroom Sink 1-PSD 21									
Lead		1030	5	ppb	2	15	07/02/19 08:20	07/10/19	JJL	
Copper			18	ppb	10	1300	07/02/19 08:20	07/10/19	JJL	
9070507-28	Sample Location: McKay Room 138/139 Restroom / Restroom Sink 2-PSD 22									
Lead		1030	3	ppb	2	15	07/02/19 08:21	07/10/19	JJL	
Copper			10	ppb	10	1300	07/02/19 08:21	07/10/19	JJL	
9070507-29	Sample Location: McKay Room 111 / Restroom Sink-PSD 23									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager

**UMPQUA Research Company**

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT**URC # 9070507****Method: EPA 200.8**

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	19	ppb	2	15	07/02/19 08:34	07/10/19	JJL	CON-1
Copper			12	ppb	10	1300	07/02/19 08:34	07/10/19	JJL	
9070507-30	Sample Location: McKay Locker Rooms / Restroom Sink-PSD 24									
Lead		1030	12	ppb	2	15	07/02/19 08:36	07/10/19	JJL	
Copper			14	ppb	10	1300	07/02/19 08:36	07/10/19	JJL	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager