

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9070501

Pendleton, City of	Project: General	Date Reported: 07/29/19
500 SW Dorian	Project #: Lead/Copper 2019	Date Received: 07/05/19 07:21
Pendleton, OR 97801	Client Contact: Greg Lacquement	Sampled By: KLL

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
9070501-01	Sample Location: PELC Room 171 / Restroom Sink-PSD 1									
Lead		1030	ND	ppb	2	15	07/03/19 11:21	07/10/19	JJL	
Copper			79	ppb	10	1300	07/03/19 11:21	07/10/19	JJL	
9070501-02	Sample Location: PELC Room 170 / Restroom Sink-PSD 2									
Lead		1030	ND	ppb	2	15	07/03/19 11:20	07/10/19	JJL	
Copper			90	ppb	10	1300	07/03/19 11:20	07/10/19	JJL	
9070501-03	Sample Location: PELC Room 180A / Restroom Sink 1-PSD 3									
Lead		1030	ND	ppb	2	15	07/03/19 11:18	07/10/19	JJL	
Copper			101	ppb	10	1300	07/03/19 11:18	07/10/19	JJL	
9070501-04	Sample Location: PELC Room 180A / Restroom Sink 2-PSD 4									
Lead		1030	ND	ppb	2	15	07/03/19 11:18	07/10/19	JJL	
Copper			201	ppb	10	1300	07/03/19 11:18	07/10/19	JJL	
9070501-05	Sample Location: PELC Room 181A / Restroom Sink 1-PSD 5									
Lead		1030	ND	ppb	2	15	07/03/19 11:17	07/10/19	JJL	
Copper			398	ppb	10	1300	07/03/19 11:17	07/10/19	JJL	
9070501-06	Sample Location: PELC Room 181A / Restroom Sink 2-PSD 6									
Lead		1030	ND	ppb	2	15	07/03/19 11:17	07/10/19	JJL	
Copper			198	ppb	10	1300	07/03/19 11:17	07/10/19	JJL	
9070501-07	Sample Location: PELC Playground / Drinking Fountain-PSD 7									
Lead		1030	ND	ppb	2	15	07/03/19 10:58	07/10/19	JJL	
Copper			864	ppb	10	1300	07/03/19 10:58	07/10/19	JJL	
9070501-08	Sample Location: PELC Commons Restroom / Restroom Sink 1-PSD 8									
Lead		1030	ND	ppb	2	15	07/03/19 10:53	07/10/19	JJL	
Copper			130	ppb	10	1300	07/03/19 10:53	07/10/19	JJL	
9070501-09	Sample Location: PELC Commons Restroom / Restroom Sink 2-PSD 9									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9070501

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	ppb	2	15	07/03/19 10:54	07/10/19	JJL	
Copper			179	ppb	10	1300	07/03/19 10:54	07/10/19	JJL	
9070501-10	Sample Location: PELC Commons Restroom / Restroom Sink 3-PSD 10									
Lead		1030	ND	ppb	2	15	07/03/19 10:55	07/10/19	JJL	
Copper			180	ppb	10	1300	07/03/19 10:55	07/10/19	JJL	
9070501-11	Sample Location: PELC Commons Restroom / Restroom Sink 4-PSD 11									
Lead		1030	ND	ppb	2	15	07/03/19 10:56	07/10/19	JJL	
Copper			298	ppb	10	1300	07/03/19 10:56	07/10/19	JJL	
9070501-12	Sample Location: PELC Room 105A / Restroom Sink-PSD 12									
Lead		1030	ND	ppb	2	15	07/03/19 11:01	07/10/19	JJL	
Copper			154	ppb	10	1300	07/03/19 11:01	07/10/19	JJL	
9070501-13	Sample Location: PELC Room 126 / Restroom Sink-PSD 13									
Lead		1030	ND	ppb	2	15	07/03/19 11:11	07/10/19	JJL	
Copper			77	ppb	10	1300	07/03/19 11:11	07/10/19	JJL	
9070501-14	Sample Location: PTTC Room 102 Unisex Restroom / Restroom Sink-PSD 169									
Lead		1030	2	ppb	2	15	07/03/19 09:57	07/10/19	JJL	
Copper			1606	ppb	10	1300	07/03/19 09:57	07/10/19	JJL	CON-1
9070501-15	Sample Location: PTTC Hall Restrooms / Restroom Sink 1-PSD 170									
Lead		1030	4	ppb	2	15	07/03/19 10:02	07/10/19	JJL	
Copper			134	ppb	10	1300	07/03/19 10:02	07/10/19	JJL	
9070501-16	Sample Location: PTTC Hall Restrooms / Restroom Sink 2-PSD 171									
Lead		1030	12	ppb	2	15	07/03/19 10:03	07/10/19	JJL	
Copper			99	ppb	10	1300	07/03/19 10:03	07/10/19	JJL	
9070501-17	Sample Location: PTTC Room 135 Restroom (East End) / Restroom Sink-PSD 172									
Lead		1030	4	ppb	2	15	07/03/19 10:04	07/10/19	JJL	
Copper			409	ppb	10	1300	07/03/19 10:04	07/10/19	JJL	
9070501-18	Sample Location: PTTC Room 118/119 / Sink-PSD 173									
Lead		1030	ND	ppb	2	15	07/03/19 10:00	07/10/19	JJL	
Copper			173	ppb	10	1300	07/03/19 10:00	07/10/19	JJL	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9070501

Qualifiers and Definitions

CON-1	Results confirmed by duplicate analysis.
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager