

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9071906

Pendleton School District
 107 NW 10th Street
 Pendleton, OR 97801

Project: General
 Project #: Sherwood School
 Client Contact: Ken Lebsock

Date Reported: 08/09/19
 Date Received: 07/19/19 09:40
 Sampled By: KLL

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
9071906-01	Sample Location: Room 163/164 Main Hall Restroom / Restroom Sink 1-PSD 25									
Lead (¢)		1030	ND	ppb	2	15	07/16/19 06:34	07/25/19	TWW	
9071906-02	Sample Location: Room 163/164 Main Hall Restroom / Restroom Sink 2-PSD 26									
Lead (¢)		1030	ND	ppb	2	15	07/16/19 06:34	07/25/19	TWW	
9071906-03	Sample Location: Room 163/164 Main Hall Restroom / Restroom Sink 3- PSD 27									
Lead (¢)		1030	5	ppb	2	15	07/16/19 06:35	07/25/19	TWW	
9071906-04	Sample Location: Room 163/164 Main Hall Restroom / Restroom Sink 4-PSD 28									
Lead (¢)		1030	3	ppb	2	15	07/16/19 06:35	07/25/19	TWW	
9071906-05	Sample Location: Room 161A / Restroom Sink-PSD 29									
Lead (¢)		1030	ND	ppb	2	15	07/16/19 06:36	07/25/19	TWW	
9071906-06	Sample Location: Room 108 / Restroom Sink-PSD 30									
Lead (¢)		1030	ND	ppb	2	15	07/16/19 06:25	07/25/19	TWW	
9071906-07	Sample Location: Room 111 / Restroom Sink-PSD 31									
Lead (¢)		1030	ND	ppb	2	15	07/16/19 06:27	07/25/19	TWW	
9071906-08	Sample Location: Room 115 / Restroom Sink-PSD 32									
Lead (¢)		1030	ND	ppb	2	15	07/16/19 06:28	07/25/19	TWW	
9071906-09	Sample Location: Room 116 / Restroom Sink-PSD 33									
Lead (¢)		1030	2	ppb	2	15	07/16/19 06:28	07/25/19	TWW	
9071906-10	Sample Location: Room 122-Boys (1st Grade Collab) / Restroom Sink 1-PSD 34									
Lead (¢)		1030	3	ppb	2	15	07/16/19 06:39	07/25/19	TWW	
9071906-11	Sample Location: Room 122-Boys (1st Grade Collab) / Restroom Sink 2-PSD 35									
Lead (¢)		1030	ND	ppb	2	15	07/16/19 06:39	07/25/19	TWW	
9071906-12	Sample Location: Room 123-Girls (1st Grade Collab) / Restroom Sink 1-PSD 36									
Lead (¢)		1030	3	ppb	2	15	07/16/19 06:40	07/25/19	TWW	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9071906

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
9071906-13	Sample Location: Room 123-Girls (1st Grade Collab) / Restroom Sink 2-PSD 37									
Lead (¢)		1030	2	ppb	2	15	07/16/19 06:40	07/25/19	TWW	
9071906-14	Sample Location: Playground / Drinking Fountain-PSD 38									
Lead (¢)		1030	3	ppb	2	15	07/16/19 06:57	07/25/19	TWW	
9071906-15	Sample Location: Room 137 / Restroom Sink-PSD 39									
Lead (¢)		1030	ND	ppb	2	15	07/16/19 06:44	07/25/19	TWW	
9071906-16	Sample Location: Room 142/143 (Grade 2/3 Collab) Restroom / Restroom Sink 1-PSD 40									
Lead (¢)		1030	3	ppb	2	15	07/16/19 06:50	07/25/19	TWW	
9071906-17	Sample Location: Room 142/143 (Grade 2/3 Collab) Restroom / Restroom Sink 2-PSD 41									
Lead (¢)		1030	ND	ppb	2	15	07/16/19 06:49	07/25/19	TWW	
9071906-18	Sample Location: Room 142/143 (Grade 2/3 Collab) Restroom / Restroom Sink 3-PSD 42									
Lead (¢)		1030	4	ppb	2	15	07/16/19 06:49	07/25/19	TWW	
9071906-19	Sample Location: Room 142/143 (Grade 2/3 Collab) Restroom / Restroom Sink 4-PSD 43									
Lead (¢)		1030	2	ppb	2	15	07/16/19 06:48	07/25/19	TWW	
9071906-20	Sample Location: Room 142/143 (Grade 2/3 Collab) Restroom / Restroom Sink 5-PSD 44									
Lead (¢)		1030	ND	ppb	2	15	07/16/19 06:48	07/25/19	TWW	
9071906-21	Sample Location: Room 144 / Restroom Sink-PSD 45									
Lead (¢)		1030	4	ppb	2	15	07/16/19 06:52	07/25/19	TWW	
9071906-22	Sample Location: Room 146 / Restroom Sink-PSD 46									
Lead (¢)		1030	4	ppb	2	15	07/16/19 06:53	07/25/19	TWW	
9071906-23	Sample Location: Room 210/211 (Grade 4/5 Collab) Restroom / Restroom Sink 1-PSD 47									
Lead (¢)		1030	14	ppb	2	15	07/16/19 07:08	07/25/19	TWW	
9071906-24	Sample Location: Room 210/211 (Grade 4/5 Collab) Restroom / Restroom Sink 2-PSD 48									
Lead (¢)		1030	15	ppb	2	15	07/16/19 07:08	07/25/19	TWW	
9071906-25	Sample Location: Room 210/211 (Grade 4/5 Collab) Restroom / Restroom Sink 3-PSD 49									
Lead (¢)		1030	17	ppb	2	15	07/16/19 07:07	07/25/19	TWW	CON-1
9071906-26	Sample Location: Room 210/211 (Grade 4/5 Collab) Restroom / Restroom Sink 4-PSD 50									
Lead (¢)		1030	8	ppb	2	15	07/16/19 07:07	07/25/19	TWW	
9071906-27	Sample Location: Room 210/211 (Grade 4/5 Collab) Restroom / Restroom Sink 5-PSD 51									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9071906

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead (±)		1030	5	ppb	2	15	07/16/19 07:06	07/25/19	TWW	
9071906-28	Sample Location: Room 212 / Restroom Sink-PSD 52									
Lead (±)		1030	5	ppb	2	15	07/16/19 07:05	07/25/19	TWW	
9071906-29	Sample Location: Room 214 / Restroom Sink-PSD 53									
Lead (±)		1030	7	ppb	2	15	07/16/19 07:04	07/25/19	TWW	
9071906-30	Sample Location: Room 221 / Drinking Fountain-PSD 54									
Lead (±)		1030	2	ppb	2	15	07/16/19 07:02	07/25/19	TWW	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9071906

Qualifiers and Definitions

CON-1	Results confirmed by duplicate analysis.
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager