

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9072414

Pendleton School District 107 NW 10th Street Pendleton, OR 97801	Project: General Project #: Washington Elementry Client Contact: Ken Lebsock	Date Reported: 08/09/19 Date Received: 07/24/19 11:40 Sampled By: KLL
--	--	---

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
9072414-01	Sample Location: Room 163/164 Main Hall Restroom Sink 1/PSD 55									
	Lead (¢)	1030	ND	ppb	2	15	07/22/19 10:25	07/30/19	TWW	
9072414-02	Sample Location: Room 163/164 Main Hall Restroom Sink 2/PSD 56									
	Lead (¢)	1030	ND	ppb	2	15	07/22/19 10:25	07/30/19	TWW	
9072414-03	Sample Location: Room 163/164 Main Hall Restroom Sink 3/PSD 57									
	Lead (¢)	1030	4	ppb	2	15	07/22/19 10:26	07/30/19	TWW	
9072414-04	Sample Location: Room 163/164 Main Hall Restroom Sink 4/PSD 58									
	Lead (¢)	1030	ND	ppb	2	15	07/22/19 10:26	07/30/19	TWW	
9072414-05	Sample Location: Room 161A Restroom Sink /PSD 59									
	Lead (¢)	1030	ND	ppb	2	15	07/22/19 10:27	07/30/19	TWW	
9072414-06	Sample Location: Room 108 Restroom Sink /PSD 60									
	Lead (¢)	1030	ND	ppb	2	15	07/22/19 10:19	07/30/19	TWW	
9072414-07	Sample Location: Room 111 Restroom Sink /PSD 61									
	Lead (¢)	1030	2	ppb	2	15	07/22/19 10:20	07/30/19	TWW	
9072414-08	Sample Location: Room 115 Restroom Sink /PSD 62									
	Lead (¢)	1030	ND	ppb	2	15	07/22/19 10:22	07/30/19	TWW	
9072414-09	Sample Location: Room 116 Restroom Sink /PSD 63									
	Lead (¢)	1030	ND	ppb	2	15	07/22/19 10:23	07/30/19	TWW	
9072414-10	Sample Location: Room 122-Boys (1st Grade Collab) Restroom Sink 1 /PSD 64									
	Lead (¢)	1030	5	ppb	2	15	07/22/19 10:30	07/30/19	TWW	
9072414-11	Sample Location: Room 122-Boys (1st Grade Collab) Restroom Sink 2 /PSD 65									
	Lead (¢)	1030	ND	ppb	2	15	07/22/19 10:30	07/30/19	TWW	
9072414-12	Sample Location: Room 123 Girls (1st Grade Collab) Restroom Sink 1 /PSD 66									
	Lead (¢)	1030	ND	ppb	2	15	07/22/19 10:31	07/30/19	TWW	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9072414

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
9072414-13	Sample Location: Room 123 Girls (1st Grade Collab) Restroom Sink 2/PSD 67									
Lead (¢)		1030	ND	ppb	2	15	07/22/19 10:31	07/30/19	TWW	
9072414-14	Sample Location: Playground Drinking Fountain/PSD 68									
Lead (¢)		1030	10	ppb	2	15	07/22/19 10:35	07/30/19	TWW	
9072414-15	Sample Location: Room 137 Restroom Sink-PSD 69									
Lead (¢)		1030	4	ppb	2	15	07/22/19 10:33	07/30/19	TWW	
9072414-16	Sample Location: Room 142/143 Grade 2/3 Collab Restroom Sink 1-PSD 70									
Lead (¢)		1030	ND	ppb	2	15	07/22/19 10:37	07/30/19	TWW	
9072414-17	Sample Location: Room 142/143 Grade 2/3 Collab Restroom Sink 2-PSD 71									
Lead (¢)		1030	4	ppb	2	15	07/22/19 10:37	07/30/19	TWW	
9072414-18	Sample Location: Room 142/143 Grade 2/3 Collab Restroom Sink 3-PSD 72									
Lead (¢)		1030	2	ppb	2	15	07/22/19 10:38	07/30/19	TWW	
9072414-19	Sample Location: Room 142/143 Grade 2/3 Collab Restroom Sink 4-PSD 73									
Lead (¢)		1030	ND	ppb	2	15	07/22/19 10:38	07/30/19	TWW	
9072414-20	Sample Location: Room 142/143 Grade 2/3 Collab Restroom Sink 5-PSD 74									
Lead (¢)		1030	3	ppb	2	15	07/22/19 10:39	07/30/19	TWW	
9072414-21	Sample Location: Room 144 Restroom Sink-PDS 75									
Lead (¢)		1030	ND	ppb	2	15	07/22/19 10:41	07/30/19	TWW	
9072414-22	Sample Location: Room 146 Restroom Sink-PDS 76									
Lead (¢)		1030	2	ppb	2	15	07/23/19 06:51	07/30/19	TWW	
9072414-23	Sample Location: Room 210/211 Grade 4/5 Collab Restroom Sink 1-PSD 77									
Lead (¢)		1030	8	ppb	2	15	07/23/19 10:48	07/30/19	TWW	
9072414-24	Sample Location: Room 210/211 Grade 4/5 Collab Restroom Sink 2-PSD 78									
Lead (¢)		1030	13	ppb	2	15	07/23/19 10:49	07/30/19	TWW	
9072414-25	Sample Location: Room 210/211 Grade 4/5 Collab Restroom Sink 3-PSD 79									
Lead (¢)		1030	12	ppb	2	15	07/23/19 10:49	07/30/19	TWW	
9072414-26	Sample Location: Room 210/211 Grade 4/5 Collab Restroom Sink 4-PSD 80									
Lead (¢)		1030	3	ppb	2	15	07/23/19 10:50	07/30/19	TWW	
9072414-27	Sample Location: Room 210/211 Grade 4/5 Collab Restroom Sink 5-PSD 81									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9072414

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead (±)		1030	7	ppb	2	15	07/23/19 10:50	07/30/19	TWW	
9072414-28	Sample Location: Room 212 Restroom Sink-PSD 82									
Lead (±)		1030	10	ppb	2	15	07/23/19 10:47	07/30/19	TWW	
9072414-29	Sample Location: Room 214 Restroom Sink-PSD 83									
Lead (±)		1030	8	ppb	2	15	07/23/19 10:47	07/30/19	TWW	
9072414-30	Sample Location: Room 221 Drinking Fountain-PSD 84									
Lead (±)		1030	5	ppb	2	15	07/22/19 10:45	07/30/19	TWW	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9072414

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager