

## Test Kit Placement Log

**Name & Physical Address of School Being Tested:** Pendleton Early Learning Center - 455 SW 13th Street, Pendleton, OR 97801

**Building:** Main Building

**Radon Testing Contact at School:** Ken Lebsock, 541.966.3268

**Name of Individual(s) Performing Testing:**

**Logger:**

Ken Lebsock

**Placer:**

Ken Lebsock

Room Description (per Floor Plan)	Canister serial #	Date Opened	Time Opened	Date Closed	Time Closed	Type of Test D=detector kit	Test Results
101	7275868	12/31/2019	6:41 AM	1/2/2020	8:58 AM	D	2.5 pCi/L
102	7275869	12/31/2019	6:41 AM	1/2/2020	9:12 AM	D	1.6 pCi/L
103	7275870	12/31/2019	6:41 AM	1/2/2020	8:59 AM	D	2.1 pCi/L
104	7275871	12/31/2019	6:41 AM	1/2/2020	9:11 AM	D	2.5 pCi/L
104	7275872	12/31/2019	6:42 AM	1/2/2020	9:11 AM	Duplicate	2.1 pCi/L
105	7275873	12/31/2019	6:42 AM	1/2/2020	9:02 AM	D	2.4 pCi/L
106	7275874	12/31/2019	6:42 AM	1/2/2020	9:11 AM	D	1.5 pCi/L
107	7275875	12/31/2019	6:42 AM	1/2/2020	9:02 AM	D	4.5 pCi/L
109	4275856	12/31/2019	6:43 AM	1/2/2020	9:03 AM	D	1.9 pCi/L
110	4275857	12/31/2019	6:43 AM	1/2/2020	9:10 AM	D	2.0 pCi/L
111	4275858	12/31/2019	6:43 AM	1/2/2020	9:04 AM	D	3.4 pCi/L
112	4275861	12/31/2019	6:44 AM	1/2/2020	9:09 AM	D	2.8 pCi/L
113	4275862	12/31/2019	6:44 AM	1/2/2020	9:05 AM	D	2.9 pCi/L
114	4275863	12/31/2019	6:44 AM	1/2/2020	9:09 AM	D	3.0 pCi/L
115	4275864	12/31/2019	6:45 AM	1/2/2020	9:06 AM	D	2.5 pCi/L
116	4275865	12/31/2019	6:50 AM	1/2/2020	9:08 AM	D	3.9 pCi/L
116	4275846	12/31/2019	6:50 AM	1/2/2020	9:08 AM	Blank	<0.4 pCi/L
117	4275847	12/31/2019	6:46 AM	1/2/2020	9:06 AM	D	3.0 pCi/L
117	4275848	12/31/2019	6:46 AM	1/2/2020	9:06 AM	Duplicate	2.8 pCi/L
118	4275849	12/31/2019	6:46 AM	1/2/2020	9:08 AM	D	3.2 pCi/L
119	4275850	12/31/2019	6:47 AM	1/2/2020	9:07 AM	D	3.4 pCi/L
125	4275859	12/31/2019	6:47 AM	1/2/2020	9:04 AM	D	3.3 pCi/L
126	4275860	12/31/2019	6:47 AM	1/2/2020	9:04 AM	D	4.6 pCi/L
133	4275867	12/31/2019	6:50 AM	1/2/2020	8:57 AM	D	2.3 pCi/L
135	4275851	12/31/2019	6:51 AM	1/2/2020	8:57 AM	D	2.6 pCi/L
141	4275852	12/31/2019	6:51 AM	1/2/2020	8:56 AM	D	6.4 pCi/L
142	4275853	12/31/2019	6:48 AM	1/2/2020	8:54 AM	D	12.6 pCi/L
142	4275854	12/31/2019	6:48 AM	1/2/2020	8:54 AM	D	12.6 pCi/L

142	4275855	12/31/2019	6:48 AM	1/2/2020	8:54 AM	Duplicate	11.8 pCi/L
142	4275836	12/31/2019	6:48 AM	1/2/2020	8:54 AM	Blank	<0.4 pCi/L
146	4275837	12/31/2019	6:39 AM	1/2/2020	8:55 AM	D	<0.4 pCi/L
150	4275838	12/31/2019	6:40 AM	1/2/2020	8:52 AM	D	3.7 pCi/L
150	4275839	12/31/2019	6:40 AM	1/2/2020	8:52 AM	D	3.6 pCi/L
150	4275840	12/31/2019	6:40 AM	1/2/2020	8:51 AM	D	3.6 pCi/L
150	4275841	12/31/2019	6:40 AM	1/2/2020	8:51 AM	Duplicate	3.2 pCi/L
150	4275842	12/31/2019	6:40 AM	1/2/2020	8:51 AM	Blank	<0.4 pCi/L
154	4275843	12/31/2019	6:41 AM	1/2/2020	8:50 AM	D	2.2 pCi/L
154	4275844	12/31/2019	6:41 AM	1/2/2020	8:50 AM	D	1.7 pCi/L
157	4275845	12/31/2019	6:41 AM	1/2/2020	8:49 AM	D	1.7 pCi/L
158	4275826	12/31/2019	6:35 AM	1/2/2020	8:39 AM	D	1.2 pCi/L
159	4275827	12/31/2019	6:35 AM	1/2/2020	8:43 AM	D	1.6 pCi/L
160	4275828	12/31/2019	6:35 AM	1/2/2020	8:42 AM	D	1.2 pCi/L
162	4275829	12/31/2019	6:36 AM	1/2/2020	8:40 AM	D	3.3 pCi/L
163	4275830	12/31/2019	6:36 AM	1/2/2020	8:41 AM	D	2.2 pCi/L
164	4275831	12/31/2019	6:36 AM	1/2/2020	8:41 AM	D	2.2 pCi/L
168	4275832	12/31/2019	6:36 AM	1/2/2020	8:42 AM	D	0.8 pCi/L
173	4275833	12/31/2019	6:37 AM	1/2/2020	8:46 AM	D	7.4 pCi/L
175	4275834	12/31/2019	6:37 AM	1/2/2020	8:34 AM	D	2.0 pCi/L
175	4275835	12/31/2019	6:38 AM	1/2/2020	8:44 AM	Duplicate	2.1 pCi/L
179	4275816	12/31/2019	6:38 AM	1/2/2020	8:44 AM	D	1.2 pCi/L
180	4275817	12/31/2019	6:38 AM	1/2/2020	8:43 AM	D	2.6 pCi/L
181	4275818	12/31/2019	6:38 AM	1/2/2020	8:48 AM	D	2.8 pCi/L
Spike	3887573	12/27/2019		12/30/2019	8:48 AM	Spike	27.1 pCi/L
Spike	3887566	12/27/2019		12/30/2019	8:48 AM	Spike	25.1 pCi/L



NELAC NY 11769  
NRPP 103216 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Pendleton Early Learning Center  
455 Southwest 13th Street  
Pendleton OR 97801

Pendleton Early Learning Center  
455 Southwest 13th Street  
Pendleton OR 97801

Log Number	Device Number	Test Exposure Duration:		Area Tested		Result pCi/L
2611273	4275868	12/31/2019 6:41 am	01/02/2020 8:58 am	Main Building Room 101		2.5
2611274	4275869	12/31/2019 6:41 am	01/02/2020 9:12 am	Main Building Room 102		1.6
2611275	4275870	12/31/2019 6:41 am	01/02/2020 8:59 am	Main Building Room 103		2.1
2611276	4275871	12/31/2019 6:41 am	01/02/2020 9:11 am	Main Building Room 104		2.5
2611277	4275872	12/31/2019 6:42 am	01/02/2020 9:11 am	Main Building Room 104		2.1
2611278	4275873	12/31/2019 6:42 am	01/02/2020 9:02 am	Main Building Room 105		2.4
2611279	4275874	12/31/2019 6:42 am	01/02/2020 9:11 am	Main Building Room 106		1.5
2611280	4275875	12/31/2019 6:42 am	01/02/2020 9:02 am	Main Building Room 107		4.5
2611281	4275856	12/31/2019 6:43 am	01/02/2020 9:03 am	Main Building Room 109		1.9
2611282	4275857	12/31/2019 6:43 am	01/02/2020 9:10 am	Main Building Room 110		2.0
2611283	4275858	12/31/2019 6:43 am	01/02/2020 9:04 am	Main Building Room 111		3.4

**Comment:** A copy of this report was emailed to klebsock@pendletonsd.org.

Test Performed By: Ken Lebsack

Distributed by: Inspect USA

Date Received: 01/06/2020 Date Logged: 01/06/2020 Date Analyzed: 01/07/2020 Date Reported: 01/07/2020

Report Reviewed By: Michael Cleveland

Report Approved By: Shawn Price

**Disclaimer:**

The uncertainty of this radon measurement is  $\pm 10\%$ . Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NELAC NY 11769  
NRPP 103216 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Pendleton Early Learning Center  
455 Southwest 13th Street  
Pendleton OR 97801

Pendleton Early Learning Center  
455 Southwest 13th Street  
Pendleton OR 97801

Log Number	Device Number	Test Exposure Duration:		Area Tested		Result pCi/L
2611284	4275861	12/31/2019 6:44 am	01/02/2020 9:09 am	Main Building Room 112		2.8
2611285	4275862	12/31/2019 6:44 am	01/02/2020 9:05 am	Main Building Room 113		2.9
2611286	4275863	12/31/2019 6:44 am	01/02/2020 9:09 am	Main Building Room 114		3.0
2611287	4275864	12/31/2019 6:45 am	01/02/2020 9:06 am	Main Building Room 115		2.5
2611288	4275865	12/31/2019 6:50 am	01/02/2020 9:08 am	Main Building Room 116		3.9
2611289	4275846	12/31/2019 6:50 am	01/02/2020 9:08 am	Main Building Room 116		< 0.4
2611290	4275847	12/31/2019 6:46 am	01/02/2020 9:06 am	Main Building Room 117		3.0
2611291	4275848	12/31/2019 6:46 am	01/02/2020 9:06 am	Main Building Room 117		2.8
2611292	4275849	12/31/2019 6:46 am	01/02/2020 9:08 am	Main Building Room 118		3.2
2611293	4275850	12/31/2019 6:47 am	01/02/2020 9:07 am	Main Building Room 119		3.4
2611294	4275859	12/31/2019 6:47 am	01/02/2020 9:04 am	Main Building Room 125		3.3

**Comment:** A copy of this report was emailed to klebsock@pendletonsd.org.

Test Performed By: Ken Lebsock

Distributed by: Inspect USA

Date Received: 01/06/2020 Date Logged: 01/06/2020 Date Analyzed: 01/07/2020 Date Reported: 01/07/2020

Report Reviewed By: Michelle Cleveland

Report Approved By: Shawn Price

**Disclaimer:**

The uncertainty of this radon measurement is ~+/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.



NELAC NY 11769  
NRPP 103216 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Pendleton Early Learning Center  
455 Southwest 13th Street  
Pendleton OR 97801

Pendleton Early Learning Center  
455 Southwest 13th Street  
Pendleton OR 97801

Log Number	Device Number	Test Exposure Duration:		Area Tested	Result pCi/L
2611295	4275860	12/31/2019 6:47 am	01/02/2020 9:04 am	Main Building Room 126	4.6
2611296	4275867	12/31/2019 6:50 am	01/02/2020 8:57 am	Main Building Room 133	2.3
2611297	4275851	12/31/2019 6:51 am	01/02/2020 8:57 am	Main Building Room 135	2.6
2611298	4275852	12/31/2019 6:51 am	01/02/2020 8:56 am	Main Building Room 141	6.4
2611299	4275853	12/31/2019 6:48 am	01/02/2020 8:54 am	Main Building Room 142	12.6
2611300	4275854	12/31/2019 6:48 am	01/02/2020 8:54 am	Main Building Room 142	12.6
2611301	4275855	12/31/2019 6:48 am	01/02/2020 8:54 am	Main Building Room 142	11.8
2611302	4275836	12/31/2019 6:48 am	01/02/2020 8:54 am	Main Building Room 142	< 0.4
2611303	4275837	12/31/2019 6:39 am	01/02/2020 8:55 am	Main Building Room 146	< 0.4
2611304	4275838	12/31/2019 6:40 am	01/02/2020 8:52 am	Main Building Room 150	3.7
2611305	4275839	12/31/2019 6:40 am	01/02/2020 8:52 am	Main Building Room 150	3.6

**Comment:** A copy of this report was emailed to klebsock@pendletonsd.org.

Test Performed By: Ken Lebsock

Distributed by: Inspect USA

Date Received: 01/06/2020 Date Logged: 01/06/2020 Date Analyzed: 01/07/2020 Date Reported: 01/07/2020

Report Reviewed By: Michael Cleveland

Report Approved By: Shawn Price

**Disclaimer:**

The uncertainty of this radon measurement is  $\pm 10\%$ . Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NELAC NY 11769  
NRPP 103216 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Pendleton Early Learning Center  
455 Southwest 13th Street  
Pendleton OR 97801

Pendleton Early Learning Center  
455 Southwest 13th Street  
Pendleton OR 97801

Log Number	Device Number	Test Exposure Duration:		Area Tested		Result pCi/L
2611306	4275840	12/31/2019 6:40 am	01/02/2020 8:51 am	Main Building Room 150		3.6
2611307	4275841	12/31/2019 6:40 am	01/02/2020 8:51 am	Main Building Room 150		3.2
2611308	4275842	12/31/2019 6:40 am	01/02/2020 8:51 am	Main Building Room 150		< 0.4
2611309	4275843	12/31/2019 6:41 am	01/02/2020 8:50 am	Main Building Room 154		2.2
2611310	4275844	12/31/2019 6:41 am	01/02/2020 8:50 am	Main Building Room 154		1.7
2611311	4275845	12/31/2019 6:41 am	01/02/2020 8:49 am	Main Building Room 157		1.7
2611312	4275826	12/31/2019 6:35 am	01/02/2020 8:39 am	Main Building Room 158		1.2
2611313	4275827	12/31/2019 6:35 am	01/02/2020 8:43 am	Main Building Room 159		1.6
2611314	4275828	12/31/2019 6:35 am	01/02/2020 8:42 am	Main Building Room 160		1.2
2611315	4275829	12/31/2019 6:36 am	01/02/2020 8:40 am	Main Building Room 162		3.3
2611316	4275830	12/31/2019 6:36 am	01/02/2020 8:41 am	Main Building Room 163		2.2

**Comment:** A copy of this report was emailed to klebsock@pendletonsd.org.

Test Performed By: Ken Lebsack

Distributed by: Inspect USA

Date Received: 01/06/2020 Date Logged: 01/06/2020 Date Analyzed: 01/07/2020 Date Reported: 01/07/2020

Report Reviewed By: Michael Cleveland

Report Approved By: Shawn Price

**Disclaimer:**

The uncertainty of this radon measurement is  $\sim \pm 10\%$ . Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.



NELAC NY 11769  
NRPP 103216 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Pendleton Early Learning Center  
455 Southwest 13th Street  
Pendleton OR 97801

Pendleton Early Learning Center  
455 Southwest 13th Street  
Pendleton OR 97801

Log Number	Device Number	Test Exposure Duration:				Area Tested	Result pCi/L
2611317	4275831	12/31/2019	6:36 am	01/02/2020	8:41 am	Main Building Room 164	2.2
2611318	4275832	12/31/2019	6:36 am	01/02/2020	8:42 am	Main Building Room 168	0.8
2611319	4275833	12/31/2019	6:37 am	01/02/2020	8:46 am	Main Building Room 173	7.4
2611320	4275834	12/31/2019	6:37 am	01/02/2020	8:34 am	Main Building Room 175	2.0
2611321	4275835	12/31/2019	6:38 am	01/02/2020	8:44 am	Main Building Room 175	2.1
2611322	4275816	12/31/2019	6:38 am	01/02/2020	8:44 am	Main Building Room 179	1.2
2611323	4275817	12/31/2019	6:38 am	01/02/2020	8:43 am	Main Building Room 180	2.6
2611324	4275818	12/31/2019	6:38 am	01/02/2020	8:48 am	Main Building Room 181	2.8
2611325	3887573	12/27/2019	6:39 am	12/30/2019	8:48 am	Main Building Room 182	27.1
2611326	3887566	12/27/2019	6:39 am	12/30/2019	8:48 am	Main Building Room 183	25.1

**Comment:** A copy of this report was emailed to klebsock@pendletonsd.org.

Test Performed By: Ken Lebsock

Distributed by: Inspect USA

Date Received: 01/06/2020 Date Logged: 01/06/2020 Date Analyzed: 01/07/2020 Date Reported: 01/07/2020

Report Reviewed By: Michelle Cleveland

Report Approved By: Shawn Price

**Disclaimer:**

The uncertainty of this radon measurement is  $\pm 10\%$ . Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

## Test Kit Placement Log

**Name & Physical Address of School Being Tested:** Sherwood Heights Elementary, 3235 SW Nye Ave., Pendleton, OR 97801

**Building:** Main Building

**Radon Testing Contact at School:** Ken Lebsock, 541.966.3268

**Name of Individual(s) Performing Testing:**

**Logger:** Ken Lebsock

**Placer:** Ken Lebsock

Room Description (per Floor Plan)	Canister serial #	Date Opened	Time Opened	Date Closed	Time Closed	Type of Test D=detector kit	Test Results
103	3887498	12/31/2019	7:03 AM	1/2/2020	9:36 AM	D	0.6 pCi/L
106	3887499	12/31/2019	7:03 AM	1/2/2020	9:37 AM	D	<0.4 pCi/L
107	3887500	12/31/2019	7:03 AM	1/2/2020	9:36 AM	D	<0.4 pCi/L
109	3887501	12/31/2019	7:04 AM	1/2/2020	9:38 AM	D	0.4 pCi/L
110	3887502	12/31/2019	7:04 AM	1/2/2020	9:35 AM	D	<0.4 pCi/L
113	3887503	12/31/2019	7:04 AM	1/2/2020	9:39 AM	D	0.4 pCi/L
117	3887504	12/31/2019	7:00 AM	1/2/2020	9:30 AM	D	<0.4 pCi/L
117	3887505	12/31/2019	7:00 AM	1/2/2020	9:30 AM	D	0.4 pCi/L
117	3887506	12/31/2019	7:00 AM	1/2/2020	9:30 AM	Duplicate	0.4 pCi/L
117	3887507	12/31/2019	7:00 AM	1/2/2020	9:30 AM	Blank	<0.4 pCi/L
120	3887508	12/31/2019	7:01 AM	1/2/2020	9:40 AM	D	<0.4 pCi/L
121	3887509	12/31/2019	7:01 AM	1/2/2020	9:40 AM	D	<0.4 pCi/L
124	3887569	12/31/2019	7:01 AM	1/2/2020	9:34 AM	D	0.5 pCi/L
125	3887510	12/31/2019	7:02 AM	1/2/2020	9:41 AM	D	<0.4 pCi/L
125	3887511	12/31/2019	7:02 AM	1/2/2020	9:41 AM	Duplicate	<0.4 pCi/L
126	3887512	12/31/2019	7:02 AM	1/2/2020	9:42 AM	D	0.4 pCi/L
128	3887513	12/31/2019	7:05 AM	1/2/2020	9:42 AM	D	0.7 pCi/L
129	3887514	12/31/2019	7:08 AM	1/2/2020	9:42 AM	D	<0.4 pCi/L
129	3887515	12/31/2019	7:08 AM	1/2/2020	9:42 AM	D	<0.4 pCi/L
130	3887516	12/31/2019	7:08 AM	1/2/2020	9:43 AM	D	<0.4 pCi/L
134	3887617	12/31/2019	7:07 AM	1/2/2020	9:44 AM	D	0.4 pCi/L
135	3887518	12/31/2019	7:07 AM	1/2/2020	9:44 AM	D	0.5 pCi/L
139	3887519	12/31/2019	7:07 AM	1/2/2020	9:45 AM	D	<0.4 pCi/L
147	3887520	12/31/2019	7:09 AM	1/2/2020	9:46 AM	D	0.4 pCi/L
148	3887521	12/31/2019	7:09 AM	1/2/2020	9:46 AM	D	<0.4 pCi/L
149	3887522	12/31/2019	7:09 AM	1/2/2020	9:47 AM	D	<0.4 pCi/L
150	3887568	12/31/2019	7:09 AM	1/2/2020	9:47 AM	D	<0.4 pCi/L
153	3887567	12/31/2019	7:10 AM	1/2/2020	9:47 AM	D	0.8 pCi/L
154	3887577	12/31/2019	7:10 AM	1/2/2020	9:48 AM	D	<0.4 pCi/L



155	3887578	12/31/2019	7:11 AM	1/2/2020	9:49 AM	D	0.5 pCi/L
155	3887579	12/31/2019	7:11 AM	1/2/2020	9:49 AM	Duplicate	0.5 pCi/L
156	3887580	12/31/2019	7:13 AM	1/2/2020	9:49 AM	D	0.5 pCi/L
157	3887581	12/31/2019	7:13 AM	1/2/2020	9:50 AM	D	1.1 pCi/L
159	3887582	12/31/2019	7:06 AM	1/2/2020	9:33 AM	D	0.7 pCi/L
159	3887583	12/31/2019	7:06 AM	1/2/2020	9:33 AM	D	0.8 pCi/L
159	3887584	12/31/2019	7:06 AM	1/2/2020	9:32 AM	D	0.7 pCi/L
159	3887585	12/31/2019	7:06 AM	1/2/2020	9:32 AM	D	0.9 pCi/L
159	3887586	12/31/2019	7:06 AM	1/2/2020	9:32 AM	Duplicate	0.6 pCi/L
159	3887587	12/31/2019	7:06 AM	1/2/2020	9:32 AM	Blank	<0.4 pCi/L
168	3887588	12/31/2019	7:07 AM	1/2/2020	9:31 AM	D	1.3 pCi/L
Spike	3887575	12/27/2019	7:07 AM	12/30/2019	9:31 AM	Spike	Invalid
Spike	3887572	12/27/2019	7:08 AM	12/30/2019	9:31 AM	Spike	28.2 pCi/L

NELAC NY 11769  
NRPP 103216 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Sherwood Heights Elementary  
3235 Southwest Nye Avenue  
Pendleton OR 97801

Sherwood Heights Elementary  
3235 Southwest Nye Avenue  
Pendleton OR 97801


Log Number	Device Number	Test Exposure Duration:		Area Tested		Result pCi/L
2611415	3887498	12/31/2019 7:03 am	01/02/2020 9:36 am	Main Building Room 103		0.6
2611416	3887499	12/31/2019 7:03 am	01/02/2020 9:37 am	Main Building Room 106		< 0.4
2611417	3887500	12/31/2019 7:03 am	01/02/2020 9:36 am	Main Building Room 107		< 0.4
2611418	3887501	12/31/2019 7:04 am	01/02/2020 9:38 am	Main Building Room 109		0.4
2611419	3887502	12/31/2019 7:04 am	01/02/2020 9:35 am	Main Building Room 110		< 0.4
2611420	3887503	12/31/2019 7:04 am	01/02/2020 9:39 am	Main Building Room 113		0.4
2611421	3887504	12/31/2019 7:00 am	01/02/2020 9:30 am	Main Building Room 117		< 0.4
2611422	3887505	12/31/2019 7:00 am	01/02/2020 9:30 am	Main Building Room 117		0.4
2611423	3887506	12/31/2019 7:00 am	01/02/2020 9:30 am	Main Building Room 117		0.4
2611424	3887507	12/31/2019 7:00 am	01/02/2020 9:30 am	Main Building Room 117		< 0.4
2611425	3887508	12/31/2019 7:01 am	01/02/2020 9:40 am	Main Building Room 120		< 0.4

**Comment:** AMENDED REPORT for 3887578, 3887575 and 3887572 on 02/05/2020 to add the times the test began. Device 3887575 is underexposed -Device must be exposed for a minimum of 48 hours ( 2.0 Days). A copy of this report was emailed to klebsock@pendletonsd.org.

Test Performed By: Ken Lebsack

Distributed by: Inspect USA

Date Received: 01/06/2020 Date Logged: 01/06/2020 Date Analyzed: 01/07/2020 Date Reported: 01/07/2020

Report Reviewed By: 

Report Approved By: 

**Disclaimer:**

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.



NELAC NY 11769  
NRPP 103216 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Sherwood Heights Elementary  
3235 Southwest Nye Avenue  
Pendleton OR 97801

Sherwood Heights Elementary  
3235 Southwest Nye Avenue  
Pendleton OR 97801


Log Number	Device Number	Test Exposure Duration:		Area Tested		Result pCi/L
2611426	3887509	12/31/2019 7:01 am	01/02/2020 9:40 am	Main Building Room 121		< 0.4
2611427	3887569	12/31/2019 7:01 am	01/02/2020 9:34 am	Main Building Room 124		0.5
2611428	3887510	12/31/2019 7:02 am	01/02/2020 9:41 am	Main Building Room 125		< 0.4
2611429	3887511	12/31/2019 7:02 am	01/02/2020 9:41 am	Main Building Room 125		< 0.4
2611430	3887512	12/31/2019 7:02 am	01/02/2020 9:42 am	Main Building Room 126		0.4
2611431	3887513	12/31/2019 7:05 am	01/02/2020 9:42 am	Main Building Room 128		0.7
2611432	3887514	12/31/2019 7:08 am	01/02/2020 9:42 am	Main Building Room 129		< 0.4
2611433	3887515	12/31/2019 7:08 am	01/02/2020 9:42 am	Main Building Room 129		< 0.4
2611434	3887516	12/31/2019 7:08 am	01/02/2020 9:43 am	Main Building Room 130		< 0.4
2611435	3887617	12/31/2019 7:07 am	01/02/2020 9:44 am	Main Building Room 134		0.4
2611436	3887518	12/31/2019 7:07 am	01/02/2020 9:44 am	Main Building Room 135		0.5

**Comment:** AMENDED REPORT for 3887578, 3887575 and 3887572 on 02/05/2020 to add the times the test began. Device 3887575 is underexposed -Device must be exposed for a minimum of 48 hours ( 2.0 Days). A copy of this report was emailed to klebsock@pendletonsd.org.

Test Performed By: Ken Lebsock

Distributed by: Inspect USA

Date Received: 01/06/2020 Date Logged: 01/06/2020 Date Analyzed: 01/07/2020 Date Reported: 01/07/2020

Report Reviewed By: 

Report Approved By: 

**Disclaimer:**

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NELAC NY 11769  
NRPP 103216 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Sherwood Heights Elementary  
3235 Southwest Nye Avenue  
Pendleton OR 97801

Sherwood Heights Elementary  
3235 Southwest Nye Avenue  
Pendleton OR 97801


Log Number	Device Number	Test Exposure Duration:				Area Tested	Result pCi/L
2611437	3887519	12/31/2019 7:07 am	01/02/2020 9:45 am			Main Building Room 139	< 0.4
2611438	3887520	12/31/2019 7:09 am	01/02/2020 9:46 am			Main Building Room 147	0.4
2611439	3887521	12/31/2019 7:09 am	01/02/2020 9:46 am			Main Building Room 148	< 0.4
2611440	3887522	12/31/2019 7:09 am	01/02/2020 9:47 am			Main Building Room 149	< 0.4
2611441	3887568	12/31/2019 7:09 am	01/02/2020 9:47 am			Main Building Room 150	< 0.4
2611442	3887567	12/31/2019 7:10 am	01/02/2020 9:47 am			Main Building Room 153	0.8
2611443	3887577	12/31/2019 7:10 am	01/02/2020 9:48 am			Main Building Room 154	< 0.4
2611444	3887578	12/31/2019 7:11 am	01/02/2020 9:49 am			Main Building Room 155	< 0.4
2611445	3887579	12/31/2019 7:11 am	01/02/2020 9:49 am			Main Building Room 155	0.5
2611446	3887580	12/31/2019 7:13 am	01/02/2020 9:49 am			Main Building Room 156	0.5
2611447	3887581	12/31/2019 7:13 am	01/02/2020 9:50 am			Main Building Room 157	1.1

**Comment:** AMENDED REPORT for 3887578, 3887575 and 3887572 on 02/05/2020 to add the times the test began. Device 3887575 is underexposed -Device must be exposed for a minimum of 48 hours ( 2.0 Days). A copy of this report was emailed to klebsock@pendletonsd.org.

Test Performed By: Ken Lebsock

Distributed by: Inspect USA

Date Received: 01/06/2020 Date Logged: 01/06/2020 Date Analyzed: 01/07/2020 Date Reported: 01/07/2020

Report Reviewed By: 

Report Approved By: 

**Disclaimer:**

The uncertainty of this radon measurement is  $\sim \pm 10\%$ . Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.



NELAC NY 11769  
NRPP 103216 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Sherwood Heights Elementary  
3235 Southwest Nye Avenue  
Pendleton OR 97801

Sherwood Heights Elementary  
3235 Southwest Nye Avenue  
Pendleton OR 97801


Log Number	Device Number	Test Exposure Duration:		Area Tested		Result pCi/L
2611448	3887582	12/31/2019 7:06 am	01/02/2020 9:33 am	Main Building Room 159		0.7
2611449	3887583	12/31/2019 7:06 am	01/02/2020 9:33 am	Main Building Room 159		0.8
2611450	3887584	12/31/2019 7:06 am	01/02/2020 9:32 am	Main Building Room 159		0.7
2611451	3887585	12/31/2019 7:06 am	01/02/2020 9:32 am	Main Building Room 159		0.9
2611452	3887586	12/31/2019 7:06 am	01/02/2020 9:32 am	Main Building Room 159		0.6
2611453	3887587	12/31/2019 7:06 am	01/02/2020 9:32 am	Main Building Room 159		< 0.4
2611454	3887588	12/31/2019 7:07 am	01/02/2020 9:31 am	Main Building Room 168		1.3
2611455	3887575	12/27/2019 7:07 am	12/27/2019 9:31 am	Main Building Room 169		Invalid
2611456	3887572	12/27/2019 7:08 am	12/30/2019 9:31 am	Main Building Room 170		28.2

**Comment:** AMENDED REPORT for 3887578, 3887575 and 3887572 on 02/05/2020 to add the times the test began. Device 3887575 is underexposed -Device must be exposed for a minimum of 48 hours ( 2.0 Days). A copy of this report was emailed to klebsack@pendletonsd.org.

Test Performed By: Ken Lebsack

Distributed by: Inspect USA

Date Received: 01/06/2020 Date Logged: 01/06/2020 Date Analyzed: 01/07/2020 Date Reported: 01/07/2020

Report Reviewed By: 

Report Approved By: 

**Disclaimer:**

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

## Test Kit Placement Log

**Name & Physical Address of School Being Tested:** Sunridge Middle School, 700 SW Runnion Ave, Pendleton, OR 97801

**Building:** Main Building

**Radon Testing Contact at School:** Ken Lebsock, 541.966.3268

**Name of Individual(s) Performing Testing:**

**Logger:** Ken Lebsock

**Placer:** Ken Lebsock

Room Description (per Floor Plan)	Canister serial #	Date Opened	Time Opened	Date Closed	Time Closed	Type of Test D=detector kit	Test Results
2103	3887517	12/31/2019	7:22 AM	1/2/2020	10:11 AM	D	<0.4 pCi/L
2105	3887618	12/31/2019	7:22 AM	1/2/2020	10:11 AM	D	<0.4 pCi/L
2106	7887619	12/31/2019	7:22 AM	1/2/2020	10:12 AM	D	<0.4 pCi/L
2107	3887620	12/31/2019	7:23 AM	1/2/2020	10:13 AM	D	<0.4 pCi/L
2108	3887621	12/31/2019	7:24 AM	1/2/2020	10:13 AM	D	<0.4 pCi/L
2095	4275866	12/31/2019	7:24 AM	1/2/2020	10:09 AM	D	<0.4 pCi/L
2111	3887616	12/31/2019	7:25 AM	1/2/2020	10:10 AM	D	<0.4 pCi/L
2112	3887626	12/31/2019	7:25 AM	1/2/2020	10:10 AM	D	<0.4 pCi/L
2113	3887625	12/31/2019	7:27 AM	1/2/2020	10:12 AM	D	<0.4 pCi/L
2114	3887624	12/31/2019	7:27 AM	1/2/2020	10:12 AM	D	<0.4 pCi/L
2115	3887623	12/31/2019	7:28 AM	1/2/2020	10:14 AM	D	0.6 pCi/L
2116	3887622	12/31/2019	7:28 AM	1/2/2020	10:14 AM	D	<0.4 pCi/L
1159	3887592	12/31/2019	7:28 AM	1/2/2020	10:08 AM	D	1.1 pCi/L
1158	3887591	12/31/2019	7:28 AM	1/2/2020	10:08 AM	D	0.8 pCi/L
1146	3887590	12/31/2019	7:29 AM	1/2/2020	10:07 AM	D	0.6 pCi/L
1146	3887593	12/31/2019	7:29 AM	1/2/2020	10:07 AM	Duplicate	<0.4 pCi/L
1138	3887589	12/31/2019	7:29 AM	1/2/2020	10:06 AM	D	0.6 pCi/L
1112	3887594	12/31/2019	7:30 AM	1/2/2020	10:05 AM	D	<0.4 pCi/L
1097	3887595	12/31/2019	7:31 AM	1/2/2020	10:05 AM	D	<0.4 pCi/L
1090	3887596	12/31/2019	7:32 AM	1/2/2020	10:16 AM	D	<0.4 pCi/L
1090	3887597	12/31/2019	7:32 AM	1/2/2020	10:03 AM	D	<0.4 pCi/L
1090	3887598	12/31/2019	7:33 AM	1/2/2020	10:03 AM	Duplicate	<0.4 pCi/L
1067	3887599	12/31/2019	7:33 AM	1/2/2020	10:00 AM	D	<0.4 pCi/L
1064	3887600	12/31/2019	7:34 AM	1/2/2020	10:17 AM	D	<0.4 pCi/L
1063	3887601	12/31/2019	7:34 AM	1/2/2020	10:17 AM	D	<0.4 pCi/L
1062	3887602	12/31/2019	7:34 AM	1/2/2020	10:17 AM	D	<0.4 pCi/L
1059	3887603	12/31/2019	7:35 AM	1/2/2020	10:18 AM	D	<0.4 pCi/L
1016	3887604	12/31/2019	7:35 AM	1/2/2020	10:18 AM	D	<0.4 pCi/L
1007	3887605	12/31/2019	7:35 AM	1/2/2020	10:20 AM	D	<0.4 pCi/L



1001	3887606	12/31/2019	7:35 AM	1/2/2020	10:20 AM	D	<0.4 pCi/L
1006	3887607	12/31/2019	7:35 AM	1/2/2020	10:19 AM	D	<0.4 pCi/L
1008	3887608	12/31/2019	7:35 AM	1/2/2020	10:18 AM	D	<0.4 pCi/L
1075	3887609	12/31/2019	7:36 AM	1/2/2020	10:21 AM	D	<0.4 pCi/L
1075	3887610	12/31/2019	7:38 AM	1/2/2020	10:21 AM	Blank	<0.4 pCi/L
1075	3887611	12/31/2019	7:38 AM	1/2/2020	10:21 AM	Duplicate	<0.4 pCi/L
1083	3887612	12/31/2019	7:38 AM	1/2/2020	10:22 AM	D	<0.4 pCi/L
1083	3887613	12/31/2019	7:40 AM	1/2/2020	10:22 AM	D	<0.4 pCi/L
1083	3887614	12/31/2019	7:40 AM	1/2/2020	10:22 AM	Blank	<0.4 pCi/L
1083	3887615	12/31/2019	7:40 AM	1/2/2020	10:22 AM	Duplicate	<0.4 pCi/L
Spike	3887571	12/27/2019	7:41 AM	12/30/2019	10:23 AM	Spike	23.2 pCi/L
Spike	3887570	12/27/2019	7:41 AM	12/30/2019	10:23 AM	Spike	23.9 pCi/L

NELAC NY 11769  
NRPP 103216 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Sunridge Middle School  
700 Southwest Runnion Avenue Main Building  
Pendleton OR 97801

Sunridge Middle School  
700 Southwest Runnion Avenue Main Building  
Pendleton OR 97801

Log Number	Device Number	Test Exposure Duration:				Area Tested	Result pCi/L
2611331	3887517	12/31/2019	7:22 am	01/02/2020	10:11 am	Main Building Room 2130	< 0.4
2611332	3887618	12/31/2019	7:22 am	01/02/2020	10:11 am	Main Building Room 2105	< 0.4
2611333	3887619	12/31/2019	7:22 am	01/02/2020	10:12 am	Main Building Room 2106	< 0.4
2611334	3887620	12/31/2019	7:23 am	01/02/2020	10:13 am	Main Building Room 2107	< 0.4
2611335	3887621	12/31/2019	7:24 am	01/02/2020	10:13 am	Main Building Room 2108	< 0.4
2611336	4275866	12/31/2019	7:24 am	01/02/2020	10:09 am	Main Building Room 2095	< 0.4
2611337	3887616	12/31/2019	7:25 am	01/02/2020	10:10 am	Main Building Room 2111	< 0.4
2611338	3887626	12/31/2019	7:25 am	01/02/2020	10:10 am	Main Building Room 2112	< 0.4
2611339	3887625	12/31/2019	7:27 am	01/02/2020	10:12 am	Main Building Room 2113	< 0.4
2611340	3887624	12/31/2019	7:27 am	01/02/2020	10:12 am	Main Building Room 2114	< 0.4
2611341	3887623	12/31/2019	7:28 am	01/02/2020	10:14 am	Main Building Room 2115	0.6

**Comment:** A copy of this report was emailed to klebsock@pendletonsd.org.

Test Performed By: Ken Lebsock

Distributed by: Inspect USA

Date Received: 01/06/2020 Date Logged: 01/06/2020 Date Analyzed: 01/07/2020 Date Reported: 01/07/2020

Report Reviewed By: Michelle Cleveland

Report Approved By: Shawn Price

**Disclaimer:**

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.



NELAC NY 11769  
NRPP 103216 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Sunridge Middle School  
700 Southwest Runnion Avenue Main Building  
Pendleton OR 97801

Sunridge Middle School  
700 Southwest Runnion Avenue Main Building  
Pendleton OR 97801

Log Number	Device Number	Test Exposure Duration:		Area Tested		Result pCi/L
2611342	3887622	12/31/2019 7:28 am	01/02/2020 10:14 am	Main Building Room 2116		< 0.4
2611343	3887592	12/31/2019 7:28 am	01/02/2020 10:08 am	Main Building Room 1159		1.1
2611344	3887591	12/31/2019 7:28 am	01/02/2020 10:08 am	Main Building Room 1158		0.8
2611345	3887590	12/31/2019 7:29 am	01/02/2020 10:07 am	Main Building Room 1146		0.6
2611346	3887593	12/31/2019 7:29 am	01/02/2020 10:07 am	Main Building Room 1146		< 0.4
2611347	3887589	12/31/2019 7:29 am	01/02/2020 10:06 am	Main Building Room 1138		0.6
2611348	3887594	12/31/2019 7:30 am	01/02/2020 10:05 am	Main Building Room 1112		< 0.4
2611349	3887595	12/31/2019 7:31 am	01/02/2020 10:05 am	Main Building Room 1097		< 0.4
2611350	3887596	12/31/2019 7:32 am	01/02/2020 10:16 am	Main Building Room 1090		< 0.4
2611351	3887597	12/31/2019 7:32 am	01/02/2020 10:03 am	Main Building Room 1090		< 0.4
2611352	3887598	12/31/2019 7:33 am	01/02/2020 10:03 am	Main Building Room 1090		< 0.4

**Comment:** A copy of this report was emailed to klebsack@pendletonsd.org.

Test Performed By: Ken Lebsack

Distributed by: Inspect USA

Date Received: 01/06/2020 Date Logged: 01/06/2020 Date Analyzed: 01/07/2020 Date Reported: 01/07/2020

Report Reviewed By: Michael Cleveland

Report Approved By: Shawn Price

**Disclaimer:**

The uncertainty of this radon measurement is  $\sim \pm 10\%$ . Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NELAC NY 11769  
NRPP 103216 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Sunridge Middle School  
700 Southwest Runnion Avenue Main Building  
Pendleton OR 97801

Sunridge Middle School  
700 Southwest Runnion Avenue Main Building  
Pendleton OR 97801

Log Number	Device Number	Test Exposure Duration:		Area Tested		Result pCi/L
2611353	3887599	12/31/2019 7:33 am	01/02/2020 10:00 am	Main Building Room 1067		< 0.4
2611354	3887600	12/31/2019 7:34 am	01/02/2020 10:17 am	Main Building Room 1064		< 0.4
2611355	3887601	12/31/2019 7:34 am	01/02/2020 10:17 am	Main Building Room 1063		< 0.4
2611356	3887602	12/31/2019 7:34 am	01/02/2020 10:17 am	Main Building Room 1062		< 0.4
2611357	3887603	12/31/2019 7:35 am	01/02/2020 10:18 am	Main Building Room 1059		< 0.4
2611358	3887604	12/31/2019 7:35 am	01/02/2020 10:18 am	Main Building Room 1016		< 0.4
2611359	3887605	12/31/2019 7:35 am	01/02/2020 10:20 am	Main Building Room 1007		< 0.4
2611360	3887606	12/31/2019 7:35 am	01/02/2020 10:20 am	Main Building Room 1001		< 0.4
2611361	3887607	12/31/2019 7:35 am	01/02/2020 10:19 am	Main Building Room 1006		< 0.4
2611362	3887608	12/31/2019 7:35 am	01/02/2020 10:18 am	Main Building Room 1008		< 0.4
2611363	3887609	12/31/2019 7:36 am	01/02/2020 10:21 am	Main Building Room 1075		< 0.4

**Comment:** A copy of this report was emailed to klebsock@pendletonsd.org.

Test Performed By: Ken Lebsock

Distributed by: Inspect USA

Date Received: 01/06/2020 Date Logged: 01/06/2020 Date Analyzed: 01/07/2020 Date Reported: 01/07/2020

Report Reviewed By: Michelle Cleveland

Report Approved By: Shawn Price

**Disclaimer:**

The uncertainty of this radon measurement is  $\pm 10\%$ . Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.



NELAC NY 11769  
NRPP 103216 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Sunridge Middle School  
700 Southwest Runnion Avenue Main Building  
Pendleton OR 97801

Sunridge Middle School  
700 Southwest Runnion Avenue Main Building  
Pendleton OR 97801

Log Number	Device Number	Test Exposure Duration:				Area Tested	Result pCi/L
2611364	3887610	12/31/2019	7:38 am	01/02/2020	10:21 am	Main Building Room 1075	< 0.4
2611365	3887611	12/31/2019	7:38 am	01/02/2020	10:21 am	Main Building Room 1075	< 0.4
2611366	3887612	12/31/2019	7:38 am	01/02/2020	10:22 am	Main Building Room 1083	< 0.4
2611367	3887613	12/31/2019	7:40 am	01/02/2020	10:22 am	Main Building Room 1083	< 0.4
2611368	3887614	12/31/2019	7:40 am	01/02/2020	10:22 am	Main Building Room 1083	< 0.4
2611369	3887615	12/31/2019	7:40 am	01/02/2020	10:22 am	Main Building Room 1083	< 0.4
2611370	3887571	12/27/2019	7:41 am	12/30/2019	10:23 am	Main Building Room 1084	23.2
2611371	3887570	12/27/2019	7:41 am	12/30/2019	10:23 am	Main Building Room 1085	23.9

**Comment:** A copy of this report was emailed to klebsack@pendletonsd.org.

Test Performed By: Ken Lebsack

Distributed by: Inspect USA

Date Received: 01/06/2020 Date Logged: 01/06/2020 Date Analyzed: 01/07/2020 Date Reported: 01/07/2020

Report Reviewed By: Michelle Cleveland

Report Approved By: Shawn Price

**Disclaimer:**

The uncertainty of this radon measurement is  $\pm 10\%$ . Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

## Test Kit Placement Log

**Name & Physical Address of School Being Tested:** Washington Elementary, 1205 SE Byers Ave., Pendleton, OR 97801

**Building:** Main Building

**Radon Testing Contact at School:** Ken Lebsock, 541.966.3268

**Name of Individual(s) Performing Testing:**

**Logger:** Ken Lebsock

**Placer:** Ken Lebsock

Room Description (per Floor Plan)	Canister serial #	Date Opened	Time Opened	Date Closed	Time Closed	Type of Test D=detector kit	Test Results
103	3887492	12/31/2019	6:12 AM	1/2/2020	8:13 AM	D	2.7 pCi/L
106	3887493	12/31/2019	6:12 AM	1/2/2020	8:12 AM	D	1.7 pCi/L
107	3887494	12/31/2019	6:12 AM	1/2/2020	8:13 AM	D	2.7 pCi/L
109	3887497	12/31/2019	6:13 AM	1/2/2020	8:12 AM	D	1.7 pCi/L
110	3887495	12/31/2019	6:13 AM	1/2/2020	8:14 AM	D	1.2 pCi/L
113	3887496	12/31/2019	6:14 AM	1/2/2020	8:09 AM	D	1.7 pCi/L
117	3887523	12/31/2019	6:14 AM	1/2/2020	8:15 AM	D	2.0 pCi/L
117	3887524	12/31/2019	6:14 AM	1/2/2020	8:15 AM	D	1.9 pCi/L
117	3887525	12/31/2019	6:15 AM	1/2/2020	8:15 AM	Duplicate	2.1 pCi/L
117	3887526	12/31/2019	6:15 AM	1/2/2020	8:15 AM	Blank	<0.4 pCi/L
120	3887463	12/31/2019	6:15 AM	1/2/2020	8:19 AM	D	1.1 pCi/L
121	3887464	12/31/2019	6:15 AM	1/2/2020	8:19 AM	D	1.3 pCi/L
125	3887465	12/31/2019	6:16 AM	1/2/2020	8:20 AM	D	2.2 pCi/L
125	3887466	12/31/2019	6:16 AM	1/2/2020	8:20 AM	Duplicate	2.0 pCi/L
126	3887467	12/31/2019	6:16 AM	1/2/2020	8:20 AM	D	2.9 pCi/L
128	3887468	12/31/2019	6:17 AM	1/2/2020	8:21 AM	D	3.1 pCi/L
129	3887469	12/31/2019	6:17 AM	1/2/2020	8:22 AM	D	1.8 pCi/L
129	3887470	12/31/2019	6:17 AM	1/2/2020	8:22 AM	D	1.8 pCi/L
130	3887471	12/31/2019	6:18 AM	1/2/2020	8:23 AM	D	1.0 pCi/L
134	3887472	12/31/2019	6:18 AM	1/2/2020	8:23 AM	D	1.5 pCi/L
135	3887473	12/31/2019	6:18 AM	1/2/2020	8:24 AM	D	3.3 pCi/L
139	3887474	12/31/2019	6:18 AM	1/2/2020	8:24 AM	D	2.6 pCi/L
147	3887475	12/31/2019	6:19 AM	1/2/2020	8:25 AM	D	2.2 pCi/L
148	3887476	12/31/2019	6:19 AM	1/2/2020	8:26 AM	D	2.2 pCi/L
149	3887477	12/31/2019	6:19 AM	1/2/2020	8:26 AM	D	2.6 pCi/L
150	3887478	12/31/2019	6:20 AM	1/2/2020	8:27 AM	D	2.5 pCi/L
153	3887479	12/31/2019	6:20 AM	1/2/2020	8:27 AM	D	2.0 pCi/L
154	3887480	12/31/2019	6:20 AM	1/2/2020	8:28 AM	D	2.2 pCi/L
155	3887481	12/31/2019	6:21 AM	1/2/2020	8:28 AM	D	1.9 pCi/L



155	3887482	12/31/2019	6:21 AM	1/2/2020	8:28 AM	Duplicate	2.1 pCi/L
156	3887483	12/31/2019	6:21 AM	1/2/2020	8:29 AM	D	2.1 pCi/L
157	3887484	12/31/2019	6:25 AM	1/2/2020	8:30 AM	D	2.5 pCi/L
159	3887485	12/31/2019	6:22 AM	1/2/2020	8:17 AM	D	2.1 pCi/L
159	3887486	12/31/2019	6:22 AM	1/2/2020	8:18 AM	D	2.3 pCi/L
159	3887487	12/31/2019	6:23 AM	1/2/2020	8:17 AM	D	2.7 pCi/L
159	3887488	12/31/2019	6:23 AM	1/2/2020	8:17 AM	D	2.2 pCi/L
159	3887489	12/31/2019	6:23 AM	1/2/2020	8:17 AM	Duplicate	2.5 pCi/L
159	3887490	12/31/2019	6:24 AM	1/2/2020	8:17 AM	Blank	0.4 pCi/L
168	3887491	12/31/2019	6:24 AM	1/2/2020	8:16 AM	D	2.6 pCi/L
Spike	3887576	12/31/2019	6:24 AM	1/2/2020	8:16 AM	Spike	13.5 pCi/L
Spike	3887574	12/31/2019	6:25 AM	1/2/2020	8:16 AM	Spike	12.7 pCi/L

NELAC NY 11769  
NRPP 103216 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Washington Elementary  
1205 Southeast Byers Avenue  
Pendleton OR 97801

Washington Elementary  
1205 Southeast Byers Avenue  
Pendleton OR 97801

Log Number	Device Number	Test Exposure Duration:		Area Tested		Result pCi/L
2611374	3887492	12/31/2019 6:12 am	01/02/2020 8:13 am	Main Building Room 103		2.7
2611375	3887493	12/31/2019 6:12 am	01/02/2020 8:12 am	Main Building Room 106		1.7
2611376	3887494	12/31/2019 6:12 am	01/02/2020 8:13 am	Main Building Room 107		2.7
2611377	3887497	12/31/2019 6:13 am	01/02/2020 8:12 am	Main Building Room 109		1.7
2611378	3887495	12/31/2019 6:13 am	01/02/2020 8:14 am	Main Building Room 110		1.2
2611379	3887496	12/31/2019 6:14 am	01/02/2020 8:09 am	Main Building Room 113		1.7
2611380	3887523	12/31/2019 6:14 am	01/02/2020 8:15 am	Main Building Room 117		2.0
2611381	3887524	12/31/2019 6:14 am	01/02/2020 8:15 am	Main Building Room 117		1.9
2611382	3887525	12/31/2019 6:15 am	01/02/2020 8:15 am	Main Building Room 117		2.1
2611383	3887526	12/31/2019 6:15 am	01/02/2020 8:15 am	Main Building Room 117		< 0.4
2611384	3887463	12/31/2019 6:15 am	01/02/2020 8:19 am	Main Building Room 120		1.1

**Comment:** A copy of this report was emailed to klebsock@pendletonsd.org.

Test Performed By: Ken Lebsock

Distributed by: Inspect USA

Date Received: 01/06/2020 Date Logged: 01/06/2020 Date Analyzed: 01/07/2020 Date Reported: 01/07/2020

Report Reviewed By: Michelle Cleveland

Report Approved By: Shawn Price

**Disclaimer:**

The uncertainty of this radon measurement is  $\sim \pm 10\%$ . Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.



NELAC NY 11769  
NRPP 103216 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Washington Elementary  
1205 Southeast Byers Avenue  
Pendleton OR 97801

Washington Elementary  
1205 Southeast Byers Avenue  
Pendleton OR 97801

Log Number	Device Number	Test Exposure Duration:		Area Tested		Result pCi/L
2611385	3887464	12/31/2019 6:15 am	01/02/2020 8:19 am	Main Building Room 121		1.3
2611386	3887465	12/31/2019 6:16 am	01/02/2020 8:20 am	Main Building Room 125		2.2
2611387	3887466	12/31/2019 6:16 am	01/02/2020 8:20 am	Main Building Room 125		2.0
2611388	3887467	12/31/2019 6:16 am	01/02/2020 8:20 am	Main Building Room 126		2.9
2611389	3887468	12/31/2019 6:17 am	01/02/2020 8:21 am	Main Building Room 128		3.1
2611390	3887469	12/31/2019 6:17 am	01/02/2020 8:22 am	Main Building Room 129		1.8
2611391	3887470	12/31/2019 6:17 am	01/02/2020 8:22 am	Main Building Room 129		1.8
2611392	3887471	12/31/2019 6:18 am	01/02/2020 8:23 am	Main Building Room 130		1.0
2611393	3887472	12/31/2019 6:18 am	01/02/2020 8:23 am	Main Building Room 130		1.5
2611394	3887473	12/31/2019 6:18 am	01/02/2020 8:24 am	Main Building Room 135		3.3
2611395	3887474	12/31/2019 6:18 am	01/02/2020 8:24 am	Main Building Room 139		2.6

**Comment:** A copy of this report was emailed to klebsock@pendletonsd.org.

Test Performed By: Ken Lebsack

Distributed by: Inspect USA

Date Received: 01/06/2020 Date Logged: 01/06/2020 Date Analyzed: 01/07/2020 Date Reported: 01/07/2020

Report Reviewed By: Michelle Cleveland

Report Approved By: Shawn Price

**Disclaimer:**

The uncertainty of this radon measurement is  $\sim \pm 10\%$ . Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NELAC NY 11769  
NRPP 103216 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Washington Elementary  
1205 Southeast Byers Avenue  
Pendleton OR 97801

Washington Elementary  
1205 Southeast Byers Avenue  
Pendleton OR 97801

Log Number	Device Number	Test Exposure Duration:				Area Tested	Result pCi/L
2611396	3887475	12/31/2019	6:19 am	01/02/2020	8:25 am	Main Building Room 147	2.2
2611397	3887476	12/31/2019	6:19 am	01/02/2020	8:26 am	Main Building Room 148	2.2
2611398	3887477	12/31/2019	6:19 am	01/02/2020	8:26 am	Main Building Room 149	2.6
2611399	3887478	12/31/2019	6:20 am	01/02/2020	8:27 am	Main Building Room 150	2.5
2611400	3887479	12/31/2019	6:20 am	01/02/2020	8:27 am	Main Building Room 153	2.0
2611401	3887480	12/31/2019	6:20 am	01/02/2020	8:28 am	Main Building Room 154	2.2
2611402	3887481	12/31/2019	6:21 am	01/02/2020	8:28 am	Main Building Room 155	1.9
2611403	3887482	12/31/2019	6:21 am	01/02/2020	8:28 am	Main Building Room 155	2.1
2611404	3887483	12/31/2019	6:21 am	01/02/2020	8:29 am	Main Building Room 156	2.1
2611405	3887484	12/31/2019	6:25 am	01/02/2020	8:30 am	Main Building Room 157	2.5
2611406	3887485	12/31/2019	6:22 am	01/02/2020	8:17 am	Main Building Room 159	2.1

**Comment:** A copy of this report was emailed to klebsock@pendletonsd.org.

Test Performed By: Ken Lebsack

Distributed by: Inspect USA

Date Received: 01/06/2020    Date Logged: 01/06/2020    Date Analyzed: 01/07/2020    Date Reported: 01/07/2020

Report Reviewed By: Michelle Cleveland

Report Approved By: Shawn Price

**Disclaimer:**

The uncertainty of this radon measurement is  $\pm 10\%$ . Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.



NELAC NY 11769  
NRPP 103216 AL  
NRSB ARL0017

EPA Method #402-R-92-004  
Liquid Scintillation  
NRPP Device Code 8088  
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Washington Elementary  
1205 Southeast Byers Avenue  
Pendleton OR 97801

Washington Elementary  
1205 Southeast Byers Avenue  
Pendleton OR 97801

Log Number	Device Number	Test Exposure Duration:				Area Tested	Result pCi/L
2611407	3887486	12/31/2019	6:22 am	01/02/2020	8:18 am	Main Building Room 159	2.3
2611408	3887487	12/31/2019	6:23 am	01/02/2020	8:17 am	Main Building Room 159	2.7
2611409	3887488	12/31/2019	6:23 am	01/02/2020	8:17 am	Main Building Room 159	2.2
2611410	3887489	12/31/2019	6:23 am	01/02/2020	8:17 am	Main Building Room 159	2.5
2611411	3887490	12/31/2019	6:24 am	01/02/2020	8:17 am	Main Building Room 159	0.4
2611412	3887491	12/31/2019	6:24 am	01/02/2020	8:16 am	Main Building Room 168	2.6
2611413	3887576	12/31/2019	6:24 am	01/02/2020	8:16 am	Main Building Room 169	13.5
2611414	3887574	12/31/2019	6:25 am	01/02/2020	8:16 am	Main Building Room 170	12.7

**Comment:** A copy of this report was emailed to klebsock@pendletonsd.org.

Test Performed By: Ken Lebsock

Distributed by: Inspect USA

Date Received: 01/06/2020 Date Logged: 01/06/2020 Date Analyzed: 01/07/2020 Date Reported: 01/07/2020

Report Reviewed By: Michael Cleveland

Report Approved By: Shawn Price

**Disclaimer:**

The uncertainty of this radon measurement is  $\sim \pm 10\%$ . Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.