

Pendleton School District 16R
Lead Analysis Results Summary Report
Summer 2019

*PPB - Parts per billion

**EPA recommends action to reduce lead levels if sample is above 15 PPB

***ND - Analyte Not Detected

Indicates levels that exceed EPA recommendations

Indicates Retest due to elevated levels of lead

Pendleton Early Learning Center					
Lab Sample #	Retest #	Sample Location		Result PPB*	Retest PPB*
9070501-01		Room 171	Restroom Sink	ND	
9070501-02		Room 170	Restroom Sink	ND	
9070501-03		Room 180A	Restroom Sink - 1	ND	
9070501-04		Room 180A	Restroom Sink - 2	ND	
9070501-05		Room 181A	Restroom Sink - 1	ND	
9070501-06		Room 181A	Restroom Sink - 2	ND	
9070501-07		Playground	Drinking fountain	ND	
9070501-08		Commons Restroom	Restroom Sink - 1	ND	
9070501-09		Commons Restroom	Restroom Sink - 2	ND	
9070501-10		Commons Restroom	Restroom Sink - 3	ND	
9070501-11		Commons Restroom	Restroom Sink - 4	ND	
9070501-12		Room 105A	Restroom Sink	ND	
9070501-13		Room 126	Restroom Sink	ND	

McKay Creek Elementary					
Lab Sample #	Retest #	Sample Location		Result PPB*	Retest PPB*
9070507-20		Primary Hallway	Drinking Fountain	3	
9070507-21		Secodary Hallway	Drinking Fountain	2	
9070507-22	9080122-68	Room 152	Restroom Sink	16	13
9070507-23		Room 150	Restroom Sink	2	
9070507-24		Room 151	Restroom Sink	6	
9070507-25	9080122-67	Room 145	Restroom Sink	53	16
	9091609-02				ND
9070507-26	9080122-66	Room 144	Restroom Sink	16	7
9070507-27		Room 138/139 Restroom	Restroom Sink - 1	5	
9070507-28		Room 138/139 Restroom	Restroom Sink - 2	3	
9070507-29	9080122-69	Room 111	Restroom Sink	19	5
9070507-30		Locker Rooms	Restroom Sink	12	

Sherwood Heights Elementary					
Lab Sample #	Retest #	Sample Location		Result PPB*	Retest PPB*
9071906-01		Room 163/164 Main Hall Restroom	Restroom Sink - 1	ND	
9071906-02		Room 163/164 Main Hall Restroom	Restroom Sink - 2	ND	
9071906-03		Room 163/164 Main Hall Restroom	Restroom Sink - 3	5	

9071906-04		Room 163/164 Main Hall Restroom	Restroom Sink - 4	3	
9071906-05		Room 161A	Restroom Sink	ND	
9071906-06		Room 108	Restroom Sink	ND	
9071906-07		Room 111	Restroom Sink	ND	
9071906-08		Room 115	Restroom Sink	ND	
9071906-09		Room 116	Restroom Sink	2	
9071906-10		Room 122 - Boys (1st Grade Collab)	Restroom Sink - 1	3	
9071906-11		Room 122 - Boys (1st Grade Collab)	Restroom Sink - 2	ND	
9071906-12		Room 123 - Girls (1st Grade Collab)	Restroom Sink - 1	3	
9071906-13		Room 123 - Girls (1st Grade Collab)	Restroom Sink - 2	2	
9071906-14		Playground	Drinking fountain	3	
9071906-15		Room 137	Restroom Sink	ND	
9071906-16		Room 142/143 (Grade 2/3 Collab) Restro	Restroom Sink - 1	3	
9071906-17		Room 142/143 (Grade 2/3 Collab) Restro	Restroom Sink - 2	ND	
9071906-18		Room 142/143 (Grade 2/3 Collab) Restro	Restroom Sink - 3	4	
9071906-19		Room 142/143 (Grade 2/3 Collab) Restro	Restroom Sink - 4	2	
9071906-20		Room 142/143 (Grade 2/3 Collab) Restro	Restroom Sink - 5	ND	
9071906-21		Room 144	Restroom Sink	4	
9071906-22		Room 146	Restroom Sink	4	
9071906-23		Room 210/211 (Grade 4/5 Collab) Restro	Restroom Sink - 1	14	
9071906-24	9091609-03	Room 210/211 (Grade 4/5 Collab) Restro	Restroom Sink - 2	15	ND
9071906-25	9091609-04	Room 210/211 (Grade 4/5 Collab) Restro	Restroom Sink - 3	17	ND
9071906-26		Room 210/211 (Grade 4/5 Collab) Restro	Restroom Sink - 4	8	
9071906-27		Room 210/211 (Grade 4/5 Collab) Restro	Restroom Sink - 5	5	
9071906-28		Room 212	Restroom Sink	5	
9071906-29		Room 214	Restroom Sink	7	
9071906-30		Room 221	Drinking Fountain	2	

Washington Elementary					
Lab Sample #	Retest #	Sample Location		Result PPB*	Retest PPB*
9072414-01		Room 163/164 Main Hall Restroom	Restroom Sink - 1	ND	
9072414-02		Room 163/164 Main Hall Restroom	Restroom Sink - 2	ND	
9072414-03		Room 163/164 Main Hall Restroom	Restroom Sink - 3	4	
9072414-04		Room 163/164 Main Hall Restroom	Restroom Sink - 4	ND	
9072414-05		Room 161A	Restroom Sink	ND	
9072414-06		Room 108	Restroom Sink	ND	
9072414-07		Room 111	Restroom Sink	2	
9072414-08		Room 115	Restroom Sink	ND	
9072414-09		Room 116	Restroom Sink	ND	
9072414-10		Room 122 - Boys (1st Grade Collab)	Restroom Sink - 1	5	
9072414-11		Room 122 - Boys (1st Grade Collab)	Restroom Sink - 2	ND	
9072414-12		Room 123 - Girls (1st Grade Collab)	Restroom Sink - 1	ND	
9072414-13		Room 123 - Girls (1st Grade Collab)	Restroom Sink - 2	ND	
9072414-14		Playground	Drinking fountain	10	
9072414-15		Room 137	Restroom Sink	4	
9072414-16		Room 142/143 (Grade 2/3 Collab) Restro	Restroom Sink - 1	ND	
9072414-17		Room 142/143 (Grade 2/3 Collab) Restro	Restroom Sink - 2	4	
9072414-18		Room 142/143 (Grade 2/3 Collab) Restro	Restroom Sink - 3	2	
9072414-19		Room 142/143 (Grade 2/3 Collab) Restro	Restroom Sink - 4	ND	
9072414-20		Room 142/143 (Grade 2/3 Collab) Restro	Restroom Sink - 5	3	

9072414-21		Room 144	Restroom Sink	ND	
9072414-22		Room 146	Restroom Sink	2	
9072414-23		Room 210/211 (Grade 4/5 Collab) Restro	Restroom Sink - 1	8	
9072414-24		Room 210/211 (Grade 4/5 Collab) Restro	Restroom Sink - 2	13	
9072414-25		Room 210/211 (Grade 4/5 Collab) Restro	Restroom Sink - 3	12	
9072414-26		Room 210/211 (Grade 4/5 Collab) Restro	Restroom Sink - 4	3	
9072414-27		Room 210/211 (Grade 4/5 Collab) Restro	Restroom Sink - 5	7	
9072414-28		Room 212	Restroom Sink	10	
9072414-29		Room 214	Restroom Sink	8	
9072414-30		Room 221	Drinking fountain	5	

Sunridge Middle School

Lab Sample #	Retest #	Sample Location		Result PPB*	Retest PPB*
9070507-01		Girls Locker Room	Restroom Sink - 1	4	
9070507-02		Girls Locker Room	Restroom Sink - 2	9	
9070507-03		Boys Locker Room	Restroom Sink - 1	4	
9070507-04		Boys Locker Room	Restroom Sink - 2	ND	
9070507-05		Room 1067 (Home Ec)	Sink - 1	ND	
9070507-06		Room 1067 (Home Ec)	Sink - 2	ND	
9070507-07		Room 1067 (Home Ec)	Sink - 3	ND	
9070507-08		Room 1067 (Home Ec)	Sink - 4	2	
9070507-09		Room 1067 (Home Ec)	Sink - 5	2	
9070507-10	9080122-70	Room 1067 (Home Ec)	Sink - 6	15	26
	9091609-01				7
9070507-11		Room 1110 Girls Restroom (Commons)	Restroom Sink	ND	
9070507-12		Room 1111 Boys Restroom (Commons)	Restroom Sink	4	
9070507-13		Room 2021 Girls Restroom (Counseling)	Restroom Sink	6	
9070507-14		Room 2022 Boys Restroom (Counseling)	Restroom Sink	ND	
9070507-15		Room 2058 (lifeskills)	kitchen Sink	ND	
9070507-16		Room 2058 (lifeskills)	Restroom Sink	ND	
9070507-17		Library Workroom	Sink	2	
9070507-18		Room 2101 Girls Restroom (6th Grade)	Restroom Sink	10	
9070507-19		Room 2102 Boys Restroom (6th Grade)	Restroom Sink	ND	

Pendleton High School

Lab Sample #	Retest #	Sample Location		Result PPB*	Retest PPB*
9080122-01		Track Concessions Building	Restroom Sink - 1	4	
9080122-02		Track Concessions Building	Restroom Sink - 2	ND	
9080122-03		Track Concessions Building	Restroom Sink - 3	ND	
9080122-04		Babe Ruth Concessions	Sink	ND	
9080122-05		Babe Ruth Restrooms	Restroom Sink - 1	11	
9080122-06		Babe Ruth Restrooms	Restroom Sink - 2	2	
9080122-07		Babe Ruth Restrooms	Restroom Sink - 3	16	
9080122-08		Babe Ruth Restrooms	Restroom Sink - 4	7	
9080122-09		Football Field	Hose Bib	ND	
9080122-10		Freshman Football Field	Hose Bib	4	
9080122-11		Hitting Facility Girls Restroom	Restroom Sink	ND	
9080122-12		Hitting Facility Boys Restroom	Restroom Sink	14	

9080122-13		Hitting Facility	Drinking Fountain	ND	
9080122-14		Room 104 (Building 4 Ag)	Sink	ND	
9080122-15		Room 118 Girls Restroom (Bldg 4)	Restroom Sink - 1	ND	
9080122-16		Room 118 Girls Restroom (Bldg 4)	Restroom Sink - 2	ND	
9080122-17		Room 121 Boys Restroom (Bldg 4)	Restroom Sink - 1	2	
9080122-18		Room 121 Boys Restroom (Bldg 4)	Restroom Sink - 2	ND	
9080122-19		Room 204 Girls Restroom (First Floor by L	Restroom Sink	ND	
9080122-20		Room 203 Boys Restroom (First Floor by	Restroom Sink	12	
9080122-21		Room 224 (Lifeskills)	Restroom Sink	ND	
9080122-22		Room 216 (Daycare)	Restroom Sink - 1	4	
9080122-23		Room 216 (Daycare)	Restroom Sink - 2	ND	
9080122-24		Room 211 (Staff Workroom)	Restroom Sink - 1	ND	
9080122-25		Room 211 (Staff Workroom)	Restroom Sink - 2	ND	
9080122-26		Room 211 (Staff Workroom)	Sink	7	
9080122-27		Room 307 Women's Restroom (Office)	Restroom Sink	ND	
9080122-28		Room 308 Men's Restroom (Office)	Restroom Sink	ND	
9080122-29		Room 311 Health Room (Office)	Restroom Sink	ND	
9080122-30		Room 407 Warberg Girls Locker Room	Restroom Sink	ND	
9080122-31		Room 408 Warberg Girls Locker Room Of	Restroom Sink	ND	
9080122-32		Room 422 Warberg Boys Locker Room	Restroom Sink	3	
9080122-33		Room 421 Warberg Boys Locker Room O	Restroom Sink	ND	
9080122-34		Room 514 Girls Restroom (2nd Floor by t	Restroom Sink	21	
9080122-35		Room 513 Boys Restroom (2nd Floor by t	Restroom Sink	2	
9080122-36		Room 531 Girls Restroom (2nd Floor by V	Restroom Sink	ND	
9080122-37		Room 530 Boys Restroom (2nd Floor by V	Restroom Sink	15	
9080122-38		Room 625 Library Workroom	Sink	ND	
9080122-39		Room 704 Girls Restroom (commons)	Restroom Sink - 1	ND	
9080122-40		Room 704 Girls Restroom (commons)	Restroom Sink - 2	ND	
9080122-41		Room 705 Boys Restroom (commons)	Restroom Sink - 1	ND	
9080122-42		Room 705 Boys Restroom (commons)	Restroom Sink - 2	ND	
9080122-43		Room 712A Health Exam Room	Sink	8	
9080122-44		Room 913 Girls Restroom (3rd Floor East	Restroom Sink	ND	
9080122-45		Room 912 Boys Restroom (3rd Floor East	Restroom Sink	4	
9080122-46		Room 930 Girls Restroom (3rd Floor Wes	Restroom Sink	5	
9080122-47		Room 929 Boys Restroom (3rd Floor wes	Restroom Sink	ND	
9080122-48		Room 1110 Team Dressing Room Gold G	Restroom Sink - 1	39	
9080122-49		Room 1110 Team Dressing Room Gold G	Restroom Sink - 2	26	
9080122-50		Room 1117 Team Dressing Room Gold G	Restroom Sink - 1	32	
9080122-51		Room 1117 Team Dressing Room Gold G	Restroom Sink - 2	17	
9080122-52		Room 1144 Girls Restroom Gold Gym Up	Restroom Sink - 1	ND	
9080122-55		Room 1146 Boys Restroom Gold Gym Up	Restroom Sink - 2	ND	
9080122-56		Corridor 1143 Gold Gym Upstairs East Sid	Drinking Fountain	ND	
9080122-57		Room 1212 Women's Restroom Bld 6	Restroom Sink - 1	11	
9080122-58		Room 1212 Women's Restroom Bld 6	Restroom Sink - 2	14	
9080122-59		Room 1212 Women's Restroom Bld 6	Restroom Sink - 3	13	
9080122-60		Room 1219 Men's Restroom Bld 6	Restroom Sink - 1	4	
9080122-61		Room 1219 Men's Restroom Bld 6	Restroom Sink - 2	3	
9080122-62		Room 1219 Men's Restroom Bld 6	Restroom Sink - 3	15	
9080122-63		Room 1240 Dressing Room Restroom	Restroom Sink	ND	
9080122-64		Room 1241 Dressing Room Restroom	Restroom Sink	ND	
9080122-65		Nurses Station	Sink	ND	

Pendleton Tech & Trades Center

Lab Sample #	Retest #	Sample Location		Result PPB*	Retest PPB*
9070501-14		Room 102 Unisex Restroom	Restroom Sink	2	
9070501-15		Hall Restrooms	Restroom Sink - 1	4	
9070501-16		Hall Restrooms	Restroom Sink - 2	12	
9070501-17		Room 135 Restroom (East End)	Restroom Sink	4	
9070501-18		Room 118/119	Sink	ND	