

Test Kit Placement Log

Name & Physical Address of School Being Tested: Pendleton Early Learning Center - 455 SW 13th Street, Pendleton, OR 97801

Building: Main Building

Radon Testing Contact at School: Ken Lebsock, 541.966.3268

Name of Individual(s) Performing Testing:

Logger: Ken Lebsock

Placer: Ken Lebsock

Room Description (per Floor Plan)	Canister serial #	Date Opened	Time Opened	Date Closed	Time Closed	Type of Test D=detector kit	Test Results
127	4420516	2/1/2021	6:23 AM	2/4/2021	6:29 AM	Blank	<0.4 pCi/L
127	4420513	2/1/2021	6:23 AM	2/4/2021	6:29 AM	D	7.2 pCi/L
127	4420517	2/1/2021	6:23 AM	2/4/2021	6:29 AM	Spike	15.4 pCi/L
173	4420512	2/1/2021	6:21 AM	2/4/2021	6:32 AM	D	0.7 pCi/L
173	4420514	2/1/2021	6:21 AM	2/4/2021	6:32 AM	D	0.6 pCi/L

NELAC NY 11769
NRPP 103216 AL
NRSB ARL0017

EPA Method #402-R-92-004
Liquid Scintillation
NRPP Device Code 8088
NRSB Device Code 12193

Laboratory Report for:

Property Tested:

Pendleton Early Learning Center
455 Southwest 13th Street
Pendleton OR 97801

Pendleton Early Learning Center
455 Southwest 13th Street
Pendleton OR 97801


Log Number	Device Number	Test Exposure	Duration:	Area Tested	Result pCi/L
2846342	4420516	02/01/2021 6:23 am	02/04/2021 6:29 am	Room 127	< 0.4
2846343	4420513	02/01/2021 6:23 am	02/04/2021 6:29 am	Room 127	7.2
2846344	4420517	02/01/2021 6:23 am	02/04/2021 6:29 am	Room 127	15.4
2846345	4420512	02/01/2021 6:21 am	02/04/2021 6:32 am	Room 173	0.7
2846346	4420514	02/01/2021 6:21 am	02/04/2021 6:32 am	Room 173	0.6

Comment: AMENDED REPORT for 4420514 on 02/25/21 to add the beginning & ending date & time. A copy of this report was emailed to klebsock@pendletonsd.org.

Test Performed By: Ken Lebsock

Distributed by: Inspect USA

Date Received: 02/08/2021 Date Logged: 02/08/2021 Date Analyzed: 02/09/2021 Date Reported: 02/09/2021

Report Reviewed By: 

Report Approved By: 

Shawn Price, Director of Laboratory Operations, AccuStar Labs

Disclaimer:

The uncertainty of this radon measurement is ~+/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.