


# Water Testing Results - McKay Creek Elementary

## Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
SICKROOM RESTROOM SINK	22070100-001BF	2/16/2023	ND
WOMEN'S OFFICE RESTROOM	22070100-002BF	2/16/2023	ND
STAFF BREAKROOM STAFF SINK	22070100-003SF	2/16/2023	ND
STAFF BREAKROOM WATER COOLER	22070100-004WC	2/16/2023	ND
CLASSROOM 1 RESTROOM SINK	22070100-005BF	2/16/2023	ND
CLASSROOM 2 RESTROOM SINK	22070100-006BF	2/16/2023	ND
EAST PRIMARY HALLWAY WATER BOTTLE FILLER	22070100-007WB	2/16/2023	ND
EAST HALL ADULT RESTROOM	22070100-008BF	2/16/2023	ND
PRIMARY RESTROOM SINK - North	22070100-009BF	2/16/2023	ND
PRIMARY RESTROOM SINK - South	22070100-010BF	2/16/2023	ND
CLASSROOM 3 SINK	22070100-011CF	2/16/2023	ND
CLASSROOM 3 DRINKING FOUNTAIN	22070100-012DW	2/16/2023	ND
WEST SECOND HALLWAY WATER BOTTLE FILLER	22070100-013WB	2/16/2023	ND
CLASSROOM 4 SINK	22070100-014CF	2/16/2023	ND
CLASSROOM 4 DRINKING FOUNTAIN	22070100-015DW	2/16/2023	ND
CLASSROOM 5 SINK	22070100-016CF	2/16/2023	ND
CLASSROOM 5 DRINKING FOUNTAIN	22070100-017DW	2/16/2023	ND
CLASSROOM 6 SINK	22070100-018CF	2/16/2023	ND
CLASSROOM 6 DRINKING FOUNTAIN	22070100-019DW	2/16/2023	ND
SECONDARY RESTROOM SINK	22070100-020BF	2/16/2023	ND
CLASSROOM 10 SINK	22070100-021CF	2/16/2023	ND
CLASSROOM 10 DRINKING FOUNTAIN	22070100-022DW	2/16/2023	ND
CLASSROOM 12 SINK	22070100-023CF	2/16/2023	ND
CLASSROOM 12 DRINKING FOUNTAIN	22070100-024DW	2/16/2023	ND
CLASSROOM 14 SINK	22070100-025CF	2/16/2023	ND
CLASSROOM 14 DRINKING FOUNTAIN	22070100-026DW	2/16/2023	ND
CLASSROOM 13 SINK	22070100-027CF	2/16/2023	ND
CLASSROOM 13 DRINKING FOUNTAIN	22070100-028DW	2/16/2023	ND
CLASSROOM 11 SINK	22070100-029CF	2/16/2023	ND
CLASSROOM 11 DRINKING FOUNTAIN	22070100-030DW	2/16/2023	ND
COMPUTER LAB SINK	22070100-031CF	2/16/2023	ND
COMPUTER LAB DRINKING FOUNTAIN	22070100-032DW	2/16/2023	ND
CLASSROOM 8 SINK	22070100-033CF	2/16/2023	ND
CLASSROOM 8 DRINKING FOUNTAIN	22070100-034DW	2/16/2023	ND
CLASSROOM 7 SINK	22070100-035CF	2/16/2023	ND
CLASSROOM 7 DRINKING FOUNTAIN	22070100-036DW	2/16/2023	ND

KITCHEN-Next to Dishwasher	22070100-037KF	2/16/2023	ND
MUSIC ROOM-NORTH WALL SINK	22070100-039CF	2/16/2023	ND
MUSIC ROOM DRINKING FOUNTAIN	22070100-040DW	2/16/2023	ND
GYM WATER BOTTLE FILLER	22070100-041WB	2/16/2023	ND
GYM RESTROOM SINK	22070100-042BF	2/16/2023	32.6
CLASSROOM 1 DRINKING FOUNTAIN	22070100-043DW	2/16/2023	ND
CLASSROOM 1 SINK	22070100-044CF	2/16/2023	ND
CLASSROOM 2 DRINKING FOUNTAIN	22070100-045CF	2/16/2023	1.2
CLASSROOM 2 SINK	22070100-046DW	2/16/2023	1.2
Any fixture testing at or above the action level of 15 ppb is IMMEDIATELY removed from service and cannot be returned to service until it has been remediated and passed follow-up testing			
RETESTS			
GYM RESTROOM SINK	22070100-042BF	4/6/2023	ND
ND = Non Detect - Lead level is below the set detection limits of 1.0 ppb			



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 3031025

Pendleton School District	Project: General	Date Reported: 03/30/23
107 NW 10th Street	Project #: McKay Elementary / Lead Testing	Date Received: 03/10/23 09:30
Pendleton, OR 97801	Client Contact: Michelle Jones	Sampled By: Thad Baum

### Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
3031025-01	Sample Location: 22070100-001BF/Sickroom-Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:45	03/24/23	DST	
3031025-02	Sample Location: 22070100-002BF/Women's Office-Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 06:50	03/24/23	DST	
3031025-03	Sample Location: 22070100-003SF/Staff Breakroom-Staff Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 06:49	03/24/23	DST	
3031025-04	Sample Location: 22070100-004WC/Staff Breakroom-Water Cooler									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:48	03/24/23	DST	
3031025-05	Sample Location: 22070100-005BF/Classroom 1-Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 06:55	03/24/23	DST	
3031025-06	Sample Location: 22070100-006BF/Classroom 2-Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 06:56	03/24/23	DST	
3031025-07	Sample Location: 22070100-007WB/East Primary Hallway-Water Bottle Filler									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 06:59	03/24/23	DST	
3031025-08	Sample Location: 22070100-008BF/East Hall Adult Restroom-Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 06:58	03/24/23	DST	
3031025-09	Sample Location: 22070100-009BF/Primary Restroom Sink-North Sink #1									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:02	03/24/23	DST	
3031025-10	Sample Location: 22070100-010BF/Primary Restroom Sink-South Sink #2									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:00	03/24/23	DST	
3031025-11	Sample Location: 22070100-011CF/Classroom 3-Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:04	03/24/23	DST	
3031025-12	Sample Location: 22070100-012DW/Classroom 3-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:04	03/24/23	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 3031025

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
3031025-13	Sample Location: 22070100-013WB/West Second Hallway-Water Bottle Filler									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:43	03/24/23	DST	
3031025-14	Sample Location: 22070100-014CF/Classroom 4-Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:06	03/24/23	DST	
3031025-15	Sample Location: 22070100-015DW/Classroom 4-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:07	03/24/23	DST	
3031025-16	Sample Location: 22070100-016CF/Classroom 5-Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:08	03/24/23	DST	
3031025-17	Sample Location: 22070100-017DW/Classroom 5-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:08	03/24/23	DST	
3031025-18	Sample Location: 22070100-018CF/Classroom 6-Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:10	03/24/23	DST	
3031025-19	Sample Location: 22070100-019DW/Classroom 6-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:11	03/24/23	DST	
3031025-20	Sample Location: 22070100-020BF/Secondary Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:13	03/24/23	DST	
3031025-21	Sample Location: 22070100-021CF/Classroom 10-Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:20	03/24/23	DST	
3031025-22	Sample Location: 22070100-022DW/Classroom 10-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:21	03/24/23	DST	
3031025-23	Sample Location: 22070100-023CF/Classroom 12-Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:23	03/24/23	DST	
3031025-24	Sample Location: 22070100-024DW/Classroom 12-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:24	03/24/23	DST	
3031025-25	Sample Location: 22070100-025CF/Classroom 14-Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:25	03/24/23	DST	
3031025-26	Sample Location: 22070100-026DW/Classroom 14-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:28	03/24/23	DST	
3031025-27	Sample Location: 22070100-027CF/Classroom 13-Sink									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 3031025

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:29	03/24/23	DST	
3031025-28	Sample Location: 22070100-028DW/Classroom 13-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:31	03/24/23	DST	
3031025-29	Sample Location: 22070100-029CF/Classroom 11-Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:32	03/24/23	DST	
3031025-30	Sample Location: 22070100-030DW/Classroom 11-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:34	03/24/23	DST	
3031025-31	Sample Location: 22070100-031CF/Computer Lab-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:35	03/24/23	DST	
3031025-32	Sample Location: 22070100-032DW/Computer Lab-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:36	03/24/23	DST	
3031025-33	Sample Location: 22070100-033CF/Classroom 8-Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:38	03/24/23	DST	
3031025-34	Sample Location: 22070100-034DW/Classroom 8-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:38	03/24/23	DST	
3031025-35	Sample Location: 22070100-035CF/Classroom 7-Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:40	03/24/23	DST	
3031025-36	Sample Location: 22070100-036DW/Classroom 7-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:41	03/24/23	DST	
3031025-37	Sample Location: 22070100-037KF/Kitchen-Next to Dishwasher-Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:56	03/24/23	DST	
3031025-38	Sample Location: 22070100-039CF/Music Room-North Classroom Sink #2									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:53	03/24/23	DST	
3031025-39	Sample Location: 22070100-040DW/Music Room-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:53	03/24/23	DST	
3031025-40	Sample Location: 22070100-041WB/Gym-Water Bottle Filler									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 07:17	03/24/23	DST	
3031025-41	Sample Location: 22070100-042BF/Gym-Restroom Sink									
Lead (±)		1030	32.6	ppb	1.0	15	02/16/23 06:55	03/24/23	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 3031025

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
3031025-42	Sample Location: 22070100-043DW/Classroom 1-Drinking Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 06:53	03/24/23	DST	
3031025-43	Sample Location: 22070100-044CF/Classroom 1-Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/16/23 06:51	03/24/23	DST	
3031025-44	Sample Location: 22070100-045CF/Classroom 2-Sink									
Lead (±)		1030	1.2	ppb	1.0	15	02/16/23 06:57	03/24/23	DST	
3031025-45	Sample Location: 22070100-046DW/Classroom 2-Drinking Fountain									
Lead (±)		1030	1.2	ppb	1.0	15	02/16/23 07:58	03/24/23	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 3031025

### Qualifiers and Definitions


DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 3041110

Pendleton School District  
107 NW 10th Street  
Pendleton, OR 97801

Project: General  
Project #: McKay Elementary Retest Lead  
Testing  
Client Contact: Michelle Jones

Date Reported: 04/17/23  
Date Received: 04/11/23 11:10  
Sampled By: Jesse Lantz

### Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
3041110-01	Sample Location: 22070100-042BF- Gym Restroom Sink/Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	04/06/23 11:17	04/13/23	DST	


UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager





## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 3041110

### Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

---

Dan Phillips, Laboratory Manager