


# Water Testing Results - Pendleton Early Learning Center

## Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID#	Test Date	Test Result
WIC OFFICE 163 WIC SINK	22070800-001SF	2/17/2023	ND
WIC OFFICE 164 WIC SINK	22070800-002SF	2/17/2023	ND
HEALTH CARE ROOM 166 EXAM RM SINK	22070800-003NS	2/17/2023	ND
HEALTH CARE ROOM 167 EXAM RM SINK	22070800-004NS	2/17/2023	ND
HEADSTART HALLWAY NORTH RESTROOM SINK	22070800-005BF	2/17/2023	ND
HEADSTART HALLWAY SOUTH RESTROOM SINK	22070800-006BF	2/17/2023	ND
CHILD CARE 173 - West SINK	22070800-007CF	2/17/2023	ND
CHILD CARE 173 - Middle SINK	22070800-008CF	2/17/2023	ND
CHILD CARE 173 - East SINK	22070800-009CF	2/17/2023	ND
MOTHER'S ROOM 178 SINK	22070800-010OT	2/17/2023	ND
HEADSTART CLASSROOM SINK-West	22070800-011CF	2/17/2023	ND
HEADSTART CLASSROOM SINK-East	22070800-012CF	2/17/2023	ND
HEADSTART RM 2 RESTROOM SINK - East	22070800-013BF	2/17/2023	ND
HEADSTART RM 2 RESTROOM SINK - West	22070800-014BF	2/17/2023	ND
HEADSTART RM 1 RESTROOM SINK - West	22070800-015BF	2/17/2023	ND
HEADSTART RM 1 RESTROOM SINK- East	22070800-016BF	2/17/2023	ND
HEADSTART CLASSROOM-1 SINK - West	22070800-017CF	2/17/2023	ND
HEADSTART CLASSROOM-1 SINK - East	22070800-018CF	2/17/2023	ND
STAFF BREAKROOM SINK SOUTH	22070800-019SF	2/17/2023	ND
KITCHEN SINK-REAR	22070800-020KF	2/17/2023	ND
KITCHEN SINK-FRONT	22070800-021KF	2/17/2023	ND
GYM WATER BOTTLE FILLER	22070800-022WB	2/17/2023	ND
LUNCHROOM/COMMONS - West RESTROOM SINK	22070800-023BF	2/17/2023	ND
LUNCHROOM/COMMONS - West Middle RESTROOM SINK	22070800-024BF	2/17/2023	ND
LUNCHROOM/COMMONS - East Middle RESTROOM SINK	22070800-025BF	2/17/2023	ND
LUNCHROOM/COMMONS - East RESTROOM SINK	22070800-026BF	2/17/2023	ND
CLASSROOM #103 SINK	22070800-027CF	2/17/2023	ND
CLASSROOM #103 DRINK FOUNTAIN	22070800-028DW	2/17/2023	ND
CLASSROOM #103 WATER COOLER	22070800-029WC	2/17/2023	ND
103/105 RESTROOM SINK	22070800-030BF	2/17/2023	1.1
CLASSROOM #105 DRINK FOUNTAIN	22070800-031DW	2/17/2023	ND
CLASSROOM #105 SINK	22070800-032CF	2/17/2023	ND
CLASSROOM #107 DRINK FOUNTAIN	22070800-033DW	2/17/2023	ND
CLASSROOM #107 SINK	22070800-034CF	2/17/2023	ND
CLASSROOM #109 SINK	22070800-035CF	2/17/2023	ND
CLASSROOM #109 DRINK FOUNTAIN	22070800-036DW	2/17/2023	ND
CLASSROOM #111 SINK	22070800-037CF	2/17/2023	ND
CLASSROOM #111 DRINK FOUNTAIN	22070800-038DW	2/17/2023	ND
WEST STAFF RESTROOM	22070800-039BF	2/17/2023	ND
STAFF BREAKROOM WEST	22070800-040SF	2/17/2023	ND
CLASSROOM #113 SINK	22070800-041CF	2/17/2023	ND
CLASSROOM #113 DRINK FOUNTAIN	22070800-042DW	2/17/2023	ND
CLASSROOM #115 SINK	22070800-043CF	2/17/2023	ND
CLASSROOM #115 DRINK FOUNTAIN	22070800-044DW	2/17/2023	ND
CLASSROOM #117 SINK	22070800-045CF	2/17/2023	ND
CLASSROOM #117 DRINK FOUNTAIN	22070800-046DW	2/17/2023	ND
CLASSROOM #119 SINK	22070800-047CF	2/17/2023	ND
CLASSROOM #119 DRINK FOUNTAIN	22070800-048DW	2/17/2023	ND
CLASSROOM #118 SINK	22070800-049CF	2/17/2023	ND
CLASSROOM #118 DRINK FOUNTAIN	22070800-050DW	2/17/2023	ND
CLASSROOM #116 SINK	22070800-051CF	2/17/2023	ND
CLASSROOM #116 DRINK FOUNTAIN	22070800-052DW	2/17/2023	ND
CLASSROOM #114 SINK	22070800-053CF	2/17/2023	ND
CLASSROOM #114 DRINK FOUNTAIN	22070800-054DW	2/17/2023	ND

CLASSROOM #112 SINK	22070800-055CF	2/17/2023	ND
CLASSROOM #112 DRINK FOUNTAIN	22070800-056DW	2/17/2023	ND
CLASSROOM #110 SINK	22070800-057CF	2/17/2023	ND
CLASSROOM #110 DRINK FOUNTAIN	22070800-058DW	2/17/2023	ND
STAFF SINK WORKROOM #108	22070800-059SF	2/17/2023	ND
CLASSROOM #108 DRINK FOUNTAIN	22070800-060DW	2/17/2023	ND
CLASSROOM #106 SINK	22070800-061CF	2/17/2023	ND
CLASSROOM #106DRINK FOUNTAIN	22070800-062DW	2/17/2023	ND
CLASSROOM #104 SINK	22070800-063CF	2/17/2023	ND
CLASSROOM #104 DRINK FOUNTAIN	22070800-064DW	2/17/2023	ND
CLASSROOM #102 SINK	22070800-065CF	2/17/2023	ND
CLASSROOM #102 DRINK FOUNTAIN	22070800-066DW	2/17/2023	ND
PLAYGROUND-SHORT DRINK FOUNTAIN	22070800-067DW	TBD - May 2023	
PLAYGROUND-TALL DRINK FOUNTAIN	22070800-068DW	TBD - May 2023	
Any fixture testing at or above the action level of 15 ppb is immediately removed from service			
RETESTS			
ND = Non Detect - Lead level is below the set detection limits			of 1 ppb



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 3031402

Pendleton School District	Project: General	Date Reported: 03/30/23
107 NW 10th Street	Project #: PELC Lead Testing	Date Received: 03/10/23 09:30
Pendleton, OR 97801	Client Contact: Michelle Jones	Sampled By: Thad Baum
	-	

### Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
3031402-01	Sample Location: 22070800-001SF/Wic Office 163-Wic Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:16	03/24/23	DST	
3031402-02	Sample Location: 22070800-002SF/Wic Office 164-Wic Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:17	03/24/23	DST	
3031402-03	Sample Location: 22070800-003NS/Health Care Room 166-Exam Rm. Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:17	03/24/23	DST	
3031402-04	Sample Location: 22070800-004NS/Health care Room 167-Exam Rm. Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:20	03/24/23	DST	
3031402-05	Sample Location: 22070800-005BF/Headstart Hallway North-Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:22	03/24/23	DST	
3031402-06	Sample Location: 22070800-006BF/Headstart Hallway South-Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:23	03/24/23	DST	
3031402-07	Sample Location: 22070800-007CF/Child Care 173 West-Classroom Sink 1									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:25	03/24/23	DST	
3031402-08	Sample Location: 22070800-008CF/Child Care 173 Middle-Classroom Sink 2									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:26	03/24/23	DST	
3031402-09	Sample Location: 22070800-009CF/Child Care 173 East-Classroom Sink 3									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:26	03/24/23	DST	
3031402-10	Sample Location: 22070800-010CF/Mother's Room 178-Mothers Rm. Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:28	03/24/23	DST	
3031402-11	Sample Location: 22070800-011CF/Headstart Classroom West-Classroom Sink 1									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:30	03/24/23	DST	
3031402-12	Sample Location: 22070800-012CF/Headstart Classroom East-Classroom Sink 2									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:31	03/24/23	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 3031402

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
3031402-13	Sample Location: 22070800-013BF/Headstart Rm. 2 Restroom East-Restroom Sink 1									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:32	03/24/23	DST	
3031402-14	Sample Location: 22070800-014BF/Headstart Rm. 2 Restroom West-Restroom Sink 2									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:31	03/24/23	DST	
3031402-15	Sample Location: 22070800-015BF/Headstart Rm. 1 Restroom West-Restroom Sink 1									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:33	03/24/23	DST	
3031402-16	Sample Location: 22070800-016BF/Headstart Rm. 1 Restroom East-Restroom Sink 2									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:36	03/24/23	DST	
3031402-17	Sample Location: 22070800-017CF/Headstart Classroom 1 West-Classroom Sink 1									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:34	03/24/23	DST	
3031402-18	Sample Location: 22070800-018CF/Headstart Classroom 1 East-Classroom Sink 2									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:35	03/24/23	DST	
3031402-19	Sample Location: 22070800-019SF/Staff Breakroom South-Breakroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:38	03/24/23	DST	
3031402-20	Sample Location: 22070800-020KF Kitchen Rear-Kitchen Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:40	03/24/23	DST	
3031402-21	Sample Location: 22070800-021KF Kitchen Front-Kitchen Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:40	03/24/23	DST	
3031402-22	Sample Location: 22070800-022WB/Gym-Water Bottle Filler									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:43	03/24/23	DST	
3031402-23	Sample Location: 22070800-023BF/Lunchroom Commons West-Restroom Sink 1									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:44	03/24/23	DST	
3031402-24	Sample Location: 22070800-024BF/Lunchroom Commons West Middle-Restroom Sink 2									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:45	03/24/23	DST	
3031402-25	Sample Location: 22070800-025BF/Lunchroom Commons East Middle-Restroom Sink 3									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:45	03/24/23	DST	
3031402-26	Sample Location: 22070800-026BF/Lunchroom Commons East-Restroom Sink 4									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:46	03/24/23	DST	
3031402-27	Sample Location: 22070800-027CF/Classroom #103-Classroom Sink									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 3031402

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:44	03/25/23	DST	
3031402-28	Sample Location: 22070800-028DW/Classroom #103-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:44	03/25/23	DST	
3031402-29	Sample Location: 22070800-029WC/Classroom #103-Water Cooler									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:50	03/25/23	DST	
3031402-30	Sample Location: 22070800-030BF/103/105 Restroom-Restroom Sink									
Lead (±)		1030	1.1	ppb	1.0	15	02/17/23 06:49	03/25/23	DST	
3031402-31	Sample Location: 22070800-031DW/Classroom #105-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:41	03/25/23	DST	
3031402-32	Sample Location: 22070800-032CF/Classroom #105-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:41	03/25/23	DST	
3031402-33	Sample Location: 22070800-033DW/Classroom #107-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:37	03/25/23	DST	
3031402-34	Sample Location: 22070800-034CF/Classroom #107-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:37	03/25/23	DST	
3031402-35	Sample Location: 22070800-035CF/Classroom #109-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:36	03/25/23	DST	
3031402-36	Sample Location: 22070800-036DW/Classroom #109-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:36	03/25/23	DST	
3031402-37	Sample Location: 22070800-037CF/Classroom #111-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:32	03/25/23	DST	
3031402-38	Sample Location: 22070800-038DW/Classroom #111-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:32	03/25/23	DST	
3031402-39	Sample Location: 22070800-039BF/West Staff Restroom-Restroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:30	03/25/23	DST	
3031402-40	Sample Location: 22070800-040SF/Staff Breakroom West-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:30	03/25/23	DST	
3031402-41	Sample Location: 22070800-041CF/Classroom #113-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:27	03/25/23	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 3031402

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
3031402-42	Sample Location: 22070800-042DW/Classroom #113-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:27	03/25/23	DST	
3031402-43	Sample Location: 22070800-043CF/Classroom Sink #115-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:45	03/25/23	DST	
3031402-44	Sample Location: 22070800-044DW/Classroom #115-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:25	03/25/23	DST	
3031402-45	Sample Location: 22070800-045CF/Classroom #117-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:22	03/25/23	DST	
3031402-46	Sample Location: 22070800-046DW/Classroom #117-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:22	03/25/23	DST	
3031402-47	Sample Location: 22070800-047CF/Classroom #119-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:18	03/25/23	DST	
3031402-48	Sample Location: 22070800-048DW/Classroom #119-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:18	03/25/23	DST	
3031402-49	Sample Location: 22070800-049CF/Classroom #118-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:16	03/25/23	DST	
3031402-50	Sample Location: 22070800-050DW/Classroom #118-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:15	03/25/23	DST	
3031402-51	Sample Location: 22070800-051CF/Classroom #116-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:21	03/25/23	DST	
3031402-52	Sample Location: 22070800-052DW/Classroom #116-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:22	03/25/23	DST	
3031402-53	Sample Location: 22070800-053CF/Classroom #114-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:24	03/25/23	DST	
3031402-54	Sample Location: 22070800-054DW/Classroom #114-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:24	03/25/23	DST	
3031402-55	Sample Location: 22070800-055CF/Classroom #112-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:28	03/25/23	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: http://ChemLab.cc  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 3031402

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
3031402-56	Sample Location: 22070800-056DW/Classroom #112-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:28	03/28/23	DST	
3031402-57	Sample Location: 22070800-057CF/Classroom #110-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:35	03/28/23	DST	
3031402-58	Sample Location: 22070800-058DW/Classroom #110-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:34	03/28/23	DST	
3031402-59	Sample Location: 22070800-059SF/Staff Workroom #108-Staff Office Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:38	03/28/23	DST	
3031402-60	Sample Location: 22070800-060DW/Classroom #108-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:38	03/28/23	DST	
3031402-61	Sample Location: 22070800-061CF/Classroom #106-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:40	03/28/23	DST	
3031402-62	Sample Location: 22070800-062DW/Classroom #106-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:40	03/28/23	DST	
3031402-63	Sample Location: 22070800-063CF/Classroom #104-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:42	03/28/23	DST	
3031402-64	Sample Location: 22070800-064DW/Classroom #104-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:47	03/28/23	DST	
3031402-65	Sample Location: 22070800-065CF/Classroom #102-Classroom Sink									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:45	03/28/23	DST	
3031402-66	Sample Location: 22070800-066DW/Classroom #102-Drink Fountain									
Lead (±)		1030	ND	ppb	1.0	15	02/17/23 06:45	03/28/23	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 3031402

### Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

---

Dan Phillips, Laboratory Manager