Water Testing Results -	PHS- HEAD	PHS- HEAD START CHILD CARE								
Action Level is 15 parts per billion (ppb)										
Fixture Location/Description	Fixture ID#	Test Date	Test Result							
CHILDCARE ROOM 103 RESTROOM SINK-1	22070500-006BF	2/16/2023	ND							
CHILDCARE ROOM 103 RESTROOM SINK-2	22070500-007BF	2/16/2023	ND							
CHILDCARE ROOM 103 CLASSROOM SINK	22070500-008 <i>C</i> F	2/16/2023	ND							
CHILDCARE ROOM 103 - KITCHEN SINGLE SINK	22070500-009KF	2/16/2023	ND							
CHILDCARE ROOM 103 - KITCHEN DOUBLE SINK	22070500-10KF	2/16/2023	ND							
CHILDCARE ROOM 103 - STAFF OFFICE SINK	22070500-011SF	2/16/2023	ND							
Any fixture testing at or above the action level of 15 ppb is immediately removed from service										
RETESTS										
ND = Non Detect - Lead level is below	of 1 ppb									



UMPQUA Research Company

626 NE Division St. - P.O. Box 609 Myrtle Creek, Oregon 97457 (541) 863-5201 Fax: (541) 863-6199

E-mail: Lab@URCmail.net Internet: http://ChemLab.cc ORELAP ID# OR100031

Project: General

Date Reported:

03/30/23

ANALYSIS REPORT

3031001

URC#

107 NW 10th Street Pendleton, OR 97801

Pendleton School District

Project #: PHS-Headstart / Lead Testing

Date Received: 03/10/23 09:30 Sampled By:

Thad Baum

Client Contact: Michelle Jones

Method: EP	A 200.8							Matrix: Dr	inking Water	
	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst Qualifier	
3031001-01	Sample Location: 22070500-006BF / Childcare Room 103-Restroom Sink #1									
Lead (‡)		1030	ND	ppb	1.0	15	02/16/23 08:42	03/24/23	DST	
3031001-02	Sample Location: 22070500-007BF / Childcare Room 103-Restroom Sink #2									
Lead (‡)		1030	ND	ppb	1.0	15	02/16/23 08:45	03/24/23	DST	
3031001-03	Sample Location: 22070500-008CF / Childcare Room 103-Classroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/16/23 08:45	03/24/23	DST	
3031001-04	Sample Location: 22070500-009KF / Childcare Room 103-Single Kitchen Sink #1									
Lead (‡)		1030	ND	ppb	1.0	15	02/16/23 08:40	03/24/23	DST	
3031001-05	Sample Location: 22070500-010KF / Childcare Room 103-Double Kitchen Sink #2									
Lead (‡)		1030	ND	ppb	1.0	15	02/16/23 08:43	03/24/23	DST	
3031001-06	Sample Location: 22070500-011SF / Childcare Room 103-Office Staff Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/16/23 08:40	03/24/23	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609 Myrtle Creek, Oregon 97457 (541) 863-5201 Fax: (541) 863-6199

E-mail: Lab@URCmail.net Internet: http://ChemLab.cc ORELAP ID# OR100031 ANALYSIS REPORT URC # 3031001

Qualifiers and Definitions

DET Analyte DETECTED

ND Analyte NOT DETECTED at or above the MRL (minimum reporting limit)

NA Not Applicable NR Not Reported

dry Sample results reported on a dry weight basis

RPD Relative Percent Difference
MRL Minimum Reporting Limit
MDL Minimum Detection Limit
MCL Maximum Contamination Level
(‡) ORELAP Accredited Analyte

(~) Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager