



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4031434

Pendleton School District
 107 NW 10th Street
 Pendleton, OR 97801

Project: General
 Project #: PHS Bldg 6 Lead Testing
 Client Contact: Michelle Jones

Date Reported: 03/26/24
 Date Received: 03/13/24 11:00
 Sampled By: Thad Baum

Method: USEPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
4031434-01	Sample Location: 22070502-056BF/ Womans Restroom Bldg 6 1212 / Left Sink-1									
Lead (‡)		1030	1.5	ppb	1.0	15	03/08/24 10:00	03/21/24	DST	
4031434-02	Sample Location: 22070502-057BF/ Womans Restroom Bldg 6 1212 / Middle Sink-2									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 10:00	03/21/24	DST	
4031434-03	Sample Location: 22070502-058BF/ Womans Restroom Bldg 6 1212 / Right Sink-3									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 10:00	03/21/24	DST	
4031434-04	Sample Location: 22070502-059DW/ Theatre Lobby Hallway 1210 / Drinking Fountain									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 10:05	03/21/24	DST	
4031434-05	Sample Location: 22070502-060WB/ Theatre Lobby Hallway 1210 / Water Bottle Filler									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 10:05	03/21/24	DST	
4031434-06	Sample Location: 22070502-061BF/ Mens Restroom Bldg 6 1218 / Left Restroom Sink-1									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 10:08	03/21/24	DST	
4031434-07	Sample Location: 22070502-062BF/ Mens Restroom Bldg 6 1218 / Middle Restroom Sink-2									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 10:08	03/21/24	DST	
4031434-08	Sample Location: 22070502-064CF/ Band Room Entry Hall 1222 / Classroom Sink									
Lead (‡)		1030	1.2	ppb	1.0	15	03/08/24 10:09	03/21/24	DST	
4031434-09	Sample Location: 22070502-065BF/ Girls Dressing Room 1242 / Left Restroom Sink									
Lead (‡)		1030	50.9	ppb	1.0	15	03/08/24 10:15	03/21/24	DST	
4031434-10	Sample Location: 22070502-066BF/ Girls Dressing Room 1242 / Right Restroom Sink									
Lead (‡)		1030	7.2	ppb	1.0	15	03/08/24 10:15	03/21/24	DST	
4031434-11	Sample Location: 22070502-067BF/ Theatre Corridor East Restroom 1242 / Right Bathroom Sink									
Lead (‡)		1030	2.9	ppb	1.0	15	03/08/24 10:19	03/21/24	DST	
4031434-12	Sample Location: 22070502-068BF/ Theatre Corridor West Restroom 1239 / Left Bathroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 10:11	03/21/24	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4031434

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
4031434-13	Sample Location: 22070502-069BF/ Boys Dressing Room 1239 / Left Restroom Sink									
Lead (±)		1030	17.7	ppb	1.0	15	03/08/24 10:21	03/21/24	DST	
4031434-14	Sample Location: 22070502-070BF/ Boys Dressing Room 1239 / Right Restroom Sink									
Lead (±)		1030	17.4	ppb	1.0	15	03/08/24 10:21	03/21/24	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 3120104

Pendleton School District 107 NW 10th Street Pendleton, OR 97801	Project: General Project #: Pendleton High School Client Contact: Michelle Jones	Date Reported: 12/07/23 Date Received: 12/01/23 10:35 Sampled By: Michelle Jones
--	--	--

Method: USEPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
3120104-01	Sample Location: Pendleton HS 063BF									
Lead (±)		1030	ND	ppb	1.0	15	11/14/23 06:50	12/04/23		DST



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4031434

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager