Lead in Water Test Results Summary: Hitting Facility

Notes:

- The lead in water Action Level is 15 parts per billion (ppb).
- Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.

Legend:

- Test results equal to or greater than the Action Level of 15 ppb are highlighted in red and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results near the Action Level of 15 ppb (11.99 to 14.99 ppb) are highlighted in yellow and precede a "Med" (Medium) value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
HITTING FACILITY-SHORT DRINKING FOUNTAIN	22070005-010DW	3/6/2024	ND	Low	[enter date]	[enter result]	[autofill]
HITTING FACILITY-TALL	22070005-011DW	3/6/2024	ND	Low			
HITTING FACILITY-GIRLS EAST RESTROOM SINK	22070005-012BF	3/6/2024	ND	Low			
HITTING FACILITY-BOYS WEST RESTROOM SINK	22070005-013BF						



UMPQUA Research Company

626 NE Division St. - P.O. Box 609 Myrtle Creek, Oregon 97457 (541) 863-5201 Fax: (541) 863-6199

E-mail: Lab@URCmail.net Internet: http://ChemLab.cc ORELAP ID# OR100031

Pendleton School District

107 NW 10th Street

Pendleton, OR 97801

Project: General

Project #: PHS Hitting Facility Lead Testing

Date Reported: 03/26/24

ANALYSIS REPORT

URC#

Date Received: 03/13/24 11:00

4031437

Sampled By:

T. Baum

Client Contact: Michelle Jones

Method: USEPA 200.8									Matrix: Drinking Water		
	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst Qualifier		
4031437-01	Sample Location: 22070005-010DW/Hitting Facility-Short Drinking Fountain										
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 10:40	03/21/24	DST		
4031437-02	Sample Location: 22070005-011DW/Hitting Facility-Tall / Drinking Fountain										
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 10:41	03/21/24	DST		
4031437-03	Sample Location: 22	070005-012	2BF/Hitting F	acility-Girls Eas	st Restroom Sin	ık / Drink	ing Fountain				
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 10:42	03/21/24	DST		

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609 Myrtle Creek, Oregon 97457 (541) 863-5201 Fax: (541) 863-6199

E-mail: Lab@URCmail.net

Internet: http://ChemLab.cc ORELAP ID# OR100031

ANALYSIS REPORT URC # 4031437

Qualifiers and Definitions

DET Analyte DETECTED

ND Analyte NOT DETECTED at or above the MRL (minimum reporting limit)

NA Not Applicable
NR Not Reported

dry Sample results reported on a dry weight basis

RPD Relative Percent Difference

MRL Minimum Reporting Limit

MDL Minimum Detection Limit

MCL Maximum Contamination Level

(‡) ORELAP Accredited Analyte

(~) Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager