

Lead in Water Test Results Summary: Pendleton High School Main Bldg

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.

Legend:

- Test results equal to or greater than the Action Level of 15 ppb are highlighted in red and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results near the Action Level of 15 ppb (11.99 to 14.99 ppb) are highlighted in yellow and precede a "Med" (Medium) value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
MAIN OFFICE MENS RESTROOM SINK	22070500-001BF	3/8/2024	ND	Low	[enter date]	[enter result]	[autofill]
MAIN OFFICE DRINKING-TALL DRINKING	22070500-002DW	3/8/2024	ND	Low			
MAIN OFFICE DRINKING-SHORT DRINKING	22070500-003DW	3/8/2024	ND	Low			
MAIN OFFICE WOMENS RESTROOM SINK	22070500-004BF	3/8/2024	ND	Low			
CONFERENCE ROOM SINK	22070500-005SF	3/8/2024	ND	Low			
CLASSROOM #107 NORTH LEFT SINK	22070500-012KF	3/8/2024	ND	Low			
CLASSROOM #107 NORTH MIDDLE SINK	22070500-013KF	3/8/2024	ND	Low			
CLASSROOM #107 NORTH RIGHT SINK	22070500-014KF	3/8/2024	2.4	Low			
CLASSROOM #107 SOUTH LEFT SINK	22070500-015KF	3/8/2024	2.1	Low			
CLASSROOM #107 SOUTH MIDDLE SINK	22070500-016KF	3/8/2024	ND	Low			
CLASSROOM #107 SOUTH RIGHT SINK	22070500-017KF	3/8/2024	ND	Low			
BUILDING 4 HALLWAY 1ST FLOOR BOTTLE	22070500-018WB	3/8/2024	ND	Low			
BUILDING 4 HALLWAY 1ST FLOOR DRINKING	22070500-019DW	3/8/2024	ND	Low			
CLASSROOM #111B RESTROOM SINK	22070500-020BF	3/8/2024	ND	Low			
CLASSROOM #111B KITCHEN SINK	22070500-021KF	3/8/2024	ND	Low			
BOYS 1ST FLOOR SINK BY LIFE SKILLS	22070500-022BF	3/8/2024	1.4	Low			
GIRLS 1ST FLOOR SINK BY LIFE SKILLS	22070500-023BF	3/8/2024	ND	Low			
CLASSROOM #108 SINK	22070500-024CF	3/8/2024	ND	Low			
CLASSROOM #104 SINK	22070500-025CF	3/8/2024	1.6	Low			
STAFF WORK ROOM SINK	22070500-026SF	3/8/2024	ND	Low			
STAFF LOUNGE MENS RESTROOM SINK	22070500-027BF	3/8/2024	ND	Low			
STAFF LOUNGE WOMENS RESTROOM SINK	22070500-028BF	3/8/2024	ND	Low			
STAFF LOUNGE SINK-ROOM #100	22070500-029SF	3/8/2024	ND	Low			
MAIN OFFICE HEALTH ROOM SINK	22070500-030NS	3/8/2024	ND	Low			
MAIN OFFICE HEALTH ROOM RESTROOM SINK	22070500-031BF	3/8/2024	ND	Low			
GIRLS RESTROOM-COMMONS LEFT SINK	22070500-032BF	3/8/2024	ND	Low			
GIRLS RESTROOM-COMMONS RIGHT SINK	22070500-033BF	3/8/2024	ND	Low			
COMMONS BOTTLE FILLER	22070500-034WB	3/8/2024	ND	Low			
COMMONS DRINKING FOUNTAIN	22070500-035DW	3/8/2024	ND	Low			
BOYS RESTROOM-COMMONS LEFT SINK	22070500-036BF	3/8/2024	ND	Low			
BOYS RESTROOM-COMMONS RIGHT SINK	22070500-037BF	3/8/2024	ND	Low			
KITCHEN BACK COUNTER EAST SINK	22070500-038KF	3/8/2024	ND	Low			
KITCHEN -WEST SINK	22070500-039KF	3/8/2024	1.3	Low			
KITCHEN -WEST ICE MACHINE	22070500-040IM	3/8/2024	ND	Low			
NURSES HALL RESTROOM (RM#255) SINK	22070500-041BF	3/8/2024	ND	Low			
NURSES HALL STAFF RESTROOM (RM#255) SINK	22070500-042BF	3/8/2024	ND	Low			
NURSES ROOM (RM#256) WATER COOLER	22070500-043WB	3/8/2024	ND	Low			
COUNSELING CONFERENCE ROOM SINK	22070500-044SF	3/8/2024	1	Low			
BOYS RESTRM 2ND FLOOR-WARBERG SINK	22070500-046BF	11/14/2023	2	Low			
CLASSROOM #247 SINK	22070500-045CF	3/8/2024	ND	Low			
WORK ROOM # 236 SINK	22070500-047SF	3/8/2024	ND	Low			
BOYS RESTRM 2ND FLOOR-4 CORNERS SINK	22070500-048BF	3/8/2024	ND	Low			
2ND FLOOR 4 CORNERS DRINKING FOUNTAIN	22070500-049DW	3/8/2024	ND	Low			
2ND FLOOR 4 CORNERS BOTTLE FILLER	22070500-050WB	3/8/2024	ND	Low			
GIRLS RESTRM 2ND FLOOR-BUCK STOP SINK	22070500-051BF	11/14/2023	ND	Low			
GIRLS RESTRM 2ND FLOOR-WARBERG SINK	22070500-052BF	3/8/2024	ND	Low			

CLASSROOM #211 SINK	22070500-053CF	3/8/2024	1.1	Low		
STUDENT STORE BUCK STOP SINK	22070500-054KF	3/8/2024	1.2	Low		
LIBRARY WORKROOM SINK	22070500-055SF	3/8/2024	ND	Low		
BIOLOGY PREP ROOM NORTH EAST-3RD	22070500-083CF	3/8/2024	ND	Low		
BIOLOGY PREP ROOM NORTH WEST-3RD	22070500-084CF	3/8/2024	ND	Low		
GREENHOUSE-SCIENCE BEHIND NW	22070500-085OT	3/8/2024	ND	Low		
BOYS RESTRM 3RD FLOOR WEST SIDE OF	22070500-086BF	3/8/2024	1.5	Low		
BOYS RESTRM 3RD FLOOR EAST SIDE OF BLDG SINK	22070500-087BF	3/8/2024	ND	Low		
GIRLS RESTRM 3RD FLOOR EAST SIDE OF BLDG SINK	22070500-088BF	3/8/2024	ND	Low		
GIRLS RESTRM 3RD FLOOR WEST SIDE OF BLDG SINK	22070500-089BF	3/8/2024	ND	Low		
SCIENCE PREP ROOM SOUTH WEST-3RD FLOOR MAIN BDG SINK	22070500-090CF	3/8/2024	ND	Low		
SCIENCE PREP ROOM SOUTH EAST-3RD FLOOR MAIN BDG SINK	22070500-091CF	3/8/2024	ND	Low		
EAST CORRIDOR 3RD FLOOR MAIN BDG BOTTLE FILLER	22070500-092WB	3/8/2024	ND	Low		
EAST CORRIDOR 3RD FLOOR MAIN BDG DRINKING FOUNTAIN	22070500-093DW	3/8/2024	ND	Low		
WEST CORRIDOR 3RD FLOOR MAIN BDG BOTTLE FILLER	22070500-094WB	3/8/2024	ND	Low		
BUILDING 4 BOYS RESTROOM LEFT SINK	22070500-095BF	3/8/2024	ND	Low		
BUILDING 4 BOYS RESTROOM RIGHT SINK	22070500-096BF	3/8/2024	2.4	Low		
BUILDING 4 CORRIDOR DRINKING FOUNTAIN	22070500-097DW	3/8/2024	ND	Low		
BUILDING 4 CORRIDOR BOTTLE FILLER	22070500-098WB	3/8/2024	ND	Low		
BUILDING 4 GIRLS RESTROOM LEFT SINK	22070500-099BF	3/8/2024	ND	Low		
BUILDING 4 GIRLS RESTROOM RIGHT SINK	22070500-100BF	3/8/2024	ND	Low		
CLASSROOM #416 LEFT SINK	22070500-101CF	3/8/2024	23.9	High		
CLASSROOM #416 RIGHT SINK	22070500-102CF	3/8/2024	4.7	Low		
GREENHOUSE BLD 4 - SINK	22070500-103OT	3/8/2024	ND	Low		
GREENHOUSE PREP CLASSROOM #416A SINK	22070500-104CF	3/8/2024	6.2	Low		
WARBERG CONCESSIONS SINK	22070500-105KF	3/8/2024	ND	Low		
WARBERG GIRLS LOCKER ROOM RESTROOM SINK	22070500-106BF	3/8/2024	ND	Low		
WARBERG GIRLS LOCKER RM-OFFICE RESTROOM SINK	22070500-107BF	3/8/2024	3.2	Low		
WARBERG SPORTS TRAINER OFFICE SINK	22070500-108NS	3/8/2024	1.1	Low		
WARBERG BOYS LOCKER RM-OFFICE RESTROOM SINK	22070500-109BF	3/8/2024	ND	Low		
WARBERG BOYS LOCKER ROOM RESTROOM SINK	22070500-110BF	3/8/2024	ND	Low		
WEST WARBERG GYM BOTTLE FILLER	22070500-111WB	3/8/2024	ND	Low		
EAST WARBERG GYM DRINKING FOUNTAIN	22070500-112DW	3/8/2024	ND	Low		
EAST WARBERG GYM BOTTLE FILLER	22070500-113WB	3/8/2024	ND	Low		
HEALTH EXAM ROOM BY COUNSELING OFFICE SINK	22070500-124NS	4/3/2024	ND	Low		



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4031402

Pendleton School District 107 NW 10th Street Pendleton, OR 97801	Project: General Project #: PHS Lead Testing Client Contact: Michelle Jones	Date Reported: 03/26/24 Date Received: 03/13/24 11:00 Sampled By: Thad Baum
--	---	---

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
4031402-01	Sample Location: 22070500-001BF/ Main Office Mens Restroom Sink 307									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 06:41	03/22/24	DST	
4031402-02	Sample Location: 22070500-002DW/ Main Office Drinking-Tall Drinking Fountain 315									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 06:41	03/22/24	DST	
4031402-03	Sample Location: 22070500-003DW/ Main Office Drinking-Short Drinking Fountain 315									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 06:42	03/22/24	DST	
4031402-04	Sample Location: 22070500-004BF/ Main Office Womens Restroom Sink 308									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 06:42	03/22/24	DST	
4031402-05	Sample Location: 22070500-005SF/ Conference Room 316 / Staff Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 06:43	03/22/24	DST	
4031402-06	Sample Location: 22070500-012KF/ Classroom #107 North Left Sink 221 / Kitchen Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 06:58	03/22/24	DST	
4031402-07	Sample Location: 22070500-013KF/ Classroom #107 North Middle Sink 221 / Classroom Sink-2									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 06:59	03/22/24	DST	
4031402-08	Sample Location: 22070500-014KF/ Classroom #107 North Right Sink 221 / Classroom Sink-3									
Lead (‡)		1030	2.4	ppb	1.0	15	03/08/24 06:59	03/22/24	DST	
4031402-09	Sample Location: 22070500-015KF/ Classroom #107 South Left Sink 221 / Classroom Sink-4									
Lead (‡)		1030	2.1	ppb	1.0	15	03/08/24 07:00	03/22/24	DST	
4031402-10	Sample Location: 22070500-016KF/ Classroom #107 South Middle Sink 221 / Classroom Sink-5									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:01	03/22/24	DST	
4031402-11	Sample Location: 22070500-017KF/ Classroom #107 South Right Sink 221 / Classroom Sink-6									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:02	03/22/24	DST	
4031402-12	Sample Location: 22070500-018WB/ Building 4 Hallway 1st Floor 229 / Water Bottle Filler									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:04	03/22/24	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4031402

Method: USEPA 200.8


Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
4031402-13	Sample Location: 22070500-019DW/ Building 4 Hallway 1st Floor 229 / Drinking Fountain									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:04	03/22/24	DST	
4031402-14	Sample Location: 22070500-020BF/ Classroom #111B Restroom Sink 224									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:08	03/22/24	DST	
4031402-15	Sample Location: 22070500-021KF/ Classroom #111B Kitchen Sink 227									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:08	03/22/24	DST	
4031402-16	Sample Location: 22070500-022BF/ Boys 1st Floor Sink By Life Skills Classroom 203 / Restroom Sink									
Lead (‡)		1030	1.4	ppb	1.0	15	03/08/24 07:12	03/22/24	DST	
4031402-17	Sample Location: 22070500-023BF/ Girls 1st Floor Sink By Life Skills Classroom 204 / Restroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:10	03/22/24	DST	
4031402-18	Sample Location: 22070500-024CF/ Classroom #108 Sink 208 / Classroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:17	03/22/24	DST	
4031402-19	Sample Location: 22070500-025CF/ Classroom #104 Sink 210 / Classroom Sink									
Lead (‡)		1030	1.6	ppb	1.0	15	03/08/24 06:53	03/22/24	DST	
4031402-20	Sample Location: 22070500-026SF/ Staff Work Room Sink 211 / Staff Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 06:51	03/22/24	DST	
4031402-21	Sample Location: 22070500-027BF/ Staff Lounge 212 / Mens Restroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 06:54	03/22/24	DST	
4031402-22	Sample Location: 22070500-028BF/ Staff Lounge 213 / Womens Restroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 06:50	03/22/24	DST	
4031402-23	Sample Location: 22070500-029SF/ Staff Lounge Sink-Room #100 302 / Staff Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 06:45	03/22/24	DST	
4031402-24	Sample Location: 22070500-030NS/ Main Office Health Room Sink 312									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:29	03/22/24	DST	
4031402-25	Sample Location: 22070500-031BF/ Main Office Health Room 311 / Restroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:20	03/22/24	DST	
4031402-26	Sample Location: 22070500-032BF/ Girls Restroom-Commons Left Sink 704 / Restroom Sink-1									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:21	03/22/24	DST	
4031402-27	Sample Location: 22070500-033BF/ Girls Restroom-Commons Right Sink 704 / Restroom Sink-2									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.



Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4031402

Method: USEPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:22	03/22/24	DST	
4031402-28	Sample Location: 22070500-034WB/ Commons Bottle Filler 701 / Water Bottle Filler									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:22	03/22/24	DST	
4031402-29	Sample Location: 22070500-035DW/ Commons Drinking Fountain 701									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:23	03/22/24	DST	
4031402-30	Sample Location: 22070500-036BF/ Boys Restroom-Commons Left Sink 705 / Restroom Sink-1									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:24	03/22/24	DST	
4031402-31	Sample Location: 22070500-037BF/ Boys Restroom-Commons Right Sink 705 / Restroom Sink-2									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:24	03/22/24	DST	
4031402-32	Sample Location: 22070500-038KF/ Kitchen Back Counter East Sink 721 / Kitchen Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:30	03/22/24	DST	
4031402-33	Sample Location: 22070500-039KF/ Kitchen-West Sink 723 / Kitchen Sink									
Lead (‡)		1030	1.3	ppb	1.0	15	03/08/24 07:31	03/22/24	DST	
4031402-34	Sample Location: 22070500-040IM/ Kitchen-West Ice Machine 723									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:37	03/22/24	DST	
4031402-35	Sample Location: 22070500-041BF/ Nurses Hall Restroom (RM#255) 709 / Restroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:38	03/22/24	DST	
4031402-36	Sample Location: 22070500-042BF/ Nurses Hall Staff Restroom (RM#255) 708 / Restroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:38	03/22/24	DST	
4031402-37	Sample Location: 22070500-043WB/ Nurses Room (RM#256) 712B / Water Cooler									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:39	03/22/24	DST	
4031402-38	Sample Location: 22070500-044SF/ Counseling Conference Room 606A / Staff Sink									
Lead (‡)		1030	1.0	ppb	1.0	15	03/08/24 07:42	03/22/24	DST	
4031402-39	Sample Location: 22070500-045CF/ Classroom #247 Journal 601 / Classroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:43	03/22/24	DST	
4031402-40	Sample Location: 22070500-047SF/ Work Room #236 520A / Staff Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:50	03/22/24	DST	
4031402-41	Sample Location: 22070500-048BF/ Boys Restrm 2nd Floor-4 Corners Sink 513 / Restroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:45	03/22/24	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4031402

Method: USEPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
4031402-42	Sample Location: 22070500-049DW/ 2nd Floor 4 Corners Drinking Fountain 511									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:47	03/22/24	DST	
4031402-43	Sample Location: 22070500-050WB/ 2nd Floor 4 Corners Water Bottle Filler 511									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 07:47	03/22/24	DST	
4031402-44	Sample Location: 22070500-052BF/ Girls Restrm 2nd Floor-Warberg Sink 531 / Restroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 08:34	03/22/24	DST	
4031402-45	Sample Location: 22070500-053CF/ Classroom #211 Sink 536 / Classroom Sink									
Lead (‡)		1030	1.1	ppb	1.0	15	03/08/24 08:26	03/22/24	DST	
4031402-46	Sample Location: 22070500-054KF/ Student Store Buck Stop Sink 545									
Lead (‡)		1030	1.2	ppb	1.0	15	03/08/24 08:29	03/22/24	DST	
4031402-47	Sample Location: 22070500-055SF/ Library Workroom Sink 625 / Staff Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 08:31	03/22/24	DST	
4031402-48	Sample Location: 22070500-083CF/ Biology Prep Room North East-3rd Floor Main Bld Sink 907A / Classroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 08:49	03/22/24	DST	
4031402-49	Sample Location: 22070500-084CF/ Biology Prep Room North West-3rd Floor Main Bldg Sink 905 / Classroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 08:47	03/22/24	DST	
4031402-50	Sample Location: 22070500-085OT/ Greenhouse-Science Behind NW Biology Prep Room-3rd Floor 904 / Greenhouse									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 08:52	03/22/24	DST	
4031402-51	Sample Location: 22070500-086BF/ Boys Restrm 3rd Floor West Side Of Bldg 929 / Restroom Sink									
Lead (‡)		1030	1.5	ppb	1.0	15	03/08/24 08:44	03/22/24	DST	
4031402-52	Sample Location: 22070500-087BF/ Boys Restrm 3rd Floor East Side Of Bldg 912 / Restroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 08:43	03/22/24	DST	
4031402-53	Sample Location: 22070500-088BF/ Girls Restrm 3rd Floor East Side Of Bldg 913 / Restroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 08:35	03/22/24	DST	
4031402-54	Sample Location: 22070500-089BF/ Girls Restrm 3rd Floor West Side Of Bldg 930 / Restroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 08:42	03/22/24	DST	
4031402-55	Sample Location: 22070500-090CF/ Science Prep Room South West-3rd Floor Main Bdg Sink 936 / Classroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 08:39	03/22/24	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4031402

Method: USEPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
4031402-56	Sample Location: 22070500-091CF/ Science Prep Room South East-3rd Floor Main Bdg Sink 940 / Classroom Sink									
Lead (‡)	1030	ND	ppb	1.0	15	03/08/24 08:38	03/22/24	DST		
4031402-57	Sample Location: 22070500-092WB/ East Corridor 3rd Floor Main Bdg 910 / Water Bottle Filler									
Lead (‡)	1030	ND	ppb	1.0	15	03/08/24 08:55	03/22/24	DST		
4031402-58	Sample Location: 22070500-093DW/ East Corridor 3rd Floor Main Bdg 910 / Drinking Fountain									
Lead (‡)	1030	ND	ppb	1.0	15	03/08/24 08:56	03/22/24	DST		
4031402-59	Sample Location: 22070500-094WB/ West Corridor 3rd Floor Main Bdg / Water Bottle Filler									
Lead (‡)	1030	ND	ppb	1.0	15	03/08/24 08:43	03/22/24	DST		
4031402-60	Sample Location: 22070500-095BF/ Building 4 Boys Restroom Left Sink 121 / Classroom Sink-1									
Lead (‡)	1030	ND	ppb	1.0	15	03/08/24 09:00	03/22/24	DST		
4031402-61	Sample Location: 22070500-096BF/ Building 4 Boys Restroom Right Sink 121 / Classroom Sink-2									
Lead (‡)	1030	2.4	ppb	1.0	15	03/08/24 09:00	03/22/24	DST		
4031402-62	Sample Location: 22070500-097DW/ Building 4 Corridor Drinking Fountain 114									
Lead (‡)	1030	ND	ppb	1.0	15	03/08/24 09:04	03/22/24	DST		
4031402-63	Sample Location: 22070500-098WB/ Building 4 Corridor Bottle Filler 114									
Lead (‡)	1030	ND	ppb	1.0	15	03/08/24 09:05	03/22/24	DST		
4031402-64	Sample Location: 22070500-099BF/ Building 4 Girls Restroom Left Sink 118 / Classroom Sink-1									
Lead (‡)	1030	ND	ppb	1.0	15	03/08/24 09:08	03/22/24	DST		
4031402-65	Sample Location: 22070500-100BF/ Building 4 Girls Restroom Right Sink 118 / Classroom Sink-2									
Lead (‡)	1030	ND	ppb	1.0	15	03/08/24 09:08	03/22/24	DST		
4031402-66	Sample Location: 22070500-101CF/ Classroom #416 Left Sink 108 / Classroom Sink-1									
Lead (‡)	1030	23.9	ppb	1.0	15	03/08/24 09:12	03/22/24	DST		
4031402-67	Sample Location: 22070500-102CF/ Classroom #416 Right Sink 108 / Classroom Sink-2									
Lead (‡)	1030	4.7	ppb	1.0	15	03/08/24 09:12	03/22/24	DST		
4031402-68	Sample Location: 22070500-103OT/ Greenhouse Bld 4 - Sink 107									
Lead (‡)	1030	ND	ppb	1.0	15	03/08/24 09:13	03/22/24	DST		
4031402-69	Sample Location: 22070500-104CF/ Greenhouse Prep Classroom #416A Sink 105 / Classroom Sink									
Lead (‡)	1030	6.2	ppb	1.0	15	03/08/24 09:13	03/22/24	DST		
4031402-70	Sample Location: 22070500-105KF/ Warberg Concessions Sink 424 / Kitchen Sink									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4031402

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 09:55	03/22/24	DST	
4031402-71	Sample Location: 22070500-106BF/ Warberg Girls Locker Room 407 / Restroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 08:09	03/22/24	DST	
4031402-72	Sample Location: 22070500-107BF/ Warberg Girls Locker Rm 408 / Office Restroom Sink									
Lead (‡)		1030	3.2	ppb	1.0	15	03/08/24 08:09	03/22/24	DST	
4031402-73	Sample Location: 22070500-108NS/ Warberg Sports Trainer Office Sink 410A / Training Room Sink									
Lead (‡)		1030	1.1	ppb	1.0	15	03/08/24 08:10	03/22/24	DST	
4031402-74	Sample Location: 22070500-109BF/ Warberg Boys Locker Rm 421 / Office Restroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 08:05	03/22/24	DST	
4031402-75	Sample Location: 22070500-110BF/ Warberg Boys Locker Room 422 / Restroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 08:03	03/22/24	DST	
4031402-76	Sample Location: 22070500-111WB/ West Warberg Gym 431 / Water Bottle Filler									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 08:22	03/22/24	DST	
4031402-77	Sample Location: 22070500-112DW/ East Warberg Gym 431 / Drinking Fountain-2									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 08:00	03/22/24	DST	
4031402-78	Sample Location: 22070500-113WB/ East Warberg Gym 431 / Water Bottle Filler									
Lead (‡)		1030	ND	ppb	1.0	15	03/08/24 08:00	03/22/24	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 3120104

Pendleton School District	Project: General	Date Reported: 12/07/23
107 NW 10th Street	Project #: Pendleton High School	Date Received: 12/01/23 10:35
Pendleton, OR 97801	Client Contact: Michelle Jones	Sampled By: Michelle Jones

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualification
3120104-02	Sample Location: Pendleton HS 051BF									
	Lead (†)	1030	ND	ppb	1.0	15	11/14/23 07:00	12/04/23	DST	
3120104-03	Sample Location: Pendleton HS 046BF									
	Lead (†)	1030	2.0	ppb	1.0	15	11/14/23 07:05	12/04/23	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4041113

Pendleton School District 107 NW 10th Street Pendleton, OR 97801	Project: General Project #: PHS Lead Testing Client Contact: Michelle Jones	Date Reported: 04/18/24 Date Received: 04/11/24 10:15 Sampled By: B Norris
--	---	--

Method: USEPA 200.8

Matrix: Drinking Water

Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
4041113-01	Sample Location: 22070500-124NS-Health Exam Room By Counseling Office Sink / Exam Sink								
Lead (†)	1030	ND	ppb	1.0	15	04/03/24 06:07	04/15/24	DST	

UMPQUA Research Company/MC

Dan Phillips, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4031402

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager