## Lead in Water Test Results Summary: PHS Track Concessions

### Notes:

- The lead in water Action Level is 15 parts per billion (ppb).

  Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.

### Legend:

- Test results equal to or greater than the Action Level of 15 ppb are highlighted in red and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results near the Action Level of 15 ppb (11.99 to 14.99 ppb) are highlighted in yellow and precede a "Med" (Medium) value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
FOOTBALL FIELD OUTSIDE SPIGOT	22070503-114OS	4/3/2024	ND	Low	[enter date]	[enter result]	[autofill]
TRACK CONCESSION WOMANS RESTROOM	22070503-115BF	4/3/2024	ND	Low			
TRACK CONCESSION MENS RESTROOM SINK	22070503-116BF	4/3/2024	ND	Low			
TRACK CONCESSION KITCHEN SINK	22070503-117KF	4/3/2024	ND	Low			



# **UMPQUA** Research Company

626 NE Division St. - P.O. Box 609 Myrtle Creek, Oregon 97457 (541) 863-5201 Fax: (541) 863-6199 E-mail: Lab@URCmail.net

Internet: http://ChemLab.cc ORELAP ID# OR100031

Project: General

Date Reported:

04/16/24

ANALYSIS REPORT

107 NW 10th Street Pendleton, OR 97801

Pendleton School District

Project #: PHS Track Concessions Lead Testing

Date Received: 04/11/24 10:15

4041112

Sampled By: T. Baum

**URC**#

Client Contact: Michelle Jones

Method: USEPA 200.8							Matrix: Drinking Water					
	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst Qualif	fier		
4041112-01	Sample Location: 22070503-114OS-Football Field / Outside Spigot											
Lead (‡)		1030	ND	ppb	1.0	15	04/03/24 06:15	04/15/24	DST			
4041112-02	Sample Location: 22070503-115BF-Track Concession Womans Restroom / Sink-1											
Lead (‡)		1030	ND	ppb	1.0	15	04/03/24 06:08	04/15/24	DST			
4041112-03	Sample Location: 22070503-116BF-Track Concession Mens Restroom / Sink-2											
Lead (‡)		1030	ND	ppb	1.0	15	04/03/24 06:05	04/15/24	DST			
4041112-04	4041112-04 Sample Location: 22070503-117KF-Track Concession Kitchen Sink / Sink-3											
Lead (‡)		1030	ND	ppb	1.0	15	04/03/24 06:10	04/15/24	DST			

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



## **UMPQUA** Research Company

626 NE Division St. - P.O. Box 609 Myrtle Creek, Oregon 97457 (541) 863-5201 Fax: (541) 863-6199

E-mail: Lab@URCmail.net Internet: http://ChemLab.cc ORELAP ID# OR100031 ANALYSIS REPORT URC # 4041112

### **Qualifiers and Definitions**

DET Analyte DETECTED

ND Analyte NOT DETECTED at or above the MRL (minimum reporting limit)

NA Not Applicable

NR Not Reported

dry Sample results reported on a dry weight basis

RPD Relative Percent Difference

MRL Minimum Reporting Limit

MDL Minimum Detection Limit

MCL Maximum Contamination Level

(‡) ORELAP Accredited Analyte

(~) Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager