



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4031331

Pendleton School District	Project: General	Date Reported: 03/21/24
107 NW 10th Street	Project #: District Office Lead Testing	Date Received: 03/13/24 11:00
Pendleton, OR 97801	Client Contact: Michelle Jones	Sampled By: Thad Baum

Method: USEPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
4031331-01	Sample Location: 22070000-001SF / Conference Room 228 / Staff Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:36	03/20/24	DST	
4031331-02	Sample Location: 22070000-002DW/ Conference Room 228 / Drinking Fountain									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:36	03/20/24	DST	
4031331-03	Sample Location: 22070000-003SF/ Board Room 226 / Staff Sink									
Lead (‡)		1030	1.1	ppb	1.0	15	03/06/24 06:37	03/20/24	DST	
4031331-04	Sample Location: 22070000-004DW/ North Hallway 227 / Drinking Fountain									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:38	03/20/24	DST	
4031331-05	Sample Location: 22070000-005WB/ North Hallway 227 / Water Bottle Filler									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:38	03/20/24	DST	
4031331-06	Sample Location: 22070000-006BF/ North Men's Restroom 224 / Bathroom Sink #1									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:39	03/20/24	DST	
4031331-07	Sample Location: 22070000-007BF/ North Men's Restroom 224 / Bathroom Sink #2									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:39	03/20/24	DST	
4031331-08	Sample Location: 22070000-008BF/ Main Co-ed Restroom 204 / Bathroom Sink									
Lead (‡)		1030	6.7	ppb	1.0	15	03/06/24 06:40	03/20/24	DST	
4031331-09	Sample Location: 22070000-009BF/ Staff Breakroom Restroom 207 / Bathroom Sink Cold									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:41	03/20/24	DST	
4031331-10	Sample Location: 22070000-010WC/ Staff Breakroom 206 / Water Cooler									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:42	03/20/24	DST	
4031331-11	Sample Location: 22070000-011SF/ Staff Breakroom 206 / Staff Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:43	03/20/24	DST	
4031331-12	Sample Location: 22070000-012SF/ Fingerprinting Room 218 / Staff Sink									
Lead (‡)		1030	1.2	ppb	1.0	15	03/06/24 06:44	03/20/24	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4031331

Method: USEPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
4031331-13	Sample Location: 22070000-013BF/ West Women's Restroom 216 / Bathroom Sink #1									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:45	03/20/24	DST	
4031331-14	Sample Location: 22070000-014BF/ West Women's Restroom 216 / Bathroom Sink #2									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:45	03/20/24	DST	
4031331-15	Sample Location: 22070000-015BF/ Maintenance Restroom 244 / Bathroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:47	03/20/24	DST	
4031331-16	Sample Location: 22070000-016SF/ Maintenance Breakroom 243 / Staff Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:48	03/20/24	DST	
4031331-17	Sample Location: 22070000-017WC/ Maintenance Breakroom 243 / Water Cooler									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:48	03/20/24	DST	
4031331-18	Sample Location: 22070000-018IM/ Maintenance Shop 130 / Ice Machine									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:49	03/20/24	DST	
4031331-19	Sample Location: 22070000-019SF/ Maintenance Shop 130 / Staff Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:49	03/20/24	DST	
4031331-20	Sample Location: 22070000-020BF/ 106 Boy's Restroom-Downstairs / Bathroom Sink #1									
Lead (‡)		1030	2.2	ppb	1.0	15	03/06/24 06:51	03/20/24	DST	
4031331-21	Sample Location: 22070000-021BF/ 106 Boy's Restroom-Downstairs / Bathroom Sink #2									
Lead (‡)		1030	8.2	ppb	1.0	15	03/06/24 06:51	03/20/24	DST	
4031331-22	Sample Location: 22070000-022BF/ 108 Girl's Restroom-Downstairs / Bathroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:52	03/20/24	DST	
4031331-23	Sample Location: 22070000-023BF/ Staff Breakroom Restroom 207 / Bathroom Sink Hot									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 06:41	03/20/24	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4031331

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager