

## Lead in Water Test Results Summary: Pendleton High School Main Bldg

**Notes:**

- The lead in water **Action Level is 15 parts per billion (ppb)**.  
*Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.*
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.

**Legend:**

- Test results equal to or greater than the Action Level of 15 ppb are highlighted in red and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results near the Action Level of 15 ppb (11.99 to 14.99 ppb) are highlighted in yellow and precede a "Med" (Medium) value in the "Initial Level" or "Final Level" column.

| Fixture Location Description             | Fixture ID #   | Initial Test Date | Initial Test Result (ppb) | Initial Level | Final Retest Date | Final Test Result (ppb) | Final Level |
|--|----------------|-------------------|---------------------------|---------------|-------------------|-------------------------|-------------|
| MAIN OFFICE MENS RESTROOM SINK           | 22070500-001BF | 3/8/2024          | ND                        | Low           | [enter date]      | [enter result]          | [autofill]  |
| MAIN OFFICE DRINKING-TALL DRINKING       | 22070500-002DW | 3/8/2024          | ND                        | Low           |                   |                         |             |
| MAIN OFFICE DRINKING-SHORT DRINKING      | 22070500-003DW | 3/8/2024          | ND                        | Low           |                   |                         |             |
| MAIN OFFICE WOMENS RESTROOM SINK         | 22070500-004BF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| CONFERENCE ROOM SINK                     | 22070500-005SF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| CLASSROOM #107 NORTH LEFT SINK           | 22070500-012KF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| CLASSROOM #107 NORTH MIDDLE SINK         | 22070500-013KF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| CLASSROOM #107 NORTH RIGHT SING          | 22070500-014KF | 3/8/2024          | 2.4                       | Low           |                   |                         |             |
| CLASSROOM #107 SOUTH LEFT SINK           | 22070500-015KF | 3/8/2024          | 2.1                       | Low           |                   |                         |             |
| CLASSROOM #107 SOUTH MIDDLE SINK         | 22070500-016KF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| CLASSROOM #107 SOUTH RIGHT SINK          | 22070500-017KF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| BUILDING 4 HALLWAY 1ST FLOOR BOTTLE      | 22070500-018WB | 3/8/2024          | ND                        | Low           |                   |                         |             |
| BUILDING 4 HALLWAY 1ST FLOOR DRINKING    | 22070500-019DW | 3/8/2024          | ND                        | Low           |                   |                         |             |
| CLASSROOM #111B RESTROOM SINK            | 22070500-020BF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| CLASSROOM #111B KITCHEN SINK             | 22070500-021KF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| BOYS 1ST FLOOR SINK BY LIFE SKILLS       | 22070500-022BF | 3/8/2024          | 1.4                       | Low           |                   |                         |             |
| GIRLS 1ST FLOOR SINK BY LIFE SKILLS      | 22070500-023BF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| CLASSROOM #108 SINK                      | 22070500-024CF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| CLASSROOM #104 SINK                      | 22070500-025CF | 3/8/2024          | 1.6                       | Low           |                   |                         |             |
| STAFF WORK ROOM SINK                     | 22070500-026SF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| STAFF LOUNGE MENS RESTROOM SINK          | 22070500-027BF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| STAFF LOUNGE WOMENS RESTROOM SINK        | 22070500-028BF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| STAFF LOUNGE SINK-ROOM #100              | 22070500-029SF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| MAIN OFFICE HEALTH ROOM SINK             | 22070500-030NS | 3/8/2024          | ND                        | Low           |                   |                         |             |
| MAIN OFFICE HEALTH ROOM RESTROOM SINK    | 22070500-031BF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| GIRLS RESTROOM-COMMONS LEFT SINK         | 22070500-032BF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| GIRLS RESTROOM-COMMONS RIGHT SINK        | 22070500-033BF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| COMMONS BOTTLE FILLER                    | 22070500-034WB | 3/8/2024          | ND                        | Low           |                   |                         |             |
| COMMONS DRINKING FOUNTAIN                | 22070500-035DW | 3/8/2024          | ND                        | Low           |                   |                         |             |
| BOYS RESTROOM-COMMONS LEFT SINK          | 22070500-036BF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| BOYS RESTROOM-COMMONS RIGHT SINK         | 22070500-037BF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| KITCHEN BACK COUNTER EAST SINK           | 22070500-038KF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| KITCHEN -WEST SINK                       | 22070500-039KF | 3/8/2024          | 1.3                       | Low           |                   |                         |             |
| KITCHEN -WEST ICE MACHINE                | 22070500-040IM | 3/8/2024          | ND                        | Low           |                   |                         |             |
| NURSES HALL RESTROOM (RM#255) SINK       | 22070500-041BF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| NURSES HALL STAFF RESTROOM (RM#255) SINK | 22070500-042BF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| NURSES ROOM (RM#256) WATER COOLER        | 22070500-043WB | 3/8/2024          | ND                        | Low           |                   |                         |             |
| COUNSELING CONFERENCE ROOM SINK          | 22070500-044SF | 3/8/2024          | 1                         | Low           |                   |                         |             |
| BOYS RESTRM 2ND FLOOR-WARBERG SINK       | 22070500-046BF | 11/14/2023        | 2                         | Low           |                   |                         |             |
| CLASSROOM #247 SINK                      | 22070500-045CF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| WORK ROOM # 236 SINK                     | 22070500-047SF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| BOYS RESTRM 2ND FLOOR-4 CORNERS SINK     | 22070500-048BF | 3/8/2024          | ND                        | Low           |                   |                         |             |
| 2ND FLOOR 4 CORNERS DRINKING FOUNTAIN    | 22070500-049DW | 3/8/2024          | ND                        | Low           |                   |                         |             |
| 2ND FLOOR 4 CORNERS BOTTLE FILLER        | 22070500-050WB | 3/8/2024          | ND                        | Low           |                   |                         |             |
| GIRLS RESTRM 2ND FLOOR-BUCK STOP SINK    | 22070500-051BF | 11/14/2023        | ND                        | Low           |                   |                         |             |
| GIRLS RESTRM 2ND FLOOR-WARBERG SINK      | 22070500-052BF | 3/8/2024          | ND                        | Low           |                   |                         |             |

|  |                |          |      |      |
|--|----------------|----------|------|------|
| CLASSROOM #211 SINK                                  | 22070500-053CF | 3/8/2024 | 1.1  | Low  |
| STUDENT STORE BUCK STOP SINK                         | 22070500-054KF | 3/8/2024 | 1.2  | Low  |
| LIBRARY WORKROOM SINK                                | 22070500-0555F | 3/8/2024 | ND   | Low  |
| BIOLOGY PREP ROOM NORTH EAST-3RD                     | 22070500-083CF | 3/8/2024 | ND   | Low  |
| BIOLOGY PREP ROOM NORTH WEST-3RD                     | 22070500-084CF | 3/8/2024 | ND   | Low  |
| GREENHOUSE-SCIENCE BEHIND NW                         | 22070500-085OT | 3/8/2024 | ND   | Low  |
| BOYS RESTRM 3RD FLOOR WEST SIDE OF BLDG SINK         | 22070500-086BF | 3/8/2024 | 1.5  | Low  |
| BOYS RESTRM 3RD FLOOR EAST SIDE OF BLDG SINK         | 22070500-087BF | 3/8/2024 | ND   | Low  |
| GIRLS RESTRM 3RD FLOOR EAST SIDE OF BLDG SINK        | 22070500-088BF | 3/8/2024 | ND   | Low  |
| GIRLS RESTRM 3RD FLOOR WEST SIDE OF BLDG SINK        | 22070500-089BF | 3/8/2024 | ND   | Low  |
| SCIENCE PREP ROOM SOUTH WEST-3RD FLOOR MAIN BDG SINK | 22070500-090CF | 3/8/2024 | ND   | Low  |
| SCIENCE PREP ROOM SOUTH EAST-3RD FLOOR MAIN BDG SINK | 22070500-091CF | 3/8/2024 | ND   | Low  |
| EAST CORRIDOR 3RD FLOOR MAIN BDG BOTTLE FILLER       | 22070500-092WB | 3/8/2024 | ND   | Low  |
| EAST CORRIDOR 3RD FLOOR MAIN BDG DRINKING FOUNTAIN   | 22070500-093DW | 3/8/2024 | ND   | Low  |
| WEST CORRIDOR 3RD FLOOR MAIN BDG BOTTLE FILLER       | 22070500-094WB | 3/8/2024 | ND   | Low  |
| BUILDING 4 BOYS RESTROOM LEFT SINK                   | 22070500-095BF | 3/8/2024 | ND   | Low  |
| BUILDING 4 BOYS RESTROOM RIGHT SINK                  | 22070500-096BF | 3/8/2024 | 2.4  | Low  |
| BUILDING 4 CORRIDOR DRINKING FOUNTAIN                | 22070500-097DW | 3/8/2024 | ND   | Low  |
| BUILDING 4 CORRIDOR BOTTLE FILLER                    | 22070500-098WB | 3/8/2024 | ND   | Low  |
| BUILDING 4 GIRLS RESTROOM LEFT SINK                  | 22070500-099BF | 3/8/2024 | ND   | Low  |
| BUILDING 4 GIRLS RESTROOM RIGHT SINK                 | 22070500-100BF | 3/8/2024 | ND   | Low  |
| CLASSROOM #416 LEFT SINK                             | 22070500-101CF | 3/8/2024 | 23.9 | High |
| CLASSROOM #416 RIGHT SINK                            | 22070500-102CF | 3/8/2024 | 4.7  | Low  |
| GREENHOUSE BLD 4 - SINK                              | 22070500-103OT | 3/8/2024 | ND   | Low  |
| GREENHOUSE PREP CLASSROOM #416A SINK                 | 22070500-104CF | 3/8/2024 | 6.2  | Low  |
| WARBERG CONCESSIONS SINK                             | 22070500-105KF | 3/8/2024 | ND   | Low  |
| WARBERG GIRLS LOCKER ROOM RESTROOM SINK              | 22070500-106BF | 3/8/2024 | ND   | Low  |
| WARBERG GIRLS LOCKER RM-OFFICE RESTROOM SINK         | 22070500-107BF | 3/8/2024 | 3.2  | Low  |
| WARBERG SPORTS TRAINER OFFICE SINK                   | 22070500-108NS | 3/8/2024 | 1.1  | Low  |
| WARBERG BOYS LOCKER RM-OFFICE RESTROOM SINK          | 22070500-109BF | 3/8/2024 | ND   | Low  |
| WARBERG BOYS LOCKER ROOM RESTROOM SINK               | 22070500-110BF | 3/8/2024 | ND   | Low  |
| WEST WARBERG GYM BOTTLE FILLER                       | 22070500-111WB | 3/8/2024 | ND   | Low  |
| EAST WARBERG GYM DRINKING FOUNTAIN                   | 22070500-112DW | 3/8/2024 | ND   | Low  |
| EAST WARBERG GYM BOTTLE FILLER                       | 22070500-113WB | 3/8/2024 | ND   | Low  |



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 4031402

|                           |                                |                               |
|---------------------------|--------------------------------|-------------------------------|
| Pendleton School District | Project: General               | Date Reported: 03/26/24       |
| 107 NW 10th Street        | Project #: PHS Lead Testing    | Date Received: 03/13/24 11:00 |
| Pendleton, OR 97801       | Client Contact: Michelle Jones | Sampled By: Thad Baum         |

Method: USEPA 200.8

Matrix: Drinking Water


|            | Sample Location  | Code | Result | Units | MRL | MCL | Sampled        | Analyzed | Analyst | Qualifier |
|------------|--|------|--------|-------|-----|-----|----------------|----------|---------|-----------|
| 4031402-01 | Sample Location: 22070500-001BF/ Main Office Mens Restroom Sink 307                      |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 06:41 | 03/22/24 | DST     |           |
| 4031402-02 | Sample Location: 22070500-002DW/ Main Office Drinking-Tall Drinking Fountain 315         |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 06:41 | 03/22/24 | DST     |           |
| 4031402-03 | Sample Location: 22070500-003DW/ Main Office Drinking-Short Drinking Fountain 315        |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 06:42 | 03/22/24 | DST     |           |
| 4031402-04 | Sample Location: 22070500-004BF/ Main Office Womens Restroom Sink 308                    |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 06:42 | 03/22/24 | DST     |           |
| 4031402-05 | Sample Location: 22070500-005SF/ Conference Room 316 / Staff Sink                        |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 06:43 | 03/22/24 | DST     |           |
| 4031402-06 | Sample Location: 22070500-012KF/ Classroom #107 North Left Sink 221 / Kitchen Sink       |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 06:58 | 03/22/24 | DST     |           |
| 4031402-07 | Sample Location: 22070500-013KF/ Classroom #107 North Middle Sink 221 / Classroom Sink-2 |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 06:59 | 03/22/24 | DST     |           |
| 4031402-08 | Sample Location: 22070500-014KF/ Classroom #107 North Right Sink 221 / Classroom Sink-3  |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | 2.4    | ppb   | 1.0 | 15  | 03/08/24 06:59 | 03/22/24 | DST     |           |
| 4031402-09 | Sample Location: 22070500-015KF/ Classroom #107 South Left Sink 221 / Classroom Sink-4   |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | 2.1    | ppb   | 1.0 | 15  | 03/08/24 07:00 | 03/22/24 | DST     |           |
| 4031402-10 | Sample Location: 22070500-016KF/ Classroom #107 South Middle Sink 221 / Classroom Sink-5 |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 07:01 | 03/22/24 | DST     |           |
| 4031402-11 | Sample Location: 22070500-017KF/ Classroom #107 South Right Sink 221 / Classroom Sink-6  |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 07:02 | 03/22/24 | DST     |           |
| 4031402-12 | Sample Location: 22070500-018WB/ Building 4 Hallway 1st Floor 229 / Water Bottle Filler  |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 07:04 | 03/22/24 | DST     |           |

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 4031402

Method: USEPA 200.8

Matrix: Drinking Water

|            | Sample Location  | Code | Result | Units | MRL | MCL | Sampled        | Analyzed | Analyst | Qualifier |
|------------|--|------|--------|-------|-----|-----|----------------|----------|---------|-----------|
| 4031402-13 | Sample Location: 22070500-019DW/ Building 4 Hallway 1st Floor 229 / Drinking Fountain              |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 07:04 | 03/22/24 | DST     |           |
| 4031402-14 | Sample Location: 22070500-020BF/ Classroom #111B Restroom Sink 224                                 |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 07:08 | 03/22/24 | DST     |           |
| 4031402-15 | Sample Location: 22070500-021KF/ Classroom #111B Kitchen Sink 227                                  |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 07:08 | 03/22/24 | DST     |           |
| 4031402-16 | Sample Location: 22070500-022BF/ Boys 1st Floor Sink By Life Skills Classroom 203 / Restroom Sink  |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | 1.4    | ppb   | 1.0 | 15  | 03/08/24 07:12 | 03/22/24 | DST     |           |
| 4031402-17 | Sample Location: 22070500-023BF/ Girls 1st Floor Sink By Life Skills Classroom 204 / Restroom Sink |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 07:10 | 03/22/24 | DST     |           |
| 4031402-18 | Sample Location: 22070500-024CF/ Classroom #108 Sink 208 / Classroom Sink                          |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 07:17 | 03/22/24 | DST     |           |
| 4031402-19 | Sample Location: 22070500-025CF/ Classroom #104 Sink 210 / Classroom Sink                          |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | 1.6    | ppb   | 1.0 | 15  | 03/08/24 06:53 | 03/22/24 | DST     |           |
| 4031402-20 | Sample Location: 22070500-026SF/ Staff Work Room Sink 211 / Staff Sink                             |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 06:51 | 03/22/24 | DST     |           |
| 4031402-21 | Sample Location: 22070500-027BF/ Staff Lounge 212 / Mens Restroom Sink                             |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 06:54 | 03/22/24 | DST     |           |
| 4031402-22 | Sample Location: 22070500-028BF/ Staff Lounge 213 / Womens Restroom Sink                           |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 06:50 | 03/22/24 | DST     |           |
| 4031402-23 | Sample Location: 22070500-029SF/ Staff Lounge Sink-Room #100 302 / Staff Sink                      |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 06:45 | 03/22/24 | DST     |           |
| 4031402-24 | Sample Location: 22070500-030NS/ Main Office Health Room Sink 312                                  |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 07:29 | 03/22/24 | DST     |           |
| 4031402-25 | Sample Location: 22070500-031BF/ Main Office Health Room 311 / Restroom Sink                       |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 07:20 | 03/22/24 | DST     |           |
| 4031402-26 | Sample Location: 22070500-032BF/ Girls Restroom-Commons Left Sink 704 / Restroom Sink-1            |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 07:21 | 03/22/24 | DST     |           |
| 4031402-27 | Sample Location: 22070500-033BF/ Girls Restroom-Commons Right Sink 704 / Restroom Sink-2           |      |        |       |     |     |                |          |         |           |

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 4031402

Method: USEPA 200.8

Matrix: Drinking Water


| Sample Location | Code  | Result | Units | MRL | MCL | Sampled        | Analyzed | Analyst | Qualifier |
|-----------------|---|--------|-------|-----|-----|----------------|----------|---------|-----------|
| Lead (‡)        | 1030  | ND     | ppb   | 1.0 | 15  | 03/08/24 07:22 | 03/22/24 | DST     |           |
| 4031402-28      | Sample Location: 22070500-034WB/ Commons Bottle Filler 701 / Water Bottle Filler          |        |       |     |     |                |          |         |           |
| Lead (‡)        | 1030  | ND     | ppb   | 1.0 | 15  | 03/08/24 07:22 | 03/22/24 | DST     |           |
| 4031402-29      | Sample Location: 22070500-035DW/ Commons Drinking Fountain 701                            |        |       |     |     |                |          |         |           |
| Lead (‡)        | 1030  | ND     | ppb   | 1.0 | 15  | 03/08/24 07:23 | 03/22/24 | DST     |           |
| 4031402-30      | Sample Location: 22070500-036BF/ Boys Restroom-Commons Left Sink 705 / Restroom Sink-1    |        |       |     |     |                |          |         |           |
| Lead (‡)        | 1030  | ND     | ppb   | 1.0 | 15  | 03/08/24 07:24 | 03/22/24 | DST     |           |
| 4031402-31      | Sample Location: 22070500-037BF/ Boys Restroom-Commons Right Sink 705 / Restroom Sink-2   |        |       |     |     |                |          |         |           |
| Lead (‡)        | 1030  | ND     | ppb   | 1.0 | 15  | 03/08/24 07:24 | 03/22/24 | DST     |           |
| 4031402-32      | Sample Location: 22070500-038KF/ Kitchen Back Counter East Sink 721 / Kitchen Sink        |        |       |     |     |                |          |         |           |
| Lead (‡)        | 1030  | ND     | ppb   | 1.0 | 15  | 03/08/24 07:30 | 03/22/24 | DST     |           |
| 4031402-33      | Sample Location: 22070500-039KF/ Kitchen-West Sink 723 / Kitchen Sink                     |        |       |     |     |                |          |         |           |
| Lead (‡)        | 1030  | 1.3    | ppb   | 1.0 | 15  | 03/08/24 07:31 | 03/22/24 | DST     |           |
| 4031402-34      | Sample Location: 22070500-040IM/ Kitchen-West Ice Machine 723                             |        |       |     |     |                |          |         |           |
| Lead (‡)        | 1030  | ND     | ppb   | 1.0 | 15  | 03/08/24 07:37 | 03/22/24 | DST     |           |
| 4031402-35      | Sample Location: 22070500-041BF/ Nurses Hall Restroom (RM#255) 709 / Restroom Sink        |        |       |     |     |                |          |         |           |
| Lead (‡)        | 1030  | ND     | ppb   | 1.0 | 15  | 03/08/24 07:38 | 03/22/24 | DST     |           |
| 4031402-36      | Sample Location: 22070500-042BF/ Nurses Hall Staff Restroom (RM#255) 708 / Restroom Sink  |        |       |     |     |                |          |         |           |
| Lead (‡)        | 1030  | ND     | ppb   | 1.0 | 15  | 03/08/24 07:38 | 03/22/24 | DST     |           |
| 4031402-37      | Sample Location: 22070500-043WB/ Nurses Room (RM#256) 712B / Water Cooler                 |        |       |     |     |                |          |         |           |
| Lead (‡)        | 1030  | ND     | ppb   | 1.0 | 15  | 03/08/24 07:39 | 03/22/24 | DST     |           |
| 4031402-38      | Sample Location: 22070500-044SF/ Counseling Conference Room 606A / Staff Sink             |        |       |     |     |                |          |         |           |
| Lead (‡)        | 1030  | 1.0    | ppb   | 1.0 | 15  | 03/08/24 07:42 | 03/22/24 | DST     |           |
| 4031402-39      | Sample Location: 22070500-045CF/ Classroom #247 Journal 601 / Classroom Sink              |        |       |     |     |                |          |         |           |
| Lead (‡)        | 1030  | ND     | ppb   | 1.0 | 15  | 03/08/24 07:43 | 03/22/24 | DST     |           |
| 4031402-40      | Sample Location: 22070500-047SF/ Work Room #236 520A / Staff Sink                         |        |       |     |     |                |          |         |           |
| Lead (‡)        | 1030  | ND     | ppb   | 1.0 | 15  | 03/08/24 07:50 | 03/22/24 | DST     |           |
| 4031402-41      | Sample Location: 22070500-048BF/ Boys Restrm 2nd Floor-4 Corners Sink 513 / Restroom Sink |        |       |     |     |                |          |         |           |
| Lead (‡)        | 1030  | ND     | ppb   | 1.0 | 15  | 03/08/24 07:45 | 03/22/24 | DST     |           |

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 4031402

Method: USEPA 200.8

Matrix: Drinking Water

|            | Sample Location   | Code | Result | Units | MRL | MCL | Sampled        | Analyzed | Analyst | Qualifier |
|------------|---|------|--------|-------|-----|-----|----------------|----------|---------|-----------|
| 4031402-42 | Sample Location: 22070500-049DW/ 2nd Floor 4 Corners Drinking Fountain 511                                  |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 07:47 | 03/22/24 | DST     |           |
| 4031402-43 | Sample Location: 22070500-050WB/ 2nd Floor 4 Corners Water Bottle Filler 511                                |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 07:47 | 03/22/24 | DST     |           |
| 4031402-44 | Sample Location: 22070500-052BF/ Girls Restrm 2nd Floor-Warberg Sink 531 / Restroom Sink                    |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:34 | 03/22/24 | DST     |           |
| 4031402-45 | Sample Location: 22070500-053CF/ Classroom #211 Sink 536 / Classroom Sink                                   |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | 1.1    | ppb   | 1.0 | 15  | 03/08/24 08:26 | 03/22/24 | DST     |           |
| 4031402-46 | Sample Location: 22070500-054KF/ Student Store Buck Stop Sink 545   |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | 1.2    | ppb   | 1.0 | 15  | 03/08/24 08:29 | 03/22/24 | DST     |           |
| 4031402-47 | Sample Location: 22070500-055SF/ Library Workroom Sink 625 / Staff Sink                                     |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:31 | 03/22/24 | DST     |           |
| 4031402-48 | Sample Location: 22070500-083CF/ Biology Prep Room North East-3rd Floor Main Bld Sink 907A / Classroom Sink |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:49 | 03/22/24 | DST     |           |
| 4031402-49 | Sample Location: 22070500-084CF/ Biology Prep Room North West-3rd Floor Main Bldg Sink 905 / Classroom Sink |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:47 | 03/22/24 | DST     |           |
| 4031402-50 | Sample Location: 22070500-085OT/ Greenhouse-Science Behind NW Biology Prep Room-3rd Floor 904 / Greenhouse  |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:52 | 03/22/24 | DST     |           |
| 4031402-51 | Sample Location: 22070500-086BF/ Boys Restrm 3rd Floor West Side Of Bldg 929 / Restroom Sink                |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | 1.5    | ppb   | 1.0 | 15  | 03/08/24 08:44 | 03/22/24 | DST     |           |
| 4031402-52 | Sample Location: 22070500-087BF/ Boys Restrm 3rd Floor East Side Of Bldg 912 / Restroom Sink                |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:43 | 03/22/24 | DST     |           |
| 4031402-53 | Sample Location: 22070500-088BF/ Girls Restrm 3rd Floor East Side Of Bldg 913 / Restroom Sink               |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:35 | 03/22/24 | DST     |           |
| 4031402-54 | Sample Location: 22070500-089BF/ Girls Restrm 3rd Floor West Side Of Bldg 930 / Restroom Sink               |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:42 | 03/22/24 | DST     |           |
| 4031402-55 | Sample Location: 22070500-090CF/ Science Prep Room South West-3rd Floor Main Bldg Sink 936 / Classroom Sink |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:39 | 03/22/24 | DST     |           |

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 4031402

Method: USEPA 200.8

Matrix: Drinking Water

|            | Sample Location  | Code | Result | Units | MRL | MCL | Sampled        | Analyzed | Analyst | Qualifier |
|------------|--|------|--------|-------|-----|-----|----------------|----------|---------|-----------|
| 4031402-56 | Sample Location: 22070500-091CF/ Science Prep Room South East-3rd Floor Main Bdg Sink 940 / Classroom Sink |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:38 | 03/22/24 | DST     |           |
| 4031402-57 | Sample Location: 22070500-092WB/ East Corridor 3rd Floor Main Bdg 910 / Water Bottle Filler                |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:55 | 03/22/24 | DST     |           |
| 4031402-58 | Sample Location: 22070500-093DW/ East Corridor 3rd Floor Main Bdg 910 / Drinking Fountain                  |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:56 | 03/22/24 | DST     |           |
| 4031402-59 | Sample Location: 22070500-094WB/ West Corridor 3rd Floor Main Bdg / Water Bottle Filler                    |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:43 | 03/22/24 | DST     |           |
| 4031402-60 | Sample Location: 22070500-095BF/ Building 4 Boys Restroom Left Sink 121 / Classroom Sink-1                 |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 09:00 | 03/22/24 | DST     |           |
| 4031402-61 | Sample Location: 22070500-096BF/ Building 4 Boys Restroom Right Sink 121 / Classroom Sink-2                |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | 2.4    | ppb   | 1.0 | 15  | 03/08/24 09:00 | 03/22/24 | DST     |           |
| 4031402-62 | Sample Location: 22070500-097DW/ Building 4 Corridor Drinking Fountain 114                                 |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 09:04 | 03/22/24 | DST     |           |
| 4031402-63 | Sample Location: 22070500-098WB/ Building 4 Corridor Bottle Filler 114                                     |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 09:05 | 03/22/24 | DST     |           |
| 4031402-64 | Sample Location: 22070500-099BF/ Building 4 Girls Restroom Left Sink 118 / Classroom Sink-1                |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 09:08 | 03/22/24 | DST     |           |
| 4031402-65 | Sample Location: 22070500-100BF/ Building 4 Girls Restroom Right Sink 118 / Classroom Sink-2               |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 09:08 | 03/22/24 | DST     |           |
| 4031402-66 | Sample Location: 22070500-101CF/ Classroom #416 Left Sink 108 / Classroom Sink-1                           |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | 23.9   | ppb   | 1.0 | 15  | 03/08/24 09:12 | 03/22/24 | DST     |           |
| 4031402-67 | Sample Location: 22070500-102CF/ Classroom #416 Right Sink 108 / Classroom Sink-2                          |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | 4.7    | ppb   | 1.0 | 15  | 03/08/24 09:12 | 03/22/24 | DST     |           |
| 4031402-68 | Sample Location: 22070500-103OT/ Greenhouse Bld 4 - Sink 107   |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 09:13 | 03/22/24 | DST     |           |
| 4031402-69 | Sample Location: 22070500-104CF/ Greenhouse Prep Classroom #416A Sink 105 / Classroom Sink                 |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |  | 1030 | 6.2    | ppb   | 1.0 | 15  | 03/08/24 09:13 | 03/22/24 | DST     |           |
| 4031402-70 | Sample Location: 22070500-105KF/ Warberg Concessions Sink 424 / Kitchen Sink                               |      |        |       |     |     |                |          |         |           |

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 4031402

Method: USEPA 200.8

Matrix: Drinking Water

|            | Sample Location   | Code | Result | Units | MRL | MCL | Sampled        | Analyzed | Analyst | Qualifier |
|------------|---|------|--------|-------|-----|-----|----------------|----------|---------|-----------|
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 09:55 | 03/22/24 | DST     |           |
| 4031402-71 | Sample Location: 22070500-106BF/ Warberg Girls Locker Room 407 / Restroom Sink                |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:09 | 03/22/24 | DST     |           |
| 4031402-72 | Sample Location: 22070500-107BF/ Warberg Girls Locker Rm 408 / Office Restroom Sink           |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | 3.2    | ppb   | 1.0 | 15  | 03/08/24 08:09 | 03/22/24 | DST     |           |
| 4031402-73 | Sample Location: 22070500-108NS/ Warberg Sports Trainer Office Sink 410A / Training Room Sink |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | 1.1    | ppb   | 1.0 | 15  | 03/08/24 08:10 | 03/22/24 | DST     |           |
| 4031402-74 | Sample Location: 22070500-109BF/ Warberg Boys Locker Rm 421 / Office Restroom Sink            |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:05 | 03/22/24 | DST     |           |
| 4031402-75 | Sample Location: 22070500-110BF/ Warberg Boys Locker Room 422 / Restroom Sink                 |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:03 | 03/22/24 | DST     |           |
| 4031402-76 | Sample Location: 22070500-111WB/ West Warberg Gym 431 / Water Bottle Filler                   |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:22 | 03/22/24 | DST     |           |
| 4031402-77 | Sample Location: 22070500-112DW/ East Warberg Gym 431 / Drinking Fountain-2                   |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:00 | 03/22/24 | DST     |           |
| 4031402-78 | Sample Location: 22070500-113WB/ East Warberg Gym 431 / Water Bottle Filler                   |      |        |       |     |     |                |          |         |           |
| Lead (‡)   |   | 1030 | ND     | ppb   | 1.0 | 15  | 03/08/24 08:00 | 03/22/24 | DST     |           |


UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager





# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 3120104

|                           |                                  |                               |
|---------------------------|----------------------------------|-------------------------------|
| Pendleton School District | Project: General                 | Date Reported: 12/07/23       |
| 107 NW 10th Street        | Project #: Pendleton High School | Date Received: 12/01/23 10:35 |
| Pendleton, OR 97801       | Client Contact: Michelle Jones   | Sampled By: Michelle Jones    |

Method: USEPA 200.8

Matrix: Drinking Water

| Sample Location                                | Code | Result | Units | MRL | MCL | Sampled        | Analyzed | Analyst | Qualification |
|--|------|--------|-------|-----|-----|----------------|----------|---------|---------------|
| 3120104-02 Sample Location: Pendleton HS 051BF |      |        |       |     |     |                |          |         |               |
| Lead (†)                                       | 1030 | ND     | ppb   | 1.0 | 15  | 11/14/23 07:00 | 12/04/23 | DST     |               |
| 3120104-03 Sample Location: Pendleton HS 046BF |      |        |       |     |     |                |          |         |               |
| Lead (†)                                       | 1030 | 2.0    | ppb   | 1.0 | 15  | 11/14/23 07:05 | 12/04/23 | DST     |               |

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 4031402


### Qualifiers and Definitions

|     |  |
|-----|--|
| DET | Analyte DETECTED   |
| ND  | Analyte NOT DETECTED at or above the MRL (minimum reporting limit)   |
| NA  | Not Applicable   |
| NR  | Not Reported   |
| dry | Sample results reported on a dry weight basis  |
| RPD | Relative Percent Difference  |
| MRL | Minimum Reporting Limit  |
| MDL | Minimum Detection Limit  |
| MCL | Maximum Contamination Level  |
| (‡) | ORELAP Accredited Analyte  |
| (~) | Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values. |

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

  
\_\_\_\_\_  
Dan Phillips, Laboratory Manager