





# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: http://ChemLab.cc  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 4031401

Pendleton School District  
107 NW 10th Street  
Pendleton, OR 97801

Project: General  
Project #: Washington Annex Lead Testing  
  
Client Contact: Michelle Jones

Date Reported: 03/21/24  
Date Received: 03/13/24 11:00  
Sampled By: T. Baum

Method: USEPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
4031401-01	Sample Location: 22070004-001DW/Drinking Fountain									
Lead (‡)		1030	5.0	ppb	1.0	15	03/06/24 09:30	03/20/24	DST	
4031401-02	Sample Location: 22070004-002BF/Womans Bathroom / Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 09:30	03/20/24	DST	
4031401-03	Sample Location: 22070004-003BF/Mens Bathroom / Sink									
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 09:30	03/20/24	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 4031401

### Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager