

## Lead in Water Test Results Summary: Hitting Facility

**Notes:**

- The lead in water **Action Level** is 15 parts per billion (ppb).


*Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.*

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.

**Legend:**

- Test results **equal to or greater than the Action Level** of 15 ppb are **highlighted in red and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **near the Action Level** of 15 ppb (11.99 to 14.99 ppb) are **highlighted in yellow and precede a "Med" (Medium) value** in the "Initial Level" or "Final Level" column.

[illegible]



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 4031437

Pendleton School District  
107 NW 10th Street  
Pendleton, OR 97801

Project: General  
Project #: PHS Hitting Facility Lead Testing

Client Contact: Michelle Jones

Date Reported: 03/26/24  
Date Received: 03/13/24 11:00  
Sampled By: T. Baum

### Method: USEPA 200.8


Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
4031437-01	Sample Location: 22070005-010DW/Hitting Facility-Short Drinking Fountain									
Lead (†)		1030	ND	ppb	1.0	15	03/06/24 10:40	03/21/24	DST	
4031437-02	Sample Location: 22070005-011DW/Hitting Facility-Tall / Drinking Fountain									
Lead (†)		1030	ND	ppb	1.0	15	03/06/24 10:41	03/21/24	DST	
4031437-03	Sample Location: 22070005-012BF/Hitting Facility-Girls East Restroom Sink / Drinking Fountain									
Lead (†)		1030	ND	ppb	1.0	15	03/06/24 10:42	03/21/24	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

  
Dan Phillips, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 4041111

Pendleton School District  
107 NW 10th Street  
Pendleton, OR 97801

Project: General  
Project #: PHS Hitting Facility Lead Testing  
Client Contact: Michelle Jones

Date Reported: 04/18/24  
Date Received: 04/11/24 10:15  
Sampled By: T. Baum

### Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
4041111-01	Sample Location: 22070005-013BF-Hitting Facility / Boys West Restroom Sink									
Lead (†)		1030	ND	ppb	1.0	15	04/03/24 06:21	04/15/24	DST	

UMPQUA Research Company/MC

Dan Phillips, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 4041111

### Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Dan Phillips, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.