Lead in Water Test Results Summary: PHS - Wrestling Building

Notes:

- The lead in water Action Level is 15 parts per billion (ppb).

 Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.

Legend:

- Test results equal to or greater than the Action Level of 15 ppb are highlighted in red and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results near the Action Level of 15 ppb (11.99 to 14.99 ppb) are highlighted in yellow and precede a "Med" (Medium) value in the "Initial Level" or "Final Level" column.

		Initial	Initial Test	Initial	Final	Final Test	Final
Fixture Location Description	Fixture ID #	Test Date	Result (ppb)	Level	Retest Date	Result (ppb)	Level
WOMEN'S RESTROOM - LEFT SINK	22070002-001BF	3/6/2024	ND	Low	[enter date]	[enter result]	[autofill]
WOMEN'S RESTROOM - RIGHT SINK	22070002-002BF	3/6/2024	ND	Low			
MEN'S RESTROOM SINK	22070002-003BF	3/6/2024	ND	Low			
DRINKING FOUNTAIN-SHORT	22070002-004DW	3/6/2024	ND	Low			
DRINKING FOUNTAIN-TALL	22070002-005DW	3/6/2024	ND	Low			



UMPQUA Research Company

626 NE Division St. - P.O. Box 609 Myrtle Creek, Oregon 97457 (541) 863-5201 Fax: (541) 863-6199

E-mail: Lab@URCmail.net Internet: http://ChemLab.cc ORELAP ID# OR100031

Pendleton School District

107 NW 10th Street

Pendleton, OR 97801

Project: General

Project #: PHS Wrestling Building Lead Testing

Date Reported:

03/21/24

ANALYSIS REPORT

URC#

Date Received:

03/13/24 11:00

4031403

Sampled By:

T. Baum

Client Contact: Michelle Jones

Method: USEPA 200.8								Matrix: Drinking Water				
	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst Qualifier			
4031403-01	Sample Location: 22070002-001BF/Women's Restroom / Sink-1											
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 10:20	03/20/24	DST			
4031403-02	Sample Location: 22070002-002BF/Women's Restroom / Sink-2											
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 10:21	03/20/24	DST			
4031403-03	Sample Location: 22070002-003BF/Men's Restroom / Sink											
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 10:21	03/20/24	DST			
4031403-04	Sample Location: 22070002-004DW/Drinking Fountain-Short											
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 10:22	03/20/24	DST			
'031403-05	3-05 Sample Location: 22070002-005DW/Drinking Fountain-Short											
Lead (‡)		1030	ND	ppb	1.0	15	03/06/24 10:23	03/20/24	DST			

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609 Myrtle Creek, Oregon 97457 (541) 863-5201 Fax: (541) 863-6199

E-mail: Lab@URCmail.net Internet: http://ChemLab.cc ORELAP ID# OR100031

ANALYSIS REPORT URC # 4031403

Qualifiers and Definitions

DET Analyte DETECTED

ND Analyte NOT DETECTED at or above the MRL (minimum reporting limit)

NA Not Applicable
NR Not Reported

dry Sample results reported on a dry weight basis

RPD Relative Percent Difference

MRL Minimum Reporting Limit

MDL Minimum Detection Limit

MCL Maximum Contamination Level

(‡) ORELAP Accredited Analyte

(~) Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager